

KLEINZICKEN, Austria

WMO: 111920

Lat: 47.208N

Lon: 16.336E

Elev: 267

StdP: 98.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-9.3	-15.0	1.1	-11.3	-12.1	1.4	-8.0	8.4	0.8	7.3	0.3	0.9	330	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	31.5	21.2	29.6	20.6	27.9	19.8	22.0	29.4	21.2	28.2	20.3	26.7	2.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.9	24.9	18.8	14.1	23.9	18.0	13.4	23.0	65.7	29.5	62.5	28.3	59.6	26.8	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.1	5.1	-15.8	33.8	3.8	2.6	-18.6	35.6	-20.8	37.1	-23.0	38.6	-25.7	40.4		
(5)			-16.1	23.6	3.6	1.2	-18.6	24.5	-20.7	25.2	-22.7	25.9	-25.3	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	-1.1	1.2	5.2	10.5	14.7	18.4	20.2	19.7	15.0	10.2	5.2	0.2		
	DBStd	8.26	3.95	4.29	4.18	3.69	3.20	3.28	3.02	2.96	3.17	3.69	3.97	3.96		
	HDD10.0	1282	343	246	153	38	2	0	0	0	1	44	151	303		
	HDD18.3	3230	602	479	406	234	118	39	17	18	107	252	395	562		
	CDD10.0	1286	0	0	5	54	149	252	316	302	152	50	6	0		
	CDD18.3	192	0	0	0	0	6	42	74	62	8	0	0	0		
	CDH23.3	2133	0	0	0	14	109	458	804	659	87	3	0	0		
	CDH26.7	643	0	0	0	1	14	127	265	226	11	0	0	0		
(14) Wind	WSAvg	1.9	1.7	1.9	2.2	2.3	2.2	1.9	1.9	1.7	1.8	1.5	1.6	1.6		
(15) Precipitation	PrecAvg	717	26	30	38	46	75	95	90	85	78	62	54	38		
	PrecMax	969	69	97	78	88	138	169	152	167	165	156	136	78		
	PrecMin	517	6	5	3	3	26	26	13	12	23	0	3	3		
	PrecStd	107	17	27	22	21	30	37	37	39	40	37	30	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	15.6	20.2	25.4	28.4	32.0	33.5	34.1	28.1	23.5	18.3	12.4		
		MCWB	7.6	9.1	11.8	16.0	19.1	21.7	22.0	21.0	19.1	16.6	13.6	9.3		
	2%	DB	8.6	12.2	17.5	22.6	26.1	29.9	31.4	31.6	25.7	21.0	15.3	8.9		
		MCWB	5.6	7.5	10.8	14.1	18.1	21.1	21.3	20.8	18.3	15.4	11.8	6.5		
	5%	DB	6.0	9.7	15.1	20.6	24.2	28.0	29.5	29.3	23.8	18.9	13.0	6.8		
		MCWB	4.0	6.1	9.5	13.2	17.0	20.0	20.5	20.4	17.5	14.4	10.6	4.9		
	10%	DB	4.3	7.5	12.7	18.6	22.4	26.0	27.8	27.1	21.7	16.7	11.0	5.2		
		MCWB	2.7	4.8	8.2	12.1	15.8	18.9	19.7	19.5	16.2	13.3	9.0	3.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.6	12.5	16.5	20.1	22.9	23.1	23.0	20.2	17.4	13.9	9.6		
		MCDB	10.7	14.7	19.0	24.1	27.2	29.4	30.5	29.8	26.3	22.2	17.4	12.2		
	2%	WB	5.9	7.9	11.0	14.9	18.6	21.6	22.1	21.7	19.0	16.0	12.2	6.9		
		MCDB	8.0	11.8	16.6	21.8	24.8	28.5	29.5	29.2	24.5	19.9	14.7	8.5		
	5%	WB	4.4	6.5	9.9	13.7	17.5	20.6	21.2	20.9	18.0	14.9	10.7	5.2		
		MCDB	5.9	9.4	14.5	19.5	23.2	27.0	28.1	28.0	22.7	18.3	12.8	6.4		
	10%	WB	2.9	5.0	8.5	12.5	16.4	19.6	20.3	19.9	16.8	13.7	9.3	4.0		
		MCDB	4.0	7.2	12.4	17.7	21.5	25.1	26.5	26.1	20.7	16.4	10.8	4.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	8.8	10.5	11.9	11.5	11.7	12.2	12.1	10.6	10.3	7.1	5.9		
		MCDBR	9.5	13.1	15.7	16.3	15.3	15.1	15.5	16.3	14.1	13.6	11.1	8.8		
		MCWBR	6.9	8.8	9.4	8.6	7.8	7.0	6.4	6.6	7.1	8.5	7.7	6.5		
		MCWBR	9.2	12.4	14.9	14.7	14.0	14.4	14.2	14.7	13.0	12.7	10.4	8.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.315	0.340	0.378	0.423	0.420	0.426	0.430	0.433	0.405	0.377	0.346	0.314		
		taud	2.399	2.351	2.278	2.173	2.229	2.253	2.244	2.247	2.297	2.348	2.391	2.429		
		Ebn at Noon	765	819	837	829	846	841	832	811	799	762	715	721		
		Edh at Noon	70	90	113	138	135	133	132	127	110	90	71	61		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.13	1.95	3.13	4.47	5.35	5.83	5.74	5.09	3.63	2.35	1.26	0.88		
		RadStd	0.12	0.27	0.38	0.44	0.52	0.41	0.44	0.52	0.43	0.24	0.14	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (90 neighbors)	+0.56	N/A	N/A	+0.90	+0.47	+0.41	-112	-151	+92	+57

Nomenclature: See separate page