

NEUSIEDL AM SEE, Austria

WMO: 111940

Lat: 47.951N

Lon: 16.842E

Elev: 486

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.6	18.8	7.5	8.2	16.3	12.6	10.6	21.2	21.2	40.0	18.8	36.8	6.9	330	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	90.6	72.6	87.1	71.0	84.0	69.3	73.8	88.1	71.9	84.8	70.2	81.9	6.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	108.2	81.6	67.3	102.1	79.1	65.8	96.8	77.1	37.6	88.9	35.9	85.1	34.4	82.1	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	15.7	13.9	10.5	95.2	6.1	4.2	6.1	98.3	2.5	100.8	-1.0	103.2	-5.4	106.2
			9.7	76.3	5.8	2.0	5.5	77.7	2.1	78.8	-1.2	79.9	-5.4	81.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	32.2	35.8	43.5	53.5	61.5	67.5	71.5	70.7	61.8	52.3	43.2	34.1	(6)
	DBStd	15.51	7.97	8.22	7.62	7.65	6.44	6.52	6.36	5.96	6.30	7.25	7.38	7.51	(7)
	HDD50	2010	551	399	227	53	1	0	0	0	1	61	224	493	(8)
	HDD65	5214	1015	817	665	348	148	48	15	16	136	396	653	957	(9)
	CDD50	2885	1	2	26	158	356	524	666	643	355	132	21	1	(10)
	CDD65	615	0	0	0	3	39	122	216	193	40	2	0	0	(11)
	CDH74	5138	0	0	0	36	329	1016	1929	1583	235	10	0	0	(12)
	CDH80	1724	0	0	0	4	58	306	748	570	38	0	0	0	(13)
(14) Wind	WSAvg	6.4	7.1	7.2	7.4	7.1	6.4	5.8	6.0	5.4	5.8	5.7	6.6	6.4	(14)
(15) Precipitation	PrecAvg	23.7	1.2	1.1	1.6	1.5	2.5	2.8	2.9	2.6	2.5	1.9	1.8	1.4	(15)
	PrecMax	30.9	2.7	2.8	3.3	3.3	5.7	6.0	7.8	6.3	6.5	3.8	3.9	2.8	(16)
	PrecMin	15.5	0.2	0.0	0.2	0.0	0.6	0.9	0.2	0.3	0.7	0.1	0.0	0.3	(17)
	PrecStd	3.5	0.7	0.8	0.9	0.9	1.3	1.3	1.7	1.5	1.7	1.0	0.8	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.1	59.6	68.6	78.5	85.3	91.0	94.9	94.9	84.3	75.0	65.1	55.3	(19)
		MCWB	47.4	49.2	54.7	61.3	68.2	72.7	75.5	73.1	69.1	63.4	56.3	48.5	(20)
	2%	DB	50.8	54.0	63.6	73.8	81.2	87.1	90.9	90.4	80.0	69.7	60.5	49.4	(21)
		MCWB	44.8	46.6	52.3	59.4	66.3	71.2	73.0	72.4	66.7	60.7	54.1	44.6	(22)
	5%	DB	46.9	50.2	59.1	70.1	77.8	83.6	87.5	86.2	76.4	66.3	56.7	45.7	(23)
		MCWB	42.0	44.6	49.8	57.6	64.1	69.2	71.2	70.5	64.6	59.2	51.7	41.9	(24)
	10%	DB	43.3	46.8	55.3	66.4	74.2	80.1	84.2	82.5	72.6	62.7	53.3	43.1	(25)
		MCWB	39.5	42.3	47.8	55.2	61.9	67.2	69.6	68.6	62.8	56.7	49.2	40.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	49.9	55.8	63.2	70.0	75.0	76.7	75.9	70.0	64.1	57.4	49.2	(27)
		MCDB	53.8	58.1	66.3	76.8	83.1	88.5	92.6	91.1	81.6	73.1	63.7	54.1	(28)
	2%	WB	45.6	47.2	53.0	60.3	67.1	72.5	73.9	73.4	67.8	62.1	54.5	44.9	(29)
		MCDB	50.7	53.0	61.6	72.0	79.2	84.6	88.6	88.3	77.3	68.3	59.8	48.6	(30)
	5%	WB	42.3	45.0	50.6	58.2	65.0	70.2	72.2	71.1	65.9	59.8	52.2	42.6	(31)
		MCDB	45.9	49.7	57.7	68.4	75.9	81.4	85.5	84.0	74.5	64.8	56.5	45.1	(32)
	10%	WB	39.7	42.7	48.4	56.2	63.0	68.2	70.3	69.4	63.9	57.7	49.5	40.5	(33)
		MCDB	42.9	46.4	54.4	65.0	72.2	78.2	82.1	80.8	71.0	61.9	52.7	42.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	11.1	14.2	17.5	17.7	18.0	18.4	18.0	15.3	13.4	9.2	7.3	(35)
		MCDBR	12.8	16.7	21.1	22.7	23.3	22.9	23.5	24.1	20.9	17.5	14.2	11.9	(36)
	5% WB	MCWBR	8.5	10.8	12.2	11.7	10.9	9.8	9.3	10.0	9.7	9.4	8.9	8.6	(37)
		MCWBR	11.9	15.6	19.9	21.4	22.2	21.7	22.2	22.8	19.4	15.9	13.7	11.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.321	0.345	0.382	0.426	0.423	0.426	0.434	0.434	0.408	0.378	0.352	0.320	(40)
		taud	2.379	2.349	2.267	2.168	2.224	2.251	2.231	2.246	2.288	2.344	2.372	2.402	(41)
	Ebn at Noon		236	256	262	261	267	266	262	256	251	239	220	221	(42)
		Edh at Noon	22	28	36	44	43	42	42	40	35	28	23	19	(43)
(44) All-Sky Solar Radiation	RadAvg		320	579	956	1431	1692	1843	1785	1590	1137	698	363	249	(44)
	RadStd		35	78	122	141	176	133	156	153	136	76	35	29	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (83 neighbors)	+1.03	N/A	N/A	+1.55	+0.85	+0.76	-216	-297	+164	+85	(47)

Nomenclature: See separate page