

WEITENSFELD, Austria

WMO: 112250

Lat: 46.8492N

Lon: 14.1908E

Elev: 2337

StdP: 13.50

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.2	9.6	1.9	6.6	8.4	5.9	8.1	12.0	14.5	37.2	11.4	37.6	3.1	280	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.9	85.7	67.6	82.5	66.1	79.5	64.9	69.1	82.3	67.5	79.6	65.9	77.0	4.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	99.7	74.8	63.1	94.3	72.8	61.7	89.7	70.6	34.6	82.3	33.2	79.6	31.9	77.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	8.8	7.2	-0.6	90.5	4.9	2.9	-4.1	92.6	-7.0	94.3	-9.8	95.9	-13.4	98.0		
			-1.0	71.9	4.9	1.6	-4.5	73.1	-7.3	74.1	-10.1	75.0	-13.6	76.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	27.3	31.3	39.1	47.6	54.7	61.9	65.3	64.6	56.6	47.9	39.1	28.2
	DBStd	14.69	6.87	7.02	6.06	5.77	5.68	5.53	5.16	5.29	5.97	6.38	6.64	6.82
	HDD50	2831	705	524	338	109	21	1	0	0	13	116	328	676
	HDD65	6721	1170	944	803	523	322	122	61	73	255	529	778	1141
	CDD50	1750	0	0	0	36	165	358	473	454	211	52	1	0
	CDD65	166	0	0	0	0	2	30	69	62	3	0	0	0
	CDH74	2250	0	0	0	11	91	528	857	698	65	0	0	0
	CDH80	574	0	0	0	0	10	132	233	196	3	0	0	0
Wind	WSAvg	3.1	2.9	3.0	3.4	3.5	3.5	3.4	3.2	3.0	2.8	3.1	2.7	2.8
Precipitation	PrecAvg	39.2	1.1	1.3	2.0	2.6	3.6	4.8	5.6	5.5	3.9	3.7	3.4	1.8
	PrecMax	50.2	3.7	5.6	3.9	4.3	5.8	7.2	11.5	8.9	6.5	9.0	9.0	4.8
	PrecMin	31.3	0.2	0.1	0.3	0.6	1.6	2.4	1.5	3.1	1.8	0.0	0.2	0.2
	PrecStd	4.6	0.7	1.1	1.0	0.9	1.0	1.2	2.0	1.7	1.3	2.0	2.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	57.1	66.3	75.3	80.9	88.3	89.3	90.3	79.0	71.1	58.2	46.2
		MCWB	40.8	45.6	49.9	58.4	62.8	66.7	69.6	69.9	64.2	60.0	51.4	39.1
	2%	DB	42.5	49.7	61.9	69.8	76.2	83.7	85.6	85.1	75.7	66.4	53.5	42.4
		MCWB	37.9	41.3	48.2	54.6	60.4	65.8	68.1	67.7	63.3	56.9	49.5	37.9
	5%	DB	39.0	45.1	56.7	66.0	72.7	80.2	82.4	81.5	72.1	62.8	50.5	39.4
		MCWB	35.4	38.1	45.8	52.2	58.6	64.2	66.4	66.5	61.6	55.1	48.0	36.0
	10%	DB	36.1	41.1	52.0	61.7	68.6	76.3	79.0	77.7	68.0	58.4	48.0	36.6
		MCWB	33.5	36.0	43.4	50.5	56.5	62.4	65.2	65.0	59.2	52.6	46.2	34.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.0	45.7	51.2	58.8	64.2	69.1	71.3	70.9	65.7	60.3	52.1	41.9
		MCDB	46.1	56.8	64.6	74.8	76.2	83.5	85.2	85.5	75.8	69.0	55.2	44.0
	2%	WB	39.2	41.8	48.6	55.7	61.6	67.1	69.3	69.1	64.0	57.9	50.2	39.1
		MCDB	42.6	48.5	60.4	67.1	74.5	80.4	82.4	82.2	73.8	65.0	52.5	41.5
	5%	WB	36.0	38.9	46.4	53.1	59.4	65.2	67.6	67.5	62.4	55.7	48.4	36.8
		MCDB	38.1	44.1	55.6	63.0	70.5	77.8	79.9	79.0	71.0	61.5	50.4	38.7
	10%	WB	34.0	36.6	43.8	51.1	57.4	63.3	65.8	65.8	60.4	53.5	46.1	34.9
		MCDB	35.5	40.4	50.9	59.7	66.9	74.6	76.9	76.2	66.6	57.9	47.8	36.3
Mean Daily Temperature Range	5% DB	MDBR	15.8	18.9	23.3	24.0	23.2	23.4	23.9	23.6	20.2	19.3	13.1	15.3
		MCDBR	18.1	26.5	32.5	33.5	31.1	31.1	30.1	30.1	25.7	25.1	17.4	18.2
		MCWBR	13.3	17.9	19.7	18.4	16.0	14.7	13.7	14.0	14.1	16.0	12.4	13.9
	5% WB	MCDBR	15.1	23.7	30.5	29.3	28.2	28.0	28.3	27.4	23.6	23.1	15.5	15.4
		MCWBR	11.5	16.6	18.9	16.4	14.8	13.8	13.5	13.5	13.2	14.9	11.4	12.3
Clear-Sky Solar Irradiance	taub	0.278	0.306	0.349	0.394	0.404	0.411	0.411	0.405	0.374	0.349	0.315	0.280	
	taud	2.424	2.367	2.320	2.256	2.278	2.298	2.300	2.332	2.395	2.444	2.486	2.480	
	Ebn at Noon	261	274	276	272	273	272	270	266	265	255	244	248	
	Edh at Noon	22	28	34	40	41	40	40	37	32	26	21	18	
All-Sky Solar Radiation	RadAvg	413	684	1033	1331	1578	1756	1767	1559	1131	758	425	343	
	RadStd	51	95	127	156	170	133	136	169	144	83	69	50	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (94 neighbors)	+0.88	N/A	N/A	+1.46	+0.85	+0.67	N/A	-239	+160	+99

Nomenclature: See separate page