

ST ANDRAE LAVANTTAL, Austria

WMO: 112290

Lat: 46.764N

Lon: 14.828E

Elev: 404

StdP: 96.57

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-10.5	-14.5	1.1	-11.5	-12.3	1.4	-8.6	5.8	0.7	4.9	1.3	0.7	20	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	31.3	21.3	29.5	20.8	27.8	20.0	22.4	29.3	21.4	28.0	20.6	26.6	1.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.5	26.1	19.1	14.6	24.7	18.3	13.9	23.5	67.7	29.5	64.1	28.4	61.0	26.7	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.0	3.0	DB	-15.6	34.2	3.8	1.6	-18.3	35.3	-20.6	36.3	-22.7	37.2	-25.5	38.3	(4)
(5)			WB	-15.8	24.0	3.8	0.9	-18.5	24.7	-20.7	25.2	-22.8	25.7	-25.6	26.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-2.1	0.7	5.5	10.3	14.7	18.7	20.3	19.6	14.9	9.8	4.7	-0.8	(6)	
	DBStd	8.49	3.91	3.84	3.76	3.30	3.35	3.47	3.14	2.93	3.20	3.67	3.78	3.50	(7)	
	HDD10.0	1364	374	260	142	36	3	0	0	0	1	49	163	336	(8)	
	HDD18.3	3336	632	493	397	239	121	37	17	21	111	263	410	594	(9)	
	CDD10.0	1273	0	0	3	46	148	262	321	298	148	44	3	0	(10)	
	CDD18.3	203	0	0	0	0	7	48	79	61	8	0	0	0	(11)	
	CDH23.3	1992	0	0	0	9	136	498	753	530	65	1	0	0	(12)	
	CDH26.7	610	0	0	0	0	23	148	268	164	6	0	0	0	(13)	
(14) Wind	WSAvg	1.2	1.0	1.1	1.3	1.5	1.4	1.3	1.2	1.1	1.0	1.1	1.0	0.9	(14)	
(15) Precipitation	PrecAvg	902	25	31	39	58	92	114	127	128	97	82	67	43	(15)	
	PrecMax	1144	69	112	88	119	143	206	298	232	153	182	162	97	(16)	
	PrecMin	676	4	0	4	14	47	67	29	44	49	0	3	3	(17)	
	PrecStd	112	16	28	24	26	32	35	55	46	28	45	37	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	14.0	20.3	24.6	29.3	32.3	34.1	33.4	27.5	22.8	15.9	8.9	(19)	
		MCWB	6.0	8.3	11.5	15.1	18.9	21.4	22.5	21.6	19.8	16.4	12.0	6.7	(20)	
	2%	DB	5.9	10.4	17.7	22.3	26.6	30.1	31.7	30.3	25.2	20.0	13.2	6.2	(21)	
		MCWB	3.8	6.0	10.6	13.4	17.6	20.8	21.9	21.1	18.7	14.8	11.1	4.7	(22)	
	5%	DB	4.2	8.0	15.4	20.4	24.7	28.4	29.6	28.4	23.2	17.9	11.4	4.7	(23)	
		MCWB	2.6	4.6	9.5	12.7	16.6	20.1	21.0	20.8	17.5	13.8	9.9	3.8	(24)	
	10%	DB	2.7	5.9	12.9	18.1	22.4	26.4	27.7	26.4	21.1	15.7	10.0	3.5	(25)	
		MCWB	1.6	3.5	8.0	11.7	15.5	19.1	20.2	19.8	16.4	12.6	9.0	2.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	8.5	12.1	15.7	19.8	22.9	23.6	23.5	20.3	16.8	12.8	7.4	(27)	
		MCDB	7.8	13.5	18.7	23.8	26.8	30.1	31.5	29.5	26.0	21.8	14.6	8.5	(28)	
	2%	WB	4.3	6.4	10.9	14.1	18.4	21.6	22.5	22.2	19.1	15.4	11.4	5.1	(29)	
		MCDB	5.7	9.9	17.0	20.6	25.3	28.6	30.2	28.2	24.0	19.1	12.9	5.8	(30)	
	5%	WB	2.8	5.0	9.7	13.1	17.1	20.5	21.5	21.2	18.1	14.2	10.1	4.0	(31)	
		MCDB	3.8	7.3	14.8	19.1	23.7	27.0	28.4	27.3	22.3	17.3	11.2	4.5	(32)	
	10%	WB	1.7	3.7	8.4	12.1	15.9	19.4	20.6	20.2	16.9	13.0	9.0	2.9	(33)	
		MCDB	2.4	5.6	12.3	17.4	21.3	25.3	26.7	25.6	20.2	15.3	10.0	3.4	(34)	
(35) Mean Daily Temperature Range	MDBR		6.9	9.2	12.4	12.5	12.5	12.4	12.7	12.2	10.8	10.0	6.1	5.2	(35)	
	5% DB	MCDBR	8.0	12.7	17.3	17.7	16.6	15.9	15.9	15.6	13.8	13.1	8.6	6.8	(36)	
		MCWBR	5.8	8.4	10.3	9.3	8.0	7.2	6.8	7.2	7.3	8.0	6.1	5.2	(37)	
	5% WB	MCDBR	6.8	11.6	16.4	15.6	15.8	14.8	15.0	14.4	12.4	12.1	7.5	5.8	(38)	
		MCWBR	5.2	7.9	10.0	8.4	7.8	7.0	6.8	7.1	6.7	7.5	5.4	4.6	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.299	0.328	0.371	0.420	0.424	0.431	0.432	0.429	0.399	0.372	0.337	0.301	(40)	
	taud		2.423	2.352	2.291	2.196	2.234	2.258	2.259	2.280	2.337	2.387	2.439	2.474	(41)	
	Ebn at Noon		795	837	846	834	844	837	831	816	809	774	738	753	(42)	
	Edh at Noon		69	91	112	135	135	132	131	123	106	87	69	59	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.26	2.10	3.22	4.21	5.06	5.62	5.63	4.97	3.56	2.37	1.31	1.03	(44)	
	RadStd		0.17	0.30	0.40	0.47	0.51	0.39	0.41	0.54	0.46	0.26	0.20	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (96 neighbors)	+0.51	N/A	N/A	+0.87	+0.48	+0.39	-91	-137	+91	+56

Nomenclature: See separate page