

FEISTRITZ OB BLEIBURG, Austria

WMO: 112320

Lat: 46.559N

Lon: 14.767E

Elev: 531

StdP: 95.11

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.0	(c) -8.9	(d) -13.8	(e) 1.2	(f) -8.3	(g) -12.0	(h) 1.4	(i) -6.8	(j) 6.7	(k) -0.7	(l) 6.1	(m) -1.2	(n) 1.2	(o) 240	(p) 0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	30.8	21.2	28.9	20.3	27.1	19.6	22.0	29.4	21.0	27.6	20.1	26.0	2.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	15.0	26.4	18.6	14.3	25.0	17.8	13.6	23.6	66.7	29.7	63.4	27.7	59.9	26.0	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.3	5.4	4.8		-13.1	33.7	2.8	1.9	-15.2	35.1	-16.8	36.2	-18.4	37.3	-20.5	38.6	
				DB												
				WB	-13.5	23.6	2.8	1.0	-15.5	24.3	-17.1	24.8	-18.7	25.4	-20.7	26.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	-2.1	0.6	5.6	10.2	13.9	17.9	20.2	19.4	14.6	9.5	4.2	-1.4		
	DBStd	8.41	3.55	3.69	3.69	3.51	3.34	3.30	3.13	3.09	3.38	3.63	3.73	3.40		
	HDD10.0	1409	376	262	141	41	6	0	0	0	3	53	174	352		
	HDD18.3	3427	634	495	395	246	142	46	18	24	120	273	423	611		
	CDD10.0	1201	0	0	4	45	127	238	314	291	140	39	2	0		
	CDD18.3	178	0	0	0	0	4	34	74	57	7	0	0	0		
	CDH23.3	1664	0	0	0	5	64	367	690	497	41	0	0	0		
	CDH26.7	479	0	0	0	0	7	92	225	153	2	0	0	0		
(14) Wind	WSAvg	1.8	1.6	1.8	2.1	2.2	2.1	2.1	1.9	1.8	1.8	1.7	1.5	1.4		
(15) Precipitation	PrecAvg	1078	36	44	56	74	99	126	131	135	114	103	94	61		
	PrecMax	1380	101	148	115	157	153	236	216	236	190	250	198	150		
	PrecMin	879	4	0	13	14	46	58	39	52	51	0	10	6		
	PrecStd	118	22	38	31	34	36	43	50	44	38	57	48	38		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	13.3	19.4	23.9	27.6	31.9	33.4	34.0	26.5	22.0	13.9	8.4		
		MCWB	5.5	7.4	11.2	15.4	18.6	20.9	22.3	22.8	19.2	16.1	10.9	6.6		
	2%	DB	5.8	9.7	16.7	21.1	25.0	29.1	31.0	30.2	24.5	19.3	12.1	6.2		
		MCWB	3.8	5.7	9.9	13.0	16.9	20.1	21.3	21.1	18.5	14.3	10.6	4.8		
	5%	DB	3.9	7.6	14.5	19.2	23.1	27.2	29.3	28.1	22.4	17.2	10.8	4.2		
		MCWB	2.6	4.4	8.8	12.4	15.7	19.3	20.6	20.4	17.3	13.4	9.5	3.1		
	10%	DB	2.5	5.6	12.2	17.2	21.0	25.5	27.3	26.1	20.4	15.1	9.3	2.9		
		MCWB	1.5	3.2	7.6	11.4	14.9	18.3	19.8	19.5	16.2	12.3	8.4	2.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	7.9	11.3	16.0	19.9	22.4	23.2	23.2	19.7	16.2	12.0	7.0		
		MCDB	9.0	12.0	18.0	23.1	25.6	29.9	31.4	31.9	25.2	21.2	13.0	7.6		
	2%	WB	4.5	6.2	10.1	13.9	17.7	21.0	22.0	21.9	18.8	14.8	10.8	5.1		
		MCDB	5.7	9.3	16.0	19.5	23.7	27.3	29.6	29.3	23.7	18.6	11.8	5.8		
	5%	WB	2.7	4.8	9.1	12.7	16.3	19.7	21.1	20.9	17.7	13.7	9.5	3.3		
		MCDB	3.4	7.3	13.9	18.1	22.0	26.0	28.0	27.1	21.7	16.6	10.7	3.9		
	10%	WB	1.7	3.4	7.8	11.6	15.2	18.7	20.1	19.9	16.6	12.6	8.4	2.2		
		MCDB	2.3	5.3	11.6	16.3	20.3	24.6	26.2	25.3	19.8	14.9	9.4	2.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	7.1	10.3	10.2	10.6	11.2	11.7	11.6	9.3	8.7	4.9	4.6		
		MCDBR	6.9	11.1	14.5	14.5	14.5	14.8	14.9	14.9	12.1	11.6	7.3	6.5		
	5% WB	MCWBR	5.0	7.3	8.4	7.7	7.4	7.2	6.7	7.2	6.5	7.1	5.4	5.0		
		MCWBR	5.7	10.3	13.6	12.7	13.5	13.8	14.0	13.8	11.2	10.6	6.6	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.302	0.330	0.373	0.422	0.424	0.431	0.430	0.428	0.400	0.374	0.338	0.303		
		taud	2.419	2.347	2.279	2.180	2.222	2.246	2.251	2.273	2.322	2.370	2.425	2.472		
	Ebn at Noon		793	835	845	832	844	838	833	819	808	772	738	753		
		Edh at Noon	70	91	114	137	136	134	132	124	108	89	70	60		
(44) All-Sky Solar Radiation	RadAvg		1.27	2.10	3.26	4.23	5.14	5.74	5.75	5.06	3.61	2.38	1.31	1.05		
	RadStd		0.18	0.32	0.42	0.48	0.50	0.39	0.40	0.55	0.47	0.27	0.21	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (89 neighbors)		+0.50	N/A	N/A	+0.85	+0.46	+0.35	-85	-134	+92	+57

Nomenclature: See separate page