

BAD GLEICHENBERG, Austria

WMO: 112440

Lat: 46.8722N

Lon: 15.9036E

Elev: 271

StdP: 98.11

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-7.9	-13.3	1.2	-8.5	-10.7	1.6	-6.1	5.5	1.4	5.1	1.1	1.0	80	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	31.7	21.8	30.1	21.3	28.5	20.5	22.7	29.9	21.9	28.5	21.0	27.2	2.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.4	15.6	26.1	19.6	14.8	25.1	18.8	14.1	24.1	68.3	30.0	65.1	28.6	62.1	27.4	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.1	4.4	3.8	-13.5	33.9	3.6	1.9	-16.2	35.3	-18.3	36.4	-20.3	37.4	-23.0	38.8		
(5)			-13.9	24.1	3.5	0.7	-16.4	24.6	-18.5	25.0	-20.5	25.4	-23.0	26.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-0.2	1.7	6.2	11.8	15.4	19.4	21.3	20.7	16.0	10.8	6.2	0.8
	DBStd	8.32	3.97	4.20	3.95	3.60	3.23	3.12	2.99	2.99	3.36	3.66	3.86	3.72
	HDD10.0	1143	316	232	126	23	2	0	0	0	1	36	123	284
	HDD18.3	2983	574	466	376	197	101	24	9	11	85	235	363	542
	CDD10.0	1469	0	0	8	77	168	283	350	333	181	59	9	1
	CDD18.3	268	0	0	0	1	9	57	101	86	15	0	0	0
	CDH23.3	2579	0	0	0	29	114	578	959	779	113	6	0	0
	CDH26.7	792	0	0	0	2	13	168	328	266	15	0	0	0
Wind	WSAvg	1.6	1.5	1.5	1.8	1.8	1.7	1.7	1.5	1.5	1.4	1.4	1.3	1.7
Precipitation	PrecAvg	890	37	34	56	64	86	106	132	116	79	62	74	45
	PrecMax	1131	78	88	110	162	142	190	325	208	184	177	170	78
	PrecMin	692	1	6	21	12	33	67	58	53	16	1	19	12
	PrecStd	131	22	24	27	38	38	34	68	48	54	46	39	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	16.8	20.9	26.5	28.2	32.7	33.7	34.0	28.5	24.2	18.2	13.6
		MCWB	8.0	9.8	12.2	16.3	19.1	22.3	22.9	22.1	20.3	16.7	13.5	10.2
	2%	DB	9.6	12.9	18.6	23.6	26.2	30.4	31.7	31.6	26.4	21.4	15.7	10.4
		MCWB	6.9	7.9	11.1	14.4	18.0	21.3	22.0	21.7	19.1	15.7	12.5	8.2
	5%	DB	7.1	10.4	16.2	21.6	24.4	28.6	30.1	29.6	24.4	19.4	13.6	8.1
		MCWB	5.2	6.5	9.9	13.5	16.8	20.4	21.3	21.2	18.2	14.8	11.2	6.0
	10%	DB	5.3	8.0	13.6	19.4	22.6	26.8	28.4	27.7	22.5	17.1	11.7	5.9
		MCWB	3.9	5.0	8.6	12.5	15.8	19.2	20.5	20.5	17.1	13.5	10.0	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	10.2	12.5	16.7	20.3	23.3	23.9	23.5	21.0	17.7	14.3	10.3
		MCDB	11.0	16.1	19.5	25.6	26.9	30.5	32.2	31.5	27.5	23.2	17.1	12.5
	2%	WB	7.1	8.1	11.5	15.3	18.7	22.1	22.8	22.5	19.6	16.1	12.9	8.3
		MCDB	9.2	11.9	17.6	22.3	24.7	28.9	29.8	30.0	24.9	20.5	15.3	10.4
	5%	WB	5.4	6.8	10.2	14.0	17.5	20.9	21.9	21.7	18.8	15.0	11.5	6.3
		MCDB	6.9	9.9	15.3	19.9	22.9	27.2	28.6	28.2	23.6	18.9	13.5	7.9
	10%	WB	4.0	5.4	8.9	13.0	16.5	19.8	21.1	20.8	17.7	14.0	10.0	4.7
		MCDB	5.2	7.7	13.0	18.5	21.4	25.7	27.2	26.6	21.5	16.6	11.4	5.6
Mean Daily Temperature Range	5% DB	MDBR	6.6	8.4	11.0	11.9	10.9	11.2	11.5	11.5	9.9	9.9	6.9	6.6
		MCDBR	10.1	13.3	15.9	16.3	14.5	14.4	14.3	14.2	12.7	13.3	10.6	10.0
		MCWBR	7.1	8.5	8.9	7.8	6.7	6.0	5.5	5.6	6.0	7.8	7.1	7.2
	5% WB	MCDBR	9.0	12.6	14.8	14.4	12.8	13.6	13.4	13.5	12.1	12.6	9.9	9.3
		MCWBR	6.6	8.2	8.6	6.9	6.2	5.9	5.4	5.7	5.8	7.6	6.7	7.1
Clear-Sky Solar Irradiance	taub	0.315	0.339	0.378	0.424	0.421	0.427	0.430	0.432	0.405	0.378	0.346	0.314	
	taud	2.412	2.357	2.284	2.174	2.230	2.255	2.247	2.252	2.299	2.349	2.397	2.447	
	Ebn at Noon	771	822	839	829	846	841	832	813	800	763	720	729	
	Edh at Noon	70	90	113	138	135	133	132	126	110	91	71	61	
All-Sky Solar Radiation	RadAvg	1.21	2.04	3.19	4.33	5.20	5.73	5.70	5.04	3.60	2.38	1.30	0.97	
	RadStd	0.15	0.29	0.39	0.46	0.51	0.41	0.42	0.54	0.45	0.25	0.18	0.14	

Historical Trends

		Heating		Cooling		Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (82 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.54	N/A	N/A	+0.90	+0.48	+0.41	-106	-142	+90

Nomenclature: See separate page