

BAD RADKERSBURG, Austria

WMO: 112480

Lat: **46.686N**Lon: **15.979E**Elev: **214**StdP: **98.78**Time Zone: **1.00 (EUC)**Period: **94-16**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-8.3	-13.2	1.2	-10.1	-10.5	1.6	-6.1	5.4	7.0	4.8	7.4	1.1	240	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	30.8	21.6	29.0	20.9	27.3	20.0	22.6	28.5	21.6	27.3	20.8	25.9	1.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.9	15.9	24.9	19.8	14.9	23.9	19.0	14.1	23.3	67.7	28.7	64.0	27.2	61.0	26.0	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.9	4.0	3.2	-13.5	33.6	4.2	2.0	-16.5	35.0	-19.0	36.2	-21.4	37.3	-24.4	38.8		
			-13.8	23.7	3.9	1.0	-16.6	24.4	-18.8	25.0	-21.0	25.5	-23.8	26.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-0.4	1.9	6.1	11.6	15.8	19.0	20.8	20.5	15.6	11.1	6.1	0.7	(6)
(7)		DBStd	8.31	4.20	4.46	4.17	3.69	3.15	3.37	3.02	3.05	3.22	3.83	4.37	4.05	(7)
(8)		HDD10.0	1159	322	228	130	26	1	0	0	0	1	33	131	288	(8)
(9)		HDD18.3	3000	580	461	378	203	91	32	12	13	94	224	368	546	(9)
(10)		CDD10.0	1448	0	1	11	74	181	270	336	325	168	69	13	1	(10)
(11)		CDD18.3	246	0	0	0	1	12	52	89	79	12	1	0	0	(11)
(12)		CDH23.3	1799	0	0	0	10	115	392	678	544	58	2	0	0	(12)
(13)		CDH26.7	490	0	0	0	1	15	96	201	172	5	0	0	0	(13)
(14)	Wind	WSAvg	1.3	1.2	1.4	1.5	1.5	1.4	1.2	1.2	1.1	1.1	1.2	1.2	(14)	
(15)	Precipitation	PrecAvg	907	35	43	50	62	87	106	99	110	103	80	75	58	(15)
(16)		PrecMax	1143	104	131	113	149	148	176	169	201	200	215	191	116	(16)
(17)		PrecMin	628	7	3	8	8	39	36	27	18	47	0	7	7	(17)
(18)		PrecStd	125	22	34	29	32	36	35	39	49	46	50	44	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	15.6	20.3	24.8	28.5	31.7	32.9	33.2	27.1	23.2	19.0	14.0	(19)
(20)			MCWB	8.3	9.6	11.8	15.5	19.1	21.8	22.3	22.0	19.2	17.2	13.7	11.2	(20)
(21)		2%	DB	10.4	12.5	17.7	22.3	26.3	29.4	30.7	30.9	25.0	20.9	16.6	10.8	(21)
(22)			MCWB	7.5	8.0	10.9	14.0	17.8	21.0	21.8	21.7	18.7	16.1	12.7	8.4	(22)
(23)		5%	DB	8.1	10.5	15.5	20.4	24.4	27.3	28.8	28.6	23.2	19.1	14.7	7.9	(23)
(24)			MCWB	5.8	6.7	10.0	13.3	17.1	20.1	20.8	21.0	18.0	15.1	11.7	6.1	(24)
(25)		10%	DB	5.5	8.6	13.2	18.6	22.5	25.6	27.1	26.5	21.3	17.2	12.8	5.9	(25)
(26)			MCWB	3.8	5.6	8.7	12.4	16.0	19.0	20.1	20.1	16.9	14.0	10.7	4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.1	12.5	16.2	20.0	22.7	23.9	24.4	20.8	17.9	14.4	11.2	(27)
(28)			MCD B	11.5	14.7	18.5	22.5	26.3	29.4	29.8	29.2	25.3	22.3	17.7	14.0	(28)
(29)		2%	WB	7.6	8.4	11.4	14.9	18.7	21.6	22.7	22.7	19.5	16.6	13.1	8.4	(29)
(30)			MCD B	10.2	11.8	16.8	20.9	24.7	27.7	28.4	28.3	23.5	20.2	16.0	10.7	(30)
(31)		5%	WB	5.9	7.0	10.3	13.9	17.6	20.7	21.7	21.6	18.5	15.5	11.9	6.5	(31)
(32)			MCD B	8.1	9.9	14.7	18.8	23.0	26.1	27.4	27.1	22.3	18.4	14.4	7.6	(32)
(33)		10%	WB	4.0	5.8	9.1	12.9	16.6	19.7	20.8	20.6	17.5	14.4	10.7	5.0	(33)
(34)			MCD B	5.1	8.0	12.8	17.2	21.4	24.4	25.8	25.4	20.6	16.8	12.7	5.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.9	8.0	9.5	10.1	10.1	9.7	10.2	9.7	8.4	8.0	6.2	5.0	(35)
(36)			MCD BR	9.6	11.4	13.6	13.5	13.6	12.4	12.8	13.0	10.7	10.5	9.7	8.8	(36)
(37)			MCWBR	6.6	6.9	7.4	5.9	5.7	4.9	4.8	4.9	5.2	6.2	6.2	6.6	(37)
(38)		5% WB	MCD BR	9.2	10.4	12.7	11.7	12.3	11.9	11.8	12.2	9.8	9.5	8.5	8.2	(38)
(39)			MCWBR	6.5	6.7	7.1	5.3	5.5	5.0	4.9	5.0	5.1	5.8	5.5	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.346	0.385	0.432	0.427	0.433	0.435	0.438	0.413	0.386	0.353	0.321	(40)	
(41)		taud	2.392	2.334	2.261	2.150	2.214	2.242	2.235	2.238	2.279	2.329	2.375	2.427	(41)	
(42)		Ebn at Noon	763	814	831	822	841	836	828	808	793	755	712	720	(42)	
(43)		Edh at Noon	72	93	116	141	137	135	134	128	113	93	73	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.22	2.04	3.21	4.36	5.29	5.83	5.80	5.13	3.64	2.40	1.30	0.97	(44)	
(45)		RadStd	0.16	0.30	0.40	0.46	0.49	0.41	0.41	0.54	0.46	0.26	0.18	0.14	(45)	

Historical Trends

		Heating	
--	--	---------	--