

KOETSCHACH-MAUTHEN, Austria

WMO: 112550

Lat: 46.677N

Lon: 12.997E

Elev: 712

StdP: 93.06

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-9.2	-14.8	1.1	-7.2	-13.1	1.3	-5.8	4.3	5.3	3.1	2.9	0.4	310	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	29.0	19.5	27.2	18.7	25.6	17.8	20.2	27.2	19.3	25.7	18.5	24.2	2.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	14.0	22.7	17.0	13.2	21.6	16.3	12.6	20.8	61.2	27.1	57.9	25.8	55.1	24.3	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 4.3	3.3	2.5	DB	-13.2	32.1	2.7	1.9	-15.1	33.5	-16.7	34.7	-18.2	35.7	-20.2	37.2	(4)
(5)			WB	-13.6	21.7	2.6	0.8	-15.4	22.2	-16.9	22.7	-18.4	23.1	-20.3	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-1.5	0.4	4.6	8.8	13.2	17.0	19.0	18.3	13.9	9.4	3.8	-0.7
	DBStd	7.98	3.69	3.71	3.86	3.59	3.25	3.44	2.93	3.10	3.23	3.60	3.89	3.63
	HDD10.0	1444	356	268	171	63	8	1	0	0	6	54	187	331
	HDD18.3	3558	614	502	426	285	161	66	28	39	136	277	436	589
	CDD10.0	1043	0	0	2	28	108	210	279	256	122	36	1	0
	CDD18.3	116	0	0	0	0	2	25	48	37	3	0	0	0
	CDH23.3	979	0	0	0	3	41	242	390	282	21	0	0	0
	CDH26.7	213	0	0	0	0	4	51	88	70	1	0	0	0
(14) Wind	WSAvg	0.9	0.7	0.8	1.0	1.1	1.2	1.1	1.1	1.0	0.8	0.8	0.7	0.6
(15) Precipitation	PrecAvg	1346	66	61	79	100	121	137	136	132	117	158	161	77
	PrecMax	1978	339	302	170	248	280	234	285	217	258	500	539	223
	PrecMin	1019	2	5	13	35	37	67	35	66	17	0	0	7
	PrecStd	246	66	60	44	47	52	49	51	40	56	117	142	55
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	12.9	18.6	22.6	27.2	30.4	31.2	31.5	25.6	21.0	14.5	9.1
		MCWB	5.9	7.0	10.1	13.5	17.4	19.6	20.6	20.6	17.9	14.8	9.8	5.2
	2%	DB	6.7	9.7	16.0	20.0	24.2	28.1	29.0	28.4	23.5	18.7	12.0	7.0
		MCWB	3.3	4.9	9.2	12.3	15.7	18.7	19.5	19.4	16.8	13.4	8.9	4.6
	5%	DB	4.8	7.5	13.5	17.9	22.1	26.2	27.2	26.4	21.5	16.8	10.4	5.2
		MCWB	2.2	3.5	7.8	10.9	14.5	17.9	18.8	18.6	15.6	12.3	8.5	3.2
	10%	DB	3.2	5.5	11.0	15.9	20.2	24.2	25.5	24.4	19.7	14.9	9.1	3.6
		MCWB	1.4	2.5	6.3	9.9	13.6	16.9	17.9	17.6	14.7	11.6	7.6	2.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	7.1	10.8	14.1	17.8	20.7	21.5	21.6	18.5	15.4	10.9	6.8
		MCDB	10.1	12.2	17.5	21.1	25.7	28.4	29.0	30.0	24.0	19.9	12.6	7.8
	2%	WB	4.0	5.2	9.4	12.7	16.3	19.4	20.3	20.1	17.3	14.1	9.9	4.9
		MCDB	6.1	8.7	15.3	19.1	23.0	26.4	27.2	27.0	22.2	17.5	11.2	6.3
	5%	WB	2.8	3.9	8.1	11.5	15.1	18.5	19.3	19.0	16.4	13.0	8.9	3.5
		MCDB	4.3	6.8	12.8	16.8	20.9	24.9	25.6	25.0	20.4	15.7	10.1	4.8
	10%	WB	1.7	2.8	6.8	10.4	14.1	17.4	18.5	18.1	15.4	12.0	7.8	2.3
		MCDB	2.8	5.0	10.4	14.9	19.1	23.0	24.1	23.3	18.5	14.5	9.0	3.4
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	7.9	10.1	10.3	10.8	10.9	11.4	10.5	9.7	8.5	6.1	6.0
		MCDBR	8.4	11.1	14.3	14.2	14.4	14.3	13.7	13.6	11.8	11.1	8.3	7.9
	5% WB	MCWBR	5.7	6.9	8.0	7.1	6.6	6.0	5.5	5.6	5.6	6.0	5.3	5.4
		MCWBR	7.3	10.0	13.6	13.1	13.1	13.3	12.6	12.4	10.6	9.7	6.8	7.0
(40) Clear-Sky Solar Irradiance	taub		0.283	0.314	0.368	0.421	0.435	0.447	0.439	0.432	0.395	0.368	0.325	0.287
		taud	2.354	2.277	2.197	2.136	2.158	2.178	2.210	2.244	2.321	2.361	2.422	2.428
	Ebn at Noon		811	849	847	832	833	823	824	813	812	778	752	768
		Edh at Noon	72	97	122	143	145	143	137	127	108	89	69	61
(44) All-Sky Solar Radiation	RadAvg		1.46	2.32	3.42	4.22	4.92	5.53	5.64	4.94	3.70	2.47	1.44	1.23
	RadStd		0.16	0.31	0.42	0.56	0.61	0.46	0.43	0.50	0.44	0.29	0.27	0.17

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (76 neighbors)	+0.43	N/A	N/A	+0.67	+0.43	+0.34	N/A	-119	+78	+45

Nomenclature: See separate page