

DELLACH IM DRAUTAL, Austria

WMO: 112700

Lat: **46.742N**Lon: **13.083E**Elev: **2058**StdP: **13.64**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	11.7	5.3	7.8	11.9	8.3	9.1	16.0	15.7	38.2	12.5	38.3	1.3	20	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	86.4	68.9	83.1	67.4	80.0	65.8	70.2	83.6	68.6	80.6	67.0	77.6	3.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.9	102.9	75.5	64.4	97.6	73.7	63.0	93.1	71.5	35.5	83.9	34.0	80.7	32.7	77.9	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	7.8	6.0	4.6	92.2	5.0	3.9	1.1	95.1	-1.8	97.4	-4.6	99.6	-8.2	102.4		
(5)			4.2	73.5	4.7	1.5	0.8	74.6	-2.0	75.5	-4.6	76.3	-8.1	77.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	26.3	32.5	41.0	49.5	57.4	64.1	67.2	66.2	57.7	49.2	37.8	27.3
	DBStd	15.56	7.00	6.23	6.50	6.28	5.68	6.16	5.35	5.47	5.62	6.14	6.87	6.83
	HDD50	2769	735	490	284	84	7	0	0	0	7	91	368	703
	HDD65	6446	1200	910	744	465	243	91	40	52	226	490	817	1168
	CDD50	2074	0	0	5	69	237	422	533	503	238	65	2	0
	CDD65	274	0	0	0	0	7	63	107	90	7	0	0	0
	CDH74	2483	0	0	0	13	146	628	924	710	62	0	0	0
	CDH80	686	0	0	0	1	25	179	272	204	5	0	0	0
Wind	WSAvg	2.1	1.9	2.0	2.2	2.4	2.5	2.5	2.6	2.3	1.9	1.7	1.6	1.6
Precipitation	PrecAvg	42.2	1.6	1.7	2.0	3.1	3.9	4.8	4.1	5.0	4.4	3.8	5.2	2.7
	PrecMax	57.7	2.8	3.8	4.8	6.9	9.0	9.0	5.8	15.9	12.4	14.6	10.3	8.3
	PrecMin	28.8	0.0	0.0	0.1	0.4	1.5	2.2	0.9	0.9	0.7	0.0	0.4	0.2
	PrecStd	7.6	1.0	1.3	1.5	1.7	2.0	1.7	1.4	3.5	3.5	3.9	3.5	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.8	55.3	67.7	75.4	83.6	88.8	91.0	91.3	80.2	70.9	55.9	45.7
		MCWB	40.5	45.5	51.8	58.3	65.6	69.8	71.4	71.0	66.2	59.9	49.7	40.2
	2%	DB	40.7	49.1	62.3	70.8	77.9	85.0	86.3	85.3	75.2	65.7	52.1	41.3
		MCWB	36.0	40.7	49.5	55.9	61.7	67.7	69.1	68.9	63.5	57.0	48.9	38.5
	5%	DB	37.6	45.2	57.9	66.9	74.1	81.4	82.7	81.4	71.6	62.6	50.0	37.9
		MCWB	34.5	38.3	47.2	53.7	59.7	66.1	67.6	67.3	61.1	55.5	47.9	36.1
	10%	DB	35.1	41.4	53.2	62.7	70.1	77.2	79.3	77.7	68.2	59.0	47.6	35.5
		MCWB	33.3	36.4	44.6	51.6	57.7	64.0	66.0	65.7	59.5	53.6	45.7	34.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	46.0	53.1	59.3	66.1	71.8	72.7	72.5	66.8	60.9	51.8	42.7
		MCDB	46.3	54.4	65.4	74.1	80.7	85.9	87.3	87.6	77.5	68.7	53.4	43.8
	2%	WB	37.6	41.6	50.1	56.8	63.0	69.0	70.4	69.9	64.6	58.5	49.9	39.0
		MCDB	40.3	47.7	61.2	68.9	75.2	82.2	83.7	83.1	72.9	64.1	51.4	40.3
	5%	WB	35.3	39.0	47.7	54.6	60.8	67.1	68.6	68.2	62.7	56.4	48.1	36.5
		MCDB	36.6	43.9	56.6	64.7	71.6	78.9	80.3	79.6	68.8	60.7	49.7	37.8
	10%	WB	33.5	37.1	45.4	52.5	58.8	65.1	67.0	66.4	60.9	54.6	45.9	34.5
		MCDB	34.8	40.5	52.2	61.0	67.9	75.3	77.1	75.9	66.3	58.4	47.4	35.4
Mean Daily Temperature Range	5% DB	MDBR	12.2	16.7	21.3	21.2	21.4	21.5	22.1	20.7	19.1	17.0	11.2	9.6
		MCDBR	14.5	23.0	29.8	29.8	29.1	28.8	27.6	27.1	23.9	22.2	14.6	11.1
		MCWBR	10.5	14.7	17.2	15.1	13.2	12.3	11.5	11.6	12.4	13.6	10.3	8.5
	5% WB	MCDBR	12.1	21.0	28.3	27.2	26.7	26.6	26.0	25.4	20.9	19.4	11.4	9.5
		MCWBR	9.5	13.9	16.5	14.0	12.6	12.0	11.3	11.5	11.5	12.2	8.5	7.8
Clear-Sky Solar Irradiance	taub		0.281	0.312	0.364	0.416	0.431	0.443	0.436	0.430	0.392	0.364	0.323	0.286
	taud		2.362	2.286	2.214	2.158	2.180	2.201	2.227	2.262	2.340	2.383	2.438	2.437
	Ebn at Noon		258	270	270	266	265	262	262	259	259	248	240	244
	Edh at Noon		23	30	38	44	45	44	43	40	34	28	22	19
All-Sky Solar Radiation	RadAvg		458	732	1079	1336	1555	1743	1779	1561	1165	781	453	386
	RadStd		51	98	132	177	191	148	139	159	139	92	83	54