

LASSNITZHOEHE, Austria

WMO: 112920

Lat: 47.074N

Lon: 15.592E

Elev: 529

StdP: 95.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-8.0	-13.6	1.2	-7.5	-11.5	1.5	-5.2	5.0	3.2	4.3	2.1	1.3	240	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	29.2	21.2	27.6	20.5	26.0	19.6	22.0	27.7	21.1	26.6	20.2	25.2	1.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	15.7	25.0	19.1	14.8	24.3	18.2	14.0	23.2	66.9	27.9	63.4	26.7	60.3	25.3	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.3	3.5	3.2	-11.9	31.8	2.5	1.9	-13.7	33.2	-15.1	34.3	-16.5	35.4	-18.3	36.8		
(5)			-12.3	23.4	2.4	0.8	-14.0	24.0	-15.5	24.5	-16.8	25.0	-18.6	25.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-0.5	1.7	5.7	10.6	14.8	18.3	20.0	19.5	14.9	10.5	5.3	0.5	(6)	(7)
	DBStd	8.17	4.37	4.59	4.59	4.15	3.55	3.58	3.20	3.23	3.36	3.89	4.14	4.05	(7)	(8)
	HDD10.0	1238	327	234	145	42	3	0	0	2	42	149	293		(8)	(9)
	HDD18.3	3180	585	466	392	232	120	45	21	24	111	242	392	551	(9)	(10)
	CDD10.0	1292	0	1	12	61	151	248	308	296	150	58	7	0	(10)	(11)
	CDD18.3	193	0	0	0	1	9	43	71	61	8	0	0	0	(11)	(12)
	CDH23.3	1158	0	0	0	5	50	264	448	364	26	0	0	0	(12)	(13)
	CDH26.7	239	0	0	0	0	5	53	96	85	1	0	0	0	(13)	(14)
(14) Wind	WSAvg	1.5	1.5	1.6	1.7	1.7	1.6	1.5	1.5	1.4	1.3	1.3	1.4	1.5	(14)	(15)
(15) Precipitation	PrecAvg	880	24	31	41	56	93	126	118	127	92	75	56	43	(15)	(16)
	PrecMax	1215	61	100	86	99	185	218	234	231	152	165	129	95	(16)	(17)
	PrecMin	576	4	3	5	12	39	57	26	39	25	6	2	4	(17)	(18)
	PrecStd	119	14	27	23	24	34	42	48	46	31	41	31	24	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	15.4	19.1	24.0	27.2	30.4	31.1	31.2	25.7	21.7	17.5	11.9	(19)	(20)
		MCWB	7.3	8.9	11.4	15.4	18.8	21.1	22.2	21.7	19.3	15.8	12.2	8.0	(20)	(21)
	2%	DB	9.2	12.1	16.6	21.2	24.7	28.1	29.1	29.0	23.8	19.5	14.6	9.5	(21)	(22)
		MCWB	5.8	7.4	10.1	13.5	17.5	20.7	21.3	21.1	18.2	14.8	11.1	6.3	(22)	(23)
	5%	DB	7.3	9.9	14.4	19.1	22.9	26.4	27.4	27.1	22.1	17.7	12.3	7.5	(23)	(24)
		MCWB	4.9	5.9	9.1	12.5	16.4	19.7	20.6	20.3	17.4	14.0	9.9	5.2	(24)	(25)
	10%	DB	5.5	8.0	12.3	17.2	21.1	24.5	25.9	25.3	20.3	16.0	10.6	5.9	(25)	(26)
		MCWB	3.5	4.7	7.9	11.5	15.3	18.5	19.7	19.4	16.3	13.1	8.8	4.1	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	9.4	12.1	15.7	19.5	22.4	23.3	22.9	20.3	16.7	13.0	8.7	(27)	(28)
		MCDB	10.9	14.6	17.6	23.1	25.4	28.3	29.0	28.7	24.6	20.0	15.9	11.0	(28)	(29)
	2%	WB	6.4	7.7	10.6	14.3	18.1	21.2	22.1	21.8	18.9	15.5	11.6	7.0	(29)	(30)
		MCDB	8.5	11.5	15.7	20.1	23.3	27.1	27.7	27.5	22.8	18.5	14.0	8.8	(30)	(31)
	5%	WB	5.1	6.3	9.5	13.1	17.0	20.2	21.2	20.8	17.9	14.5	10.2	5.5	(31)	(32)
		MCDB	7.2	9.4	13.8	18.4	22.1	25.5	26.4	26.3	21.2	17.0	12.1	7.1	(32)	(33)
	10%	WB	3.7	5.1	8.3	12.0	15.8	19.2	20.2	19.8	16.8	13.6	9.0	4.2	(33)	(34)
		MCDB	5.3	7.6	11.7	16.2	20.3	23.8	25.1	24.6	19.6	15.7	10.4	5.8	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	6.5	7.7	8.5	8.5	8.7	8.6	8.2	7.2	6.6	5.0	4.7	(35)	(36)
		MCDBR	7.6	9.3	10.7	11.2	10.7	10.9	10.5	10.4	9.1	8.8	7.9	7.5	(36)	(37)
		MCWBR	4.9	5.9	6.1	5.8	5.4	5.2	4.9	4.9	4.5	4.6	4.9	5.2	(37)	(38)
	5% WB	MCDBR	7.2	8.6	10.1	10.2	10.3	10.5	10.0	9.8	8.7	8.0	6.9	6.9	(38)	(39)
		MCWBR	4.9	5.6	6.0	5.4	5.3	5.2	4.9	5.0	4.5	4.4	4.6	5.1	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub	0.297	0.322	0.360	0.403	0.404	0.410	0.413	0.413	0.385	0.359	0.329	0.297		(40)	(41)
	taud	2.444	2.394	2.329	2.232	2.272	2.291	2.282	2.293	2.346	2.400	2.446	2.481		(41)	(42)
	Ebn at Noon	796	844	859	849	861	856	847	830	821	786	745	754		(42)	(43)
	Edh at Noon	67	86	107	130	129	128	127	121	105	86	67	58		(43)	(44)
(44) All-Sky Solar Radiation	RadAvg	1.22	2.07	3.17	4.20	4.98	5.49	5.48	4.87	3.50	2.35	1.30	1.00		(44)	(45)
	RadStd	0.15	0.28	0.38	0.45	0.52	0.40	0.44	0.54	0.45	0.24	0.19	0.14		(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (95 neighbors)	+0.55	N/A	N/A	+0.89	+0.48	+0.40	-107	-145	+91	+57

Nomenclature: See separate page