

DORNBIRN, Austria

WMO: 113020

Lat: 47.4327N

Lon: 9.7257E

Elev: 1335

StdP: 14.00

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 15.4	(c) 19.1	(d) 12.0	(e) 10.6	(f) 16.5	(g) 15.9	(h) 12.9	(i) 20.8	(j) 13.2	(k) 46.7	(l) 10.7	(m) 44.0	(n) 1.8	(o) 50	(p) 0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	86.0	70.1	82.6	68.6	79.7	67.2	71.5	83.0	69.8	80.4	68.2	77.6	4.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	106.7	77.7	66.0	100.8	75.4	64.6	95.9	73.2	36.2	83.2	34.6	80.8	33.3	77.8	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.6	(b) 8.4	(c) 6.9	(e) 10.2	(f) 91.4	(g) 5.9	(h) 3.9	(i) 5.9	(j) 94.2	(k) 2.5	(l) 96.4	(m) -0.8	(n) 98.6	(o) -5.1	(p) 101.4		
(a) 10.6	(b) 8.4	(c) 6.9	(e) 9.8	(f) 74.9	(g) 5.8	(h) 1.9	(i) 5.6	(j) 76.2	(k) 2.2	(l) 77.4	(m) -1.1	(n) 78.4	(o) -5.3	(p) 79.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	32.9	35.8	43.1	50.2	58.2	64.7	67.1	66.6	59.3	51.8	41.6	35.2
	DBStd	13.86	7.52	7.72	7.14	7.07	6.48	6.70	5.76	5.42	5.73	6.04	6.95	7.12
	HDD50	2034	532	399	231	83	9	1	0	0	3	52	263	461
	HDD65	5566	996	817	680	444	226	87	45	47	187	411	702	924
	CDD50	2260	1	2	15	90	263	443	530	515	281	107	11	2
	CDD65	316	0	0	0	1	15	79	110	96	15	0	0	0
	CDH74	2430	0	0	0	14	160	671	842	653	85	5	0	0
	CDH80	611	0	0	0	2	21	187	228	166	6	1	0	0
Wind	WSAvg	2.5	2.3	2.6	3.0	2.9	2.8	2.7	2.5	2.2	2.1	2.2	2.2	2.3
Precipitation	PrecAvg	55.1	2.7	3.0	3.5	4.0	5.4	6.7	6.6	6.7	4.9	3.8	4.1	3.6
	PrecMax	70.8	5.9	8.3	7.0	7.4	12.6	12.4	12.2	11.5	7.9	8.2	9.4	7.6
	PrecMin	42.0	0.3	0.8	1.2	1.3	0.7	2.6	2.6	1.9	2.2	0.4	0.3	0.4
	PrecStd	6.1	1.6	1.6	1.5	1.7	2.6	2.4	2.6	2.4	1.5	1.7	2.0	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	60.4	67.2	75.6	82.6	89.6	89.9	89.7	80.4	71.9	64.7	60.4
		MCWB	48.0	48.3	53.6	58.8	65.6	71.2	71.5	72.5	67.3	60.5	53.8	48.0
	2%	DB	49.5	54.0	62.5	71.6	78.7	85.2	85.8	84.4	76.5	67.6	58.8	50.3
		MCWB	44.3	45.7	51.0	57.1	63.5	69.2	69.9	70.8	65.6	59.1	51.2	45.8
	5%	DB	46.0	50.1	58.8	67.7	74.9	81.4	82.2	80.8	72.9	64.1	53.8	47.0
		MCWB	42.6	43.8	49.6	55.4	62.0	67.6	68.6	68.8	64.2	57.4	49.4	43.9
	10%	DB	42.7	46.4	55.0	63.5	70.9	77.7	78.8	77.3	69.4	60.7	50.5	44.6
		MCWB	40.2	41.7	47.6	53.2	59.6	66.0	67.0	67.3	62.2	56.3	47.4	42.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	49.5	54.6	61.1	67.6	73.1	73.5	73.8	69.0	62.9	55.3	49.2
		MCDB	54.7	57.4	65.0	73.6	79.9	85.6	87.5	86.3	77.2	69.5	62.1	56.0
	2%	WB	45.0	46.7	52.2	58.0	64.8	70.6	70.9	71.7	66.8	60.2	52.2	46.6
		MCDB	48.4	53.3	60.4	68.8	75.9	82.3	82.7	82.6	74.4	65.3	57.2	50.3
	5%	WB	42.6	44.3	50.3	55.8	62.7	68.6	69.3	69.7	64.9	58.3	49.9	44.4
		MCDB	45.2	49.3	57.1	65.5	72.5	79.1	80.1	79.1	71.2	62.6	53.4	46.8
	10%	WB	40.3	42.0	48.3	53.8	60.6	66.6	67.7	67.9	63.0	56.5	47.9	42.1
		MCDB	42.6	45.9	53.8	62.4	69.1	76.1	77.1	76.0	68.5	60.1	50.4	44.1
Mean Daily Temperature Range	5% DB	MDBR	10.2	13.5	16.7	18.3	18.2	18.0	17.9	17.8	16.5	14.3	11.6	9.9
		MCDBR	13.9	19.6	23.9	26.0	25.7	25.1	24.1	24.0	21.5	19.4	17.1	13.6
		MCWBR	9.8	12.4	14.1	13.3	12.3	11.3	10.8	11.6	11.9	11.9	11.1	9.3
	5% WB	MCDBR	13.3	18.1	21.5	23.8	23.0	23.3	22.0	22.4	19.6	17.2	15.6	13.2
		MCWBR	9.8	11.9	13.3	12.9	11.8	11.1	10.4	11.3	11.5	11.4	10.7	9.2
Clear-Sky Solar Irradiance	taub	0.288	0.315	0.357	0.401	0.416	0.423	0.424	0.415	0.383	0.350	0.316	0.285	
	taud	2.393	2.317	2.281	2.224	2.241	2.267	2.262	2.303	2.370	2.447	2.471	2.420	
	Ebn at Noon	253	268	272	270	269	268	265	263	261	253	241	240	
	Edh at Noon	22	29	36	41	42	42	41	38	32	26	21	19	
All-Sky Solar Radiation	RadAvg	382	656	1029	1370	1567	1790	1741	1525	1142	733	413	315	
	RadStd	43	87	133	193	163	170	161	159	122	80	53	47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (109 neighbors)		N/A	N/A	N/A	N/A	+0.77	+0.67	N/A	N/A	+95	+23

Nomenclature: See separate page