

ISCHGL IDALPE, Austria

WMO: 113100

Lat: 46.983N

Lon: 10.317E

Elev: 2312

StdP: 76.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.9	-15.9	-26.1	0.5	-10.1	-23.6	0.6	-9.6	8.9	-6.7	7.6	-4.9	1.2	90	0.733

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	18.1	10.4	16.6	9.7	15.2	9.0	11.3	16.2	10.4	15.2	9.6	14.2	2.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	9.6	12.9	8.2	9.0	12.3	7.3	8.5	11.7	39.3	16.4	36.8	15.4	34.6	14.2	14.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.0	5.0	DB	-20.5	20.8	2.8	1.9	-22.5	22.1	-24.2	23.2	-25.8	24.3	-27.9	25.6	(4)
(5)			WB	-20.7	12.7	2.9	1.0	-22.8	13.4	-24.5	14.0	-26.1	14.5	-28.2	15.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.5	-5.9	-6.1	-3.9	-0.7	3.4	7.4	9.4	9.6	5.9	3.6	-1.2	-4.1
	DBStd	7.14	4.57	5.12	4.80	4.36	3.89	4.27	3.84	3.81	4.12	4.43	4.99	4.87
	HDD10.0	3219	494	452	431	321	206	99	57	54	132	199	337	438
	HDD18.3	6149	752	686	689	571	462	329	277	271	374	456	587	696
	CDD10.0	111	0	0	0	0	2	21	39	41	7	2	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	2.0	2.2	2.0	2.1	2.0	1.9	2.0	2.0	1.8	1.7	2.0	2.3	2.1
Precipitation	PrecAvg	767	41	37	40	40	64	92	107	113	69	64	59	41
	PrecMax	986	103	174	104	84	127	150	179	201	140	152	194	142
	PrecMin	587	4	9	8	8	24	46	70	44	25	4	5	5
	PrecStd	98	27	36	24	17	24	28	26	35	31	35	40	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	5.7	7.2	9.8	14.7	19.2	19.7	20.1	16.2	14.2	9.5	5.7
		MCWB	-0.5	-1.2	0.8	3.6	7.7	10.8	11.2	11.0	8.2	6.3	2.9	-0.5
	2%	DB	3.1	3.5	5.1	8.1	12.3	16.8	18.0	18.2	14.4	12.1	7.7	4.1
		MCWB	-1.6	-1.8	-0.3	2.6	6.0	9.6	10.5	10.4	7.7	5.5	1.8	-1.6
	5%	DB	1.6	1.8	3.7	6.5	10.5	15.1	16.3	16.5	12.8	10.3	6.2	3.0
		MCWB	-2.5	-2.6	-1.0	1.8	5.0	8.9	9.8	9.7	6.9	4.5	1.1	-1.9
	10%	DB	0.1	0.3	2.1	5.1	8.8	13.4	14.9	14.9	11.4	9.0	4.8	1.8
		MCWB	-3.1	-3.3	-1.8	0.9	4.2	8.0	9.1	9.0	6.4	4.0	0.4	-2.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	0.3	1.6	4.5	8.6	11.7	12.4	12.6	9.7	7.6	4.2	0.9
		MCDB	2.8	3.0	5.5	8.4	14.1	17.9	17.4	17.4	13.5	12.1	7.8	3.1
	2%	WB	-0.7	-1.1	0.5	3.3	6.7	10.3	11.3	11.3	8.6	6.4	2.9	0.1
		MCDB	1.8	1.8	3.9	7.0	11.2	15.4	16.3	16.0	12.8	10.4	6.2	2.3
	5%	WB	-1.8	-2.0	-0.4	2.2	5.6	9.4	10.5	10.3	7.8	5.5	1.9	-0.8
		MCDB	0.7	1.4	2.6	5.8	9.6	14.1	15.2	15.1	11.8	9.2	5.0	1.8
	10%	WB	-2.8	-3.0	-1.3	1.2	4.6	8.5	9.7	9.5	7.0	4.7	1.0	-1.8
		MCDB	0.0	0.1	1.5	4.7	8.1	12.8	14.0	14.1	10.6	8.3	3.9	1.1
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.3	5.7	5.7	5.7	6.1	6.2	6.1	5.6	5.4	4.6	4.9
		MCDBR	5.5	5.7	6.7	6.5	7.4	8.1	7.7	7.8	7.0	6.6	5.2	5.2
		MCWBR	4.0	4.0	4.5	3.9	3.9	4.0	3.8	3.8	4.0	4.1	3.3	3.5
	5% WB	MCDBR	5.2	5.6	5.8	5.9	6.8	7.5	7.3	7.2	6.3	6.0	4.8	5.0
		MCWBR	4.4	4.6	4.3	3.8	3.9	4.0	4.0	3.8	3.7	4.1	3.5	4.2
Clear-Sky Solar Irradiance	taub	0.207	0.225	0.256	0.291	0.304	0.311	0.310	0.305	0.281	0.260	0.233	0.207	
	taud	2.405	2.360	2.341	2.395	2.458	2.473	2.471	2.505	2.566	2.599	2.561	2.452	
	Ebn at Noon	933	974	980	968	960	951	948	942	943	923	895	896	
	Edh at Noon	65	86	104	109	107	106	105	97	83	68	57	55	
All-Sky Solar Radiation	RadAvg	1.47	2.41	3.57	4.40	4.86	5.53	5.52	4.84	3.69	2.48	1.48	1.22	
	RadStd	0.17	0.29	0.43	0.61	0.61	0.53	0.49	0.47	0.48	0.40	0.30	0.23	0.16

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (105 neighbors)		+0.34	N/A	N/A	+0.64	+0.42	+0.36	N/A	N/A	+58	+16

Nomenclature: See separate page