

SCHMITTENHOEHE, Austria

WMO: 113400

Lat: 47.329N

Lon: 12.738E

Elev: 6412

StdP: 11.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.0	(c) 6.5	(d) -9.6	(e) 4.2	(f) 20.2	(g) -4.5	(h) 5.5	(i) 20.9	(j) 36.6	(k) 26.8	(l) 32.2	(m) 24.7	(n) 9.1	(o) 320	(p) 0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.2	(c) 68.4	(d) 56.3	(e) 65.7	(f) 54.7	(g) 63.1	(h) 53.6	(i) 58.0	(j) 65.6	(k) 56.2	(l) 63.4	(m) 54.6	(n) 61.5	(o) 6.5	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.9	81.6	61.3	53.0	76.0	59.8	51.4	71.7	58.1	28.1	65.8	26.7	63.5	25.6	61.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 28.2	(b) 24.1	(c) 20.7	(e) 0.5	(f) 71.7	(g) 5.8	(h) 3.1	(i) -3.6	(j) 74.0	(k) -7.0	(l) 75.8	(m) -10.2	(n) 77.5	(o) -14.4	(p) 79.7		
(a) 28.2	(b) 24.1	(c) 20.7	(e) -0.1	(f) 60.7	(g) 5.5	(h) 1.8	(i) -4.1	(j) 62.0	(k) -7.3	(l) 63.1	(m) -10.4	(n) 64.1	(o) -14.4	(p) 65.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.2	23.8	23.8	27.6	33.5	41.2	48.2	51.3	51.3	44.5	41.4	31.8	27.2
	DBStd	13.20	8.75	9.54	9.03	8.73	8.09	8.51	7.21	7.48	8.12	8.59	9.88	9.34
	HDD50	5048	813	733	695	496	291	134	73	76	199	284	548	706
	HDD65	10147	1278	1153	1160	945	739	506	425	426	614	733	997	1171
	CDD50	382	0	0	0	1	18	79	115	117	35	16	1	0
	CDD65	4	0	0	0	0	0	1	1	2	0	0	0	0
	CDH74	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.8	10.5	9.5	9.8	8.3	8.3	8.6	9.0	8.0	7.4	8.0	9.0	9.2
Precipitation	PrecAvg	55.3	3.0	2.8	3.7	3.4	5.6	6.9	7.4	7.2	5.2	4.0	3.3	3.0
	PrecMax	64.6	8.5	7.8	9.4	6.5	7.8	10.9	11.7	11.3	10.1	7.4	6.7	8.6
	PrecMin	45.1	0.3	0.3	1.1	0.3	1.4	3.8	2.8	4.6	2.2	1.0	0.0	0.7
	PrecStd	4.6	1.8	1.8	2.0	1.7	1.9	1.7	2.1	1.9	1.8	1.6	1.6	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.2	46.7	48.8	55.1	63.7	70.3	71.0	71.7	64.0	61.4	53.9	48.7
		MCWB	34.0	32.7	36.5	43.0	49.7	54.7	57.1	57.4	52.5	45.9	41.5	34.5
	2%	DB	42.2	42.0	45.0	51.1	59.2	66.6	68.2	68.4	60.8	57.8	50.3	44.6
		MCWB	31.7	31.4	35.3	41.1	48.3	54.1	56.6	56.7	51.4	44.7	39.3	33.4
	5%	DB	39.2	39.1	42.3	48.6	56.0	63.6	65.0	65.5	58.3	55.1	47.3	41.8
		MCWB	30.7	30.4	33.7	39.7	46.5	53.2	55.0	55.2	49.7	44.1	37.8	32.3
	10%	DB	35.9	36.2	39.7	45.5	52.8	60.6	62.2	62.3	55.9	52.6	44.5	39.3
		MCWB	29.3	29.4	32.3	37.9	44.9	51.6	54.1	53.9	48.4	43.1	36.4	30.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.3	35.1	38.7	45.0	52.1	58.2	60.1	60.3	55.1	49.1	43.4	37.3
		MCDB	41.9	40.5	45.2	52.8	59.5	65.7	66.7	67.8	60.4	56.1	51.5	43.7
	2%	WB	33.8	33.1	36.5	42.3	49.5	55.9	58.2	57.9	52.9	47.2	40.9	35.4
		MCDB	39.6	39.4	42.6	49.6	57.1	63.6	65.3	66.2	58.8	54.0	48.1	41.3
	5%	WB	31.9	31.5	34.9	40.4	47.3	54.1	56.4	56.0	51.0	45.7	39.0	33.8
		MCDB	37.4	37.1	40.4	47.3	54.4	61.6	62.9	63.7	56.8	52.3	45.1	39.7
	10%	WB	30.0	29.9	33.4	38.4	45.5	52.4	54.7	54.4	49.2	44.3	37.3	32.1
		MCDB	35.1	35.3	38.5	44.4	51.8	59.5	61.2	61.2	54.7	50.8	43.1	37.7
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.0	9.0	9.0	10.2	10.8	11.1	10.2	9.4	9.9	8.6	8.7
		MCDBR	12.0	11.0	11.3	11.1	13.2	14.0	14.1	13.0	11.7	11.4	10.3	10.9
		MCWBR	6.9	6.6	6.7	6.4	7.6	8.0	8.4	8.6	8.2	7.3	6.2	6.8
	5% WB	MCDBR	10.7	10.9	10.4	10.8	12.8	13.0	13.2	12.7	11.0	10.7	9.9	10.4
MCWBR		7.3	7.6	6.7	6.6	8.0	8.2	8.8	8.8	8.0	7.3	6.6	7.4	
Clear-Sky Solar Irradiance	taub	0.229	0.250	0.282	0.313	0.326	0.332	0.332	0.326	0.301	0.279	0.255	0.229	
	taud	2.446	2.398	2.395	2.418	2.434	2.441	2.435	2.468	2.530	2.572	2.568	2.502	
	Ebn at Noon	284	298	301	299	298	295	293	291	291	284	272	272	
	Edh at Noon	20	26	31	34	35	35	35	32	27	22	18	17	
All-Sky Solar Radiation	RadAvg	418	712	1027	1305	1493	1655	1684	1496	1097	764	431	342	
	RadStd	50	90	122	165	180	169	159	176	144	82	72	53	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (90 neighbors)		+0.77	N/A	N/A	N/A	+0.72	+0.72	N/A	N/A	+124	+59

Nomenclature: See separate page