

SCHMITTENHOEHE, Austria

WMO: 113400

Lat: 47.329N

Lon: 12.738E

Elev: 1954

StdP: 79.95

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.1	-14.2	-23.1	0.6	-6.6	-20.3	0.8	-6.1	16.4	-2.9	14.4	-4.0	4.1	320	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	20.2	13.5	18.7	12.6	17.3	12.0	14.4	18.6	13.4	17.5	12.6	16.4	2.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.7	11.7	16.3	11.7	10.9	15.4	10.8	10.2	14.5	47.4	18.8	44.3	17.5	41.7	16.5	17.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	10.8	9.3	-17.5	22.1	3.2	1.7	-19.8	23.3	-21.7	24.3	-23.5	25.3	-25.8	26.5		
(5)			-17.8	16.0	3.1	1.0	-20.0	16.7	-21.8	17.3	-23.5	17.9	-25.8	18.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.9	-4.6	-4.5	-2.4	0.8	5.1	9.0	10.7	10.7	7.0	5.2	-0.1	-2.6
	DBStd	7.34	4.86	5.30	5.02	4.85	4.49	4.73	4.01	4.15	4.51	4.77	5.49	5.19
	HDD10.0	2804	452	407	386	276	162	74	41	42	111	158	304	392
	HDD18.3	5637	710	641	644	525	411	281	236	237	341	407	554	651
	CDD10.0	212	0	0	0	1	10	44	64	65	19	9	1	0
	CDD18.3	2	0	0	0	0	0	1	1	1	0	0	0	0
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	3.9	4.7	4.3	4.4	3.7	3.7	3.8	4.0	3.6	3.3	3.6	4.0	4.1
(15) Precipitation	PrecAvg	1405	75	71	93	87	141	175	188	183	131	101	83	77
	PrecMax	1640	215	197	239	166	198	278	296	287	256	188	170	219
	PrecMin	1146	8	8	29	8	36	97	72	117	57	26	0	18
	PrecStd	116	46	45	50	42	47	44	53	47	46	41	41	45
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	8.1	9.3	12.8	17.6	21.3	21.7	22.0	17.8	16.4	12.2	9.3
		MCWB	1.1	0.4	2.5	6.1	9.8	12.6	14.0	14.1	11.4	7.7	5.3	1.4
	2%	DB	5.7	5.6	7.2	10.6	15.1	19.2	20.1	20.2	16.0	14.3	10.2	7.0
		MCWB	-0.2	-0.3	1.8	5.1	9.0	12.3	13.7	13.7	10.8	7.1	4.1	0.8
	5%	DB	4.0	3.9	5.7	9.2	13.4	17.6	18.3	18.6	14.6	12.8	8.5	5.5
		MCWB	-0.7	-0.9	0.9	4.3	8.0	11.8	12.8	12.9	9.8	6.7	3.2	0.2
	10%	DB	2.2	2.3	4.3	7.5	11.6	15.9	16.8	16.9	13.3	11.5	6.9	4.1
		MCWB	-1.5	-1.4	0.2	3.3	7.2	10.9	12.3	12.2	9.1	6.2	2.4	-0.6
	0.4%	WB	2.4	1.7	3.7	7.2	11.1	14.6	15.6	15.7	12.8	9.5	6.3	2.9
		MCDB	5.5	4.7	7.3	11.5	15.3	18.7	19.3	19.9	15.8	13.4	10.8	6.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	1.0	0.6	2.5	5.7	9.7	13.3	14.6	14.4	11.6	8.5	4.9	1.9
		MCDB	4.2	4.1	5.9	9.8	14.0	17.6	18.5	19.0	14.9	12.2	8.9	5.1
	5%	WB	0.0	-0.3	1.6	4.7	8.5	12.3	13.5	13.3	10.6	7.6	3.9	1.0
		MCDB	3.0	2.8	4.7	8.5	12.4	16.4	17.2	17.6	13.8	11.3	7.3	4.3
	10%	WB	-1.1	-1.1	0.8	3.6	7.5	11.3	12.6	12.4	9.5	6.8	2.9	0.0
		MCDB	1.7	1.8	3.6	6.9	11.0	15.3	16.2	16.2	12.6	10.4	6.1	3.2
	5% DB	MDBR	4.7	5.0	5.0	5.0	5.6	6.0	6.1	5.7	5.2	5.5	4.8	4.8
		MCDBR	6.7	6.1	6.3	6.2	7.4	7.8	7.8	7.2	6.5	6.3	5.7	6.1
		MCWBR	3.8	3.6	3.7	3.6	4.2	4.4	4.7	4.8	4.5	4.1	3.4	3.8
		MCWBR	5.9	6.0	5.8	6.0	7.1	7.2	7.4	7.0	6.1	5.9	5.5	5.8
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.1	4.2	3.7	3.7	4.4	4.6	4.9	4.9	4.4	4.0	3.7	4.1
(40) Clear-Sky Solar Irradiance	taub		0.229	0.250	0.282	0.313	0.326	0.332	0.332	0.326	0.301	0.279	0.255	0.229
	taud		2.446	2.398	2.395	2.418	2.434	2.441	2.435	2.468	2.530	2.572	2.568	2.502
	Ebn at Noon		896	938	948	943	938	930	925	918	918	894	858	857
	Edh at Noon		63	83	99	107	110	110	109	101	86	70	57	53
(44) All-Sky Solar Radiation	RadAvg		1.32	2.24	3.24	4.11	4.71	5.22	5.31	4.72	3.46	2.41	1.36	1.08
	RadStd		0.16	0.28	0.38	0.52	0.57	0.53	0.50	0.55	0.46	0.26	0.23	0.17

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (90 neighbors)	+0.43	N/A	N/A	N/A	+0.40	+0.40	N/A	N/A	+69	+33

Nomenclature: See separate page