

ST VEIT IM PONGAU, Austria

WMO: 113450

Lat: 47.329N

Lon: 13.155E

Elev: 2458

StdP: 13.44

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.3	14.3	6.9	8.6	11.1	10.5	10.3	15.6	10.5	33.4	8.1	31.4	1.8	270	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	85.6	67.1	82.3	65.6	78.9	64.2	68.5	82.4	66.8	79.2	65.3	76.3	5.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.8	97.2	73.7	62.4	92.5	71.7	61.2	88.3	69.8	34.2	82.8	32.7	79.6	31.5	76.5	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.0	7.4	6.5	92.5	5.1	2.6	2.8	94.3	-0.2	95.8	-3.1	97.3	-6.9	99.2		
(5)			5.6	71.9	5.1	1.1	2.0	72.7	-1.0	73.4	-3.8	74.1	-7.5	74.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	28.0	31.8	40.0	49.3	55.5	62.3	65.5	64.5	56.6	48.9	37.8	30.1		
	DBStd	14.78	6.42	7.58	7.04	7.07	7.15	7.39	6.28	6.42	6.26	6.54	7.08	6.16		
	HDD50	2743	683	510	315	97	30	6	0	1	15	99	370	617		
	HDD65	6579	1148	930	776	472	303	133	72	90	259	498	816	1082		
	CDD50	1868	0	0	4	75	201	376	479	451	212	66	4	0		
	CDD65	230	0	0	0	0	9	53	86	75	7	0	0	0		
	CDH74	2028	0	0	0	15	131	520	714	589	59	0	0	0		
	CDH80	552	0	0	0	1	21	152	204	167	7	0	0	0		
	WSAvg	2.8	2.1	2.3	3.0	3.3	3.4	3.3	3.2	2.9	2.7	2.5	2.1	2.1		
	PrecAvg	52.8	2.8	2.7	3.7	3.3	5.0	6.5	7.3	6.7	4.9	3.6	3.3	3.0		
(15) Precipitation	PrecMax	61.1	6.4	7.2	7.8	5.7	7.2	9.4	11.1	9.7	7.8	5.9	6.5	8.5		
	PrecMin	43.3	0.4	0.8	1.5	0.9	1.1	4.4	3.6	4.1	2.3	0.8	0.5	0.9		
	PrecStd	4.1	1.5	1.6	1.7	1.3	1.7	1.4	2.0	1.4	1.5	1.5	1.3	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.8	53.0	65.4	75.7	83.2	89.8	89.8	88.9	80.1	70.7	62.1	53.2		
		MCWB	44.3	42.7	50.4	57.8	63.7	68.7	68.7	68.6	64.5	58.0	50.9	43.7		
	2%	DB	40.5	47.6	60.4	70.9	77.7	84.0	85.4	84.6	74.9	65.7	55.1	42.8		
		MCWB	37.8	40.3	47.8	55.0	61.1	65.6	67.2	67.3	62.1	55.4	48.2	39.7		
	5%	DB	37.6	43.8	56.0	66.8	72.9	80.1	81.8	80.5	70.6	62.3	50.5	39.6		
		MCWB	35.7	38.0	45.7	52.8	58.4	64.2	65.9	65.7	60.2	53.7	46.0	37.3		
	10%	DB	35.3	40.5	51.2	63.0	68.9	75.7	77.9	76.3	66.8	58.8	46.8	37.1		
		MCWB	33.8	36.3	43.2	51.1	56.4	62.6	64.5	64.3	58.4	52.2	44.0	35.5		
	0.4%	WB	44.5	43.8	51.3	58.8	65.1	69.8	70.9	70.6	65.2	59.1	51.3	43.9		
		MCDB	49.2	51.3	64.2	74.7	79.4	85.4	85.6	85.3	77.2	68.6	59.4	51.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.9	40.8	48.5	55.6	62.1	67.4	68.6	68.2	63.1	56.6	48.4	40.7		
		MCDB	40.0	46.4	59.2	69.0	75.2	81.6	82.1	81.8	72.8	63.4	53.9	42.6		
	5%	WB	36.0	38.6	46.2	53.6	59.6	65.3	66.6	66.4	61.1	54.8	46.4	37.9		
		MCDB	37.5	42.7	54.9	65.1	70.9	77.3	78.3	78.3	68.8	60.5	50.4	39.3		
	10%	WB	34.1	36.8	43.8	51.7	57.5	63.4	65.2	64.7	59.2	53.0	44.3	35.7		
		MCDB	35.1	40.0	50.5	61.8	66.7	73.5	75.5	74.8	65.2	57.9	46.9	37.1		
	5% DB	MDBR	9.2	13.5	17.3	19.9	19.1	18.6	19.0	18.9	16.6	16.1	10.9	9.1		
		MCDBR	10.2	19.1	26.6	28.0	27.7	27.3	26.5	26.8	23.4	21.5	17.2	12.3		
		MCWBR	7.4	11.9	14.5	13.3	12.1	10.4	9.9	10.5	11.1	11.5	10.5	8.4		
		MCWBR	9.7	17.3	25.3	26.0	25.5	24.7	23.9	25.3	21.3	19.2	15.9	11.2		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.311	0.359	0.403	0.417	0.425	0.424	0.415	0.378	0.346	0.313	0.282		
		taud	2.365	2.274	2.218	2.190	2.212	2.242	2.248	2.291	2.369	2.426	2.449	2.427		
	Ebn at Noon		256	269	271	269	269	267	265	263	263	254	242	243		
		Edh at Noon	22	30	38	43	43	43	42	38	32	26	21	19		
(44) All-Sky Solar Radiation	RadAvg		418	712	1027	1305	1493	1655	1684	1496	1097	764	431	342		
	RadStd		50	90	122	165	180	169	159	176	144	82	72	53		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (86 neighbors)		+0.79	N/A	N/A	N/A	+0.72	+0.61	N/A	N/A	+126	+59

Nomenclature: See separate page