

ST VEIT IM PONGAU, Austria

WMO: 113450

Lat: 47.329N

Lon: 13.155E

Elev: 749

StdP: 92.64

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.1	-9.8	-13.9	1.2	-11.6	-11.9	1.5	-9.1	4.7	0.8	3.6	-0.3	0.8	270	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	29.8	19.5	27.9	18.7	26.0	17.9	20.3	28.0	19.3	26.2	18.5	24.6	2.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	13.9	23.2	16.9	13.2	22.1	16.2	12.6	21.0	61.6	28.2	58.3	26.4	55.3	24.7	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	4.0	3.3	-14.2	33.6	2.9	1.4	-16.2	34.6	-17.9	35.5	-19.5	36.3	-21.6	37.3		
(5)			-14.6	22.2	2.8	0.6	-16.7	22.6	-18.3	23.0	-19.9	23.4	-22.0	23.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-2.2	-0.1	4.4	9.6	13.1	16.8	18.6	18.1	13.7	9.4	3.2	-1.1	(6)	(7)
	DBStd	8.21	3.56	4.21	3.91	3.93	3.97	4.11	3.49	3.57	3.48	3.63	3.93	3.42	(7)	(8)
	HDD10.0	1524	379	283	175	54	17	3	0	1	8	55	206	343	(8)	(9)
	HDD18.3	3655	638	517	431	262	168	74	40	50	144	277	453	601	(9)	(10)
	CDD10.0	1038	0	0	2	42	112	209	266	251	118	37	2	0	(10)	(11)
	CDD18.3	128	0	0	0	0	5	29	48	42	4	0	0	0	(11)	(12)
	CDH23.3	1127	0	0	0	8	73	289	397	327	33	0	0	0	(12)	(13)
	CDH26.7	307	0	0	0	1	12	84	113	93	4	0	0	0	(13)	(14)
(14) Wind	WSAvg	1.2	0.9	1.0	1.3	1.5	1.5	1.5	1.4	1.3	1.2	1.1	1.0	0.9	(14)	(15)
(15) Precipitation	PrecAvg	1342	71	68	94	85	128	164	185	171	124	92	84	76	(15)	(16)
	PrecMax	1552	162	182	198	145	184	238	281	246	198	150	164	215	(16)	(17)
	PrecMin	1099	9	20	38	23	28	111	91	105	58	21	12	23	(17)	(18)
	PrecStd	105	39	40	44	33	42	35	52	36	37	37	33	38	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	11.7	18.5	24.3	28.4	32.1	32.1	31.6	26.7	21.5	16.7	11.8	(19)	(20)
		MCWB	6.8	5.9	10.2	14.4	17.6	20.4	20.4	20.4	18.0	14.4	10.5	6.5	(20)	(21)
	2%	DB	4.7	8.7	15.8	21.6	25.4	28.9	29.7	29.2	23.8	18.7	12.8	6.0	(21)	(22)
		MCWB	3.2	4.6	8.8	12.8	16.2	18.6	19.6	19.6	16.7	13.0	9.0	4.3	(22)	(23)
	5%	DB	3.1	6.6	13.3	19.3	22.7	26.7	27.6	26.9	21.5	16.9	10.3	4.2	(23)	(24)
		MCWB	2.1	3.3	7.6	11.6	14.7	17.9	18.8	18.7	15.7	12.0	7.8	2.9	(24)	(25)
	10%	DB	1.8	4.7	10.7	17.2	20.5	24.3	25.5	24.6	19.4	14.9	8.2	2.9	(25)	(26)
		MCWB	1.0	2.4	6.2	10.6	13.5	17.0	18.0	18.0	14.6	11.2	6.7	1.9	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	6.5	10.7	14.9	18.4	21.0	21.6	21.4	18.4	15.1	10.7	6.6	(27)	(28)
		MCDB	9.6	10.7	17.9	23.7	26.3	29.7	29.8	29.6	25.1	20.3	15.2	10.9	(28)	(29)
	2%	WB	3.3	4.9	9.2	13.1	16.7	19.6	20.3	20.1	17.3	13.7	9.1	4.8	(29)	(30)
		MCDB	4.4	8.0	15.1	20.6	24.0	27.6	27.8	27.7	22.7	17.5	12.2	5.9	(30)	(31)
	5%	WB	2.2	3.7	7.9	12.0	15.3	18.5	19.2	19.1	16.2	12.7	8.0	3.3	(31)	(32)
		MCDB	3.1	6.0	12.7	18.4	21.6	25.2	25.7	25.7	20.5	15.8	10.2	4.0	(32)	(33)
	10%	WB	1.2	2.7	6.5	11.0	14.1	17.4	18.4	18.2	15.1	11.7	6.8	2.1	(33)	(34)
		MCDB	1.7	4.5	10.3	16.6	19.3	23.1	24.2	23.8	18.5	14.4	8.3	2.8	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	7.5	9.6	11.1	10.6	10.3	10.5	10.5	9.2	9.0	6.1	5.0	(35)	(36)
		MCDBR	5.6	10.6	14.8	15.5	15.4	15.2	14.7	14.9	13.0	11.9	9.6	6.8	(36)	(37)
	5% WB	MCWBR	4.1	6.6	8.1	7.4	6.7	5.8	5.5	5.8	6.2	6.4	5.9	4.7	(37)	(38)
		MCDWR	5.4	9.6	14.0	14.4	14.1	13.7	13.3	14.0	11.8	10.7	8.9	6.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.280	0.311	0.359	0.403	0.417	0.425	0.424	0.415	0.378	0.346	0.313	0.282	(39)	(40)
		taud	2.365	2.274	2.218	2.190	2.212	2.242	2.248	2.291	2.369	2.426	2.449	2.427	(40)	(41)
	Ebn at Noon		808	847	854	848	848	842	836	828	828	801	762	765	(41)	(42)
		Edh at Noon	70	96	119	135	137	134	132	121	102	83	66	60	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		1.32	2.24	3.24	4.11	4.71	5.22	5.31	4.72	3.46	2.41	1.36	1.08	(43)	(44)
	RadStd		0.16	0.28	0.38	0.52	0.57	0.53	0.50	0.55	0.46	0.26	0.23	0.17	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (86 neighbors)	+0.44	N/A	N/A	N/A	+0.40	+0.34	N/A	N/A	+70	+33

Nomenclature: See separate page