

MARIAPFARR, Austria

WMO: 113480

Lat: 47.152N

Lon: 13.745E

Elev: 3783

StdP: 12.80

Time Zone: 1.00 (EUC)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.5	7.6	-0.3	6.2	5.9	3.2	7.5	10.3	22.1	27.1	19.5	25.8	2.2	350	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	79.4	62.7	76.2	61.2	73.1	59.9	64.1	75.9	62.4	73.7	60.8	70.9	6.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.9	88.6	68.6	58.2	83.3	66.5	56.7	79.0	64.6	31.4	76.2	30.1	73.9	28.8	71.0	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.9	14.1	-1.8	84.1	6.0	2.7	-6.1	86.0	-9.6	87.6	-12.9	89.1	-17.3	91.0		
(5)			-2.2	66.7	5.9	2.2	-6.4	68.2	-9.8	69.5	-13.1	70.7	-17.4	72.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.9	24.8	28.5	34.9	42.0	50.0	56.2	59.6	59.2	51.8	44.5	35.3	26.8		
	DBStd	13.89	7.77	7.58	7.34	6.38	5.71	6.40	5.55	5.54	6.14	6.50	7.51	7.65		
	HDD50	3600	781	601	470	247	72	19	3	5	53	188	441	720		
	HDD65	8102	1246	1021	935	691	465	268	180	191	395	635	890	1185		
	CDD50	1001	0	0	0	7	73	205	300	290	107	18	1	0		
	CDD65	27	0	0	0	0	0	4	12	11	0	0	0	0		
	CDH74	518	0	0	0	0	12	112	204	184	6	0	0	0		
	CDH80	64	0	0	0	0	0	8	26	30	0	0	0	0		
(14) Wind	WSAvg	4.8	4.7	5.4	5.8	5.8	5.5	5.1	5.0	4.2	4.3	3.9	4.2	3.8		
(15) Precipitation	PrecAvg	39.6	1.5	1.4	2.0	2.2	3.6	5.2	5.9	5.6	3.9	3.5	3.0	1.8		
	PrecMax	46.9	3.0	4.7	4.4	3.7	5.2	8.4	10.4	8.8	6.3	8.4	7.0	5.7		
	PrecMin	32.6	0.3	0.2	0.4	0.8	1.8	2.8	1.0	3.3	2.2	0.6	0.0	0.3		
	PrecStd	4.4	0.9	1.1	1.0	0.7	0.9	1.4	2.2	1.3	1.1	1.7	1.7	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	50.9	60.0	66.4	75.8	81.0	83.3	83.7	74.6	67.0	57.6	49.4		
		MCWB	39.9	40.9	47.3	51.4	58.0	62.7	64.8	65.1	60.3	55.0	48.1	40.0		
	2%	DB	42.9	46.0	55.0	62.1	70.7	77.2	79.4	79.0	70.1	62.4	52.9	43.1		
		MCWB	37.2	38.4	43.8	49.4	56.2	60.7	63.1	63.0	57.7	51.9	46.0	37.9		
	5%	DB	39.4	42.5	51.1	58.6	66.8	73.8	75.7	75.2	66.5	58.6	49.4	39.7		
		MCWB	34.8	36.3	41.8	47.7	54.3	59.6	61.9	61.2	55.6	50.3	44.1	35.5		
	10%	DB	35.8	39.3	46.7	54.8	63.0	69.9	72.2	71.3	63.0	55.0	46.0	36.6		
		MCWB	32.6	34.3	39.9	45.4	52.2	57.8	60.2	59.6	54.4	48.9	42.4	33.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.6	41.7	47.7	52.8	59.6	64.6	66.6	66.6	61.7	56.2	49.5	42.1		
		MCDB	46.2	48.7	58.5	64.6	72.1	78.0	79.6	80.8	71.9	64.4	55.1	45.8		
	2%	WB	37.8	39.1	44.7	50.1	57.0	62.0	64.5	63.9	59.1	53.5	46.8	38.5		
		MCDB	41.6	44.7	53.2	60.3	68.9	74.1	75.5	76.1	67.9	60.0	51.3	42.3		
	5%	WB	35.0	36.7	42.3	48.2	55.0	60.4	62.7	62.1	57.0	51.6	45.0	36.1		
		MCDB	38.1	41.7	49.7	57.2	65.3	71.5	73.7	73.1	64.2	56.9	48.5	39.1		
	10%	WB	32.9	34.6	40.3	46.2	53.0	58.6	61.0	60.3	55.2	49.6	42.7	33.8		
		MCDB	35.7	38.7	46.3	53.5	61.5	68.2	70.4	69.6	61.4	54.2	46.0	36.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	15.7	17.1	18.1	19.5	19.3	19.7	19.9	18.2	18.3	13.0	12.8		
		MCDBR	16.8	21.4	26.0	26.8	28.3	28.1	27.3	27.8	24.6	24.3	18.8	16.6		
		MCWBR	11.8	13.9	15.2	14.5	14.3	12.7	12.5	12.7	12.8	14.2	12.3	11.9		
		MCDBR	15.1	19.3	23.9	24.7	26.5	25.5	25.2	26.0	21.6	21.4	16.0	15.1		
	5% WB	MCWBR	11.3	13.1	14.3	13.6	13.7	12.0	12.1	12.3	11.6	13.0	10.9	11.2		
(40) Clear-Sky Solar Irradiance	taub		0.267	0.297	0.343	0.388	0.399	0.405	0.405	0.397	0.363	0.335	0.302	0.269		
	taud		2.386	2.307	2.260	2.222	2.246	2.274	2.275	2.316	2.388	2.442	2.468	2.448		
	Ebn at Noon		264	276	277	274	274	273	271	268	268	259	248	251		
	Edh at Noon		22	30	36	42	42	41	41	37	32	26	21	18		
(44) All-Sky Solar Radiation	RadAvg		420	704	1033	1315	1523	1689	1713	1517	1112	763	432	347		
	RadStd		49	91	123	162	179	154	150	171	142	82	72	52		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (96 neighbors)	+0.85	N/A	N/A	+1.37	+0.88	+0.68	N/A	-220	+146	+86

Nomenclature: See separate page