

RAMSAU AM DACHSTEIN, Austria

WMO: 113510

Lat: 47.4253N

Lon: 13.6342E

Elev: 3969

StdP: 12.71

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.2	11.2	2.7	7.3	9.2	6.6	8.9	14.0	16.1	26.3	14.1	27.0	2.9	0	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	78.2	62.9	75.1	61.6	72.0	60.2	64.4	75.3	62.7	72.5	61.2	70.2	4.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.6	91.6	68.9	59.0	86.4	67.0	57.5	81.8	65.4	31.7	75.2	30.4	72.4	29.2	70.4	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.6	9.2	2.8	83.8	6.2	2.8	-1.7	85.8	-5.3	87.4	-8.8	89.0	-13.3	91.1		
(5)			2.2	67.3	5.9	1.7	-2.1	68.5	-5.5	69.5	-8.9	70.5	-13.2	71.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.2	26.4	28.6	34.1	42.3	49.9	56.1	59.2	59.1	51.6	45.5	36.0	29.2		
	DBStd	13.88	7.54	8.50	8.04	8.03	7.13	7.56	6.38	6.47	6.92	7.51	8.67	7.92		
	HDD50	3521	733	599	493	251	92	29	7	8	65	175	424	645		
	HDD65	7990	1198	1019	958	682	469	277	199	201	403	604	870	1110		
	CDD50	1053	0	0	0	19	88	213	291	290	112	36	4	0		
	CDD65	49	0	0	0	0	1	11	18	18	1	0	0	0		
	CDH74	375	0	0	0	0	7	103	137	125	3	0	0	0		
	CDH80	37	0	0	0	0	0	12	14	11	0	0	0	0		
(14) Wind	WSAvg	3.8	4.3	4.5	4.5	4.2	3.8	3.5	3.6	3.2	3.2	3.3	3.8	3.8		
(15) Precipitation	PrecAvg	53.9	2.8	2.8	3.8	3.3	4.8	6.9	7.7	6.8	5.0	3.7	3.3	2.9		
	PrecMax	61.9	5.8	6.5	9.1	5.0	7.2	10.3	12.8	10.6	9.3	6.2	6.5	9.2		
	PrecMin	45.6	0.4	0.9	1.6	1.3	1.7	5.0	3.0	4.3	2.4	0.9	0.6	1.0		
	PrecStd	4.4	1.5	1.4	1.9	0.9	1.5	1.3	2.5	1.5	1.5	1.3	1.3	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.3	49.6	57.2	67.5	74.9	81.6	81.8	81.4	73.3	67.0	59.0	48.9		
		MCWB	38.9	39.4	45.2	53.4	58.8	63.7	64.4	64.2	60.8	55.6	48.9	40.9		
	2%	DB	42.5	45.2	52.9	62.7	69.6	76.9	77.9	77.5	69.4	63.2	54.7	44.8		
		MCWB	37.2	37.4	42.9	50.2	56.5	62.1	63.1	62.9	58.6	53.7	46.7	38.3		
	5%	DB	39.4	42.2	48.9	58.7	66.0	73.3	74.3	74.2	65.7	59.4	51.0	41.6		
		MCWB	35.3	36.1	40.7	47.9	54.6	60.4	61.7	61.7	56.5	51.5	44.5	36.5		
	10%	DB	36.5	39.4	45.0	54.7	62.3	69.2	70.7	70.5	62.4	55.8	47.5	38.8		
		MCWB	33.3	34.3	38.7	45.8	52.5	58.4	60.3	60.1	55.0	49.7	42.6	35.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.4	40.8	46.6	54.1	60.1	66.1	66.5	66.2	62.2	57.0	49.8	42.0		
		MCDB	44.4	47.0	55.1	65.8	70.7	78.4	77.9	77.3	70.3	65.6	56.8	47.1		
	2%	WB	37.7	38.5	43.6	50.8	57.5	63.2	64.3	64.2	59.7	54.3	47.3	39.6		
		MCDB	41.4	43.8	51.6	61.1	67.8	73.8	74.9	75.1	67.5	61.3	53.7	43.6		
	5%	WB	35.7	36.8	41.3	48.6	55.5	61.2	62.6	62.4	57.6	52.3	45.2	37.5		
		MCDB	39.0	41.4	47.5	57.2	64.2	71.1	72.0	72.1	64.1	58.1	50.1	40.5		
	10%	WB	33.7	34.9	39.3	46.6	53.4	59.4	61.0	60.7	55.6	50.4	43.0	35.4		
		MCDB	36.1	38.8	44.0	53.6	60.8	67.9	69.4	69.4	61.0	55.1	46.8	38.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	11.7	13.1	14.9	16.1	16.4	16.1	16.3	14.6	14.3	10.5	9.3		
		MCDBR	12.1	15.4	18.9	21.3	22.5	23.4	22.4	22.2	19.9	18.8	15.3	12.7		
	5% WB	MCWBR	8.7	10.1	10.7	11.0	11.0	10.6	10.1	10.1	10.2	11.2	9.6	9.0		
		MCWBR	10.9	13.8	17.5	20.0	20.9	21.5	20.4	20.5	18.0	17.0	14.1	11.6		
(40) Clear-Sky Solar Irradiance	taub		0.262	0.291	0.332	0.371	0.383	0.388	0.390	0.382	0.351	0.323	0.294	0.264		
		taud	2.398	2.330	2.295	2.284	2.299	2.322	2.316	2.357	2.423	2.480	2.496	2.460		
	Ebn at Noon		266	278	281	279	279	278	275	273	272	264	251	252		
		Edh at Noon	21	29	35	39	40	39	39	36	30	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		408	701	1014	1301	1488	1643	1668	1485	1085	758	426	332		
	RadStd		49	88	119	160	177	166	161	177	144	79	69	52		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (98 neighbors)		+0.85	N/A	N/A	+1.33	+0.81	+0.65	N/A	N/A	+140	+74

Nomenclature: See separate page