

RAMSAU AM DACHSTEIN, Austria

WMO: 113510

Lat: 47.4253N

Lon: 13.6342E

Elev: 1210

StdP: 87.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.8	-11.5	-16.3	1.0	-12.6	-14.1	1.3	-10.0	7.2	-3.2	6.3	-2.8	1.3	0	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	25.7	17.2	24.0	16.5	22.2	15.7	18.0	24.1	17.1	22.5	16.2	21.2	1.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.9	13.1	20.5	15.0	12.3	19.4	14.2	11.7	18.5	55.9	24.0	52.8	22.5	50.1	21.3	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
5.5	4.7	4.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-16.2	28.8	3.5	1.6	-18.7	29.9	-20.7	30.8	-22.7	31.7	-25.2	32.8		
			-16.5	19.6	3.3	0.9	-18.9	20.3	-20.9	20.9	-22.7	21.4	-25.1	22.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-3.1	-1.9	1.2	5.7	9.9	13.4	15.1	15.0	10.9	7.5	2.2	-1.6	(6)
(7)		DBStd	7.71	4.19	4.72	4.47	4.46	3.96	4.20	3.54	3.59	3.85	4.17	4.82	4.40	(7)
(8)		HDD10.0	1956	407	333	274	139	51	16	4	4	36	97	236	358	(8)
(9)		HDD18.3	4439	666	566	532	379	261	154	111	112	224	336	483	617	(9)
(10)		CDD10.0	585	0	0	0	11	49	118	162	161	62	20	2	0	(10)
(11)		CDD18.3	27	0	0	0	0	1	6	10	10	1	0	0	0	(11)
(12)		CDH23.3	208	0	0	0	0	4	57	76	69	2	0	0	0	(12)
(13)		CDH26.7	21	0	0	0	0	0	7	8	6	0	0	0	0	(13)
(14)	Wind	WSAvg	1.7	1.9	2.0	2.0	1.9	1.7	1.6	1.6	1.4	1.4	1.5	1.7	1.7	(14)
(15)	Precipitation	PrecAvg	1368	72	72	97	85	122	176	195	173	126	93	84	74	(15)
(16)		PrecMax	1571	148	166	230	126	183	262	324	269	235	157	164	234	(16)
(17)		PrecMin	1158	10	22	40	32	44	128	77	108	61	24	15	26	(17)
(18)		PrecStd	111	38	36	48	24	38	34	64	39	37	32	34	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	9.8	14.0	19.7	23.8	27.6	27.7	27.4	23.0	19.5	15.0	9.4	(19)
(20)			MCWB	3.8	4.1	7.3	11.9	14.9	17.6	18.0	17.9	16.0	13.1	9.4	5.0	(20)
(21)		2%	DB	5.9	7.3	11.6	17.1	20.9	24.9	25.5	25.3	20.8	17.3	12.6	7.1	(21)
(22)			MCWB	2.9	3.0	6.1	10.1	13.6	16.7	17.3	17.2	14.8	12.0	8.1	3.5	(22)
(23)		5%	DB	4.1	5.7	9.4	14.8	18.9	22.9	23.5	23.5	18.7	15.2	10.6	5.3	(23)
(24)			MCWB	1.8	2.3	4.8	8.9	12.6	15.8	16.5	16.5	13.6	10.8	6.9	2.5	(24)
(25)		10%	DB	2.5	4.1	7.2	12.6	16.8	20.6	21.5	21.4	16.9	13.2	8.6	3.8	(25)
(26)			MCWB	0.7	1.3	3.7	7.7	11.4	14.6	15.7	15.6	12.8	9.8	5.9	1.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	4.9	8.1	12.3	15.6	18.9	19.2	19.0	16.8	13.9	9.9	5.6	(27)
(28)			MCDWB	6.9	8.4	12.9	18.8	21.5	25.8	25.5	25.2	21.3	18.7	13.8	8.4	(28)
(29)		2%	WB	3.1	3.6	6.4	10.5	14.1	17.3	17.9	17.9	15.4	12.4	8.5	4.2	(29)
(30)			MCDWB	5.2	6.6	10.9	16.2	19.9	23.2	23.9	24.0	19.7	16.3	12.0	6.5	(30)
(31)		5%	WB	2.0	2.7	5.2	9.2	13.0	16.2	17.0	16.9	14.2	11.3	7.3	3.1	(31)
(32)			MCDWB	3.9	5.2	8.6	14.0	17.9	21.7	22.2	22.3	17.9	14.5	10.1	4.7	(32)
(33)		10%	WB	0.9	1.6	4.1	8.1	11.9	15.2	16.1	16.0	13.1	10.2	6.1	1.9	(33)
(34)			MCDWB	2.3	3.8	6.7	12.0	16.0	20.0	20.8	20.8	16.1	12.8	8.2	3.5	(34)
(35)	Mean Daily Temperature Range	MDBR	5.5	6.5	7.3	8.3	8.9	9.1	9.0	9.1	8.1	8.0	5.8	5.2	(35)	
(36)		5% DB	MCDBR	6.7	8.6	10.5	11.9	12.5	13.0	12.5	12.3	11.1	10.4	8.5	7.0	(36)
(37)			MCWBR	4.9	5.6	6.0	6.1	6.1	5.9	5.6	5.6	5.7	6.2	5.3	5.0	(37)
(38)		5% WB	MCDBR	6.1	7.7	9.7	11.1	11.6	12.0	11.3	11.4	10.0	9.4	7.8	6.5	(38)
(39)			MCWBR	4.6	5.3	5.8	5.9	6.1	5.8	5.5	5.6	5.5	5.9	5.1	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.262	0.291	0.332	0.371	0.383	0.388	0.390	0.382	0.351	0.323	0.294	0.264	(40)	
(41)		taud	2.398	2.330	2.295	2.284	2.299	2.322	2.316	2.357	2.423	2.480	2.496	2.460	(41)	
(42)		Ebn at Noon	837	876	885	881	881	875	868	860	858	832	792	795	(42)	
(43)		Edh at Noon	67	90	110	123	126	124	123	113	96	78	62	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.28	2.21	3.20	4.10	4.69	5.18	5.26	4.68	3.42	2.39	1.34	1.05	(44)	
(45)		RadStd	0.15	0.28	0.38	0.50	0.56	0.52	0.51	0.56	0.45	0.25	0.22	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (98 neighbors)	+0.47	N/A	N/A	+0.74	+0.45	+0.36	N/A	N/A	+78	+41

Nomenclature: See separate page