

BAD AUSSEE, Austria

WMO: 113560

Lat: 47.611N

Lon: 13.758E

Elev: 742

StdP: 92.72

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.0	-10.5	-14.9	1.1	-11.6	-12.6	1.4	-9.6	6.7	1.1	5.9	0.9	0.9	280	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	29.7	19.3	27.9	18.5	26.0	17.7	20.0	27.9	19.2	26.3	18.3	24.5	1.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	13.7	22.2	16.7	13.0	21.4	16.0	12.5	20.6	60.5	28.2	57.6	26.4	54.8	24.6	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.0	4.2	3.4	-15.8	33.5	3.9	1.4	-18.6	34.5	-20.9	35.3	-23.1	36.1	-25.9	37.1		
(5)			-16.5	21.8	3.8	0.7	-19.2	22.4	-21.4	22.8	-23.5	23.2	-26.2	23.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-2.0	0.0	3.9	8.9	13.1	16.6	18.1	18.0	13.7	9.6	3.8	-0.5		
	DBStd	8.09	4.06	4.21	3.80	4.16	3.97	4.06	3.48	3.52	3.56	3.75	4.22	3.82		
	HDD10.0	1509	373	281	190	68	17	3	0	1	8	54	190	324		
	HDD18.3	3651	631	514	447	283	166	79	48	51	142	272	436	583		
	CDD10.0	1014	0	0	1	35	113	201	251	247	121	41	4	0		
	CDD18.3	113	0	0	0	0	4	27	40	39	4	0	0	0		
	CDH23.3	1126	0	0	0	8	76	293	383	326	39	1	0	0		
	CDH26.7	291	0	0	0	1	12	80	111	84	4	0	0	0		
(14) Wind	WSAvg	1.3	1.4	1.4	1.4	1.5	1.3	1.1	1.1	1.1	1.1	1.3	1.4	1.3		
(15) Precipitation	PrecAvg	1684	111	99	134	109	148	192	216	183	155	110	113	114		
	PrecMax	1945	258	202	302	186	254	326	413	329	298	208	265	264		
	PrecMin	1406	15	37	57	38	40	116	110	90	74	40	24	49		
	PrecStd	143	59	44	65	36	53	47	74	51	57	43	52	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	12.0	18.0	24.2	28.5	31.8	32.2	31.5	26.8	22.4	17.6	11.8		
		MCWB	6.7	6.1	9.8	14.3	17.4	20.0	20.3	20.1	17.8	14.5	10.9	6.8		
	2%	DB	6.5	9.4	15.5	21.5	25.5	29.0	29.6	29.0	24.2	19.7	15.0	7.7		
		MCWB	3.8	4.5	8.5	12.7	15.8	18.9	19.3	19.2	16.4	13.1	9.8	4.8		
	5%	DB	4.2	7.2	12.8	19.2	23.2	26.8	27.5	27.0	22.3	17.7	12.3	5.7		
		MCWB	2.6	3.7	7.1	11.4	14.8	17.8	18.7	18.5	15.6	12.1	8.5	4.0		
	10%	DB	2.6	5.3	10.2	16.9	20.8	24.5	25.3	24.9	20.2	15.7	9.8	4.1		
		MCWB	1.5	2.7	5.9	10.2	13.6	16.8	17.6	17.7	14.6	11.2	7.2	2.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	6.6	10.1	14.7	18.0	20.7	21.2	20.9	18.6	15.0	11.5	7.1		
		MCDB	10.2	11.1	16.8	23.5	25.6	29.0	29.7	28.8	24.9	20.3	16.3	10.7		
	2%	WB	4.1	5.0	8.8	13.1	16.6	19.5	20.0	19.8	17.2	13.8	10.0	5.6		
		MCDB	5.9	8.3	14.5	20.8	24.0	27.3	28.0	27.3	22.5	18.0	14.3	7.3		
	5%	WB	2.7	3.9	7.6	11.7	15.4	18.5	19.1	18.9	16.2	12.7	8.7	4.1		
		MCDB	4.0	6.7	12.0	18.4	21.8	25.3	26.1	25.7	21.1	16.6	11.9	5.6		
	10%	WB	1.7	2.9	6.3	10.5	14.2	17.4	18.2	18.1	15.2	11.8	7.5	2.8		
		MCDB	2.5	5.2	9.7	16.0	19.8	23.2	24.0	23.8	19.2	15.1	9.7	3.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	7.5	9.2	10.7	10.5	10.5	10.5	10.6	9.6	9.3	6.6	5.5		
		MCDBR	7.0	11.2	14.7	15.8	15.9	15.7	15.3	14.6	13.5	12.9	10.3	7.2		
		MCWBR	4.8	6.9	8.2	7.7	6.9	6.2	5.8	5.8	6.3	6.8	5.9	5.0		
		MCWBR	6.6	9.8	13.8	14.7	14.6	14.1	13.9	13.8	12.3	11.5	9.4	6.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.281	0.311	0.354	0.392	0.404	0.409	0.412	0.404	0.373	0.341	0.312	0.282		
		taud	2.385	2.309	2.265	2.248	2.263	2.291	2.284	2.325	2.387	2.451	2.470	2.442		
		Ebn at Noon	806	847	859	859	860	856	847	838	832	806	763	762		
		Edh at Noon	68	92	113	127	130	128	127	117	100	80	64	58		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.23	2.15	3.15	4.12	4.72	5.20	5.23	4.66	3.38	2.34	1.30	1.00		
		RadStd	0.15	0.27	0.37	0.50	0.56	0.51	0.51	0.55	0.45	0.24	0.20	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (98 neighbors)	+0.49	N/A	N/A	+0.76	+0.45	+0.36	N/A	N/A	+75	+40

Nomenclature: See separate page