

BAD MITTERNDORF, Austria

WMO: 113580

Lat: 47.553N

Lon: 13.935E

Elev: 2630

StdP: 13.35

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.3	8.1	0.6	6.2	4.0	4.9	7.8	9.3	17.8	33.1	15.5	32.7	0.8	300	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	84.3	65.5	80.8	64.0	77.5	62.6	66.9	80.8	65.3	77.9	63.8	74.8	5.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.5	93.2	70.5	60.9	88.2	68.6	59.6	84.0	67.8	32.9	81.3	31.6	78.0	30.4	74.9	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.4	9.6	-3.0	90.5	7.2	2.5	-8.1	92.3	-12.3	93.8	-16.4	95.2	-21.6	97.0		
(5)			-3.5	69.7	7.0	1.8	-8.5	71.0	-12.6	72.0	-16.6	73.0	-21.6	74.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	25.7	29.6	36.8	45.5	53.5	60.1	62.6	62.5	54.7	46.9	36.6	28.2		
	DBStd	14.80	7.85	7.80	6.77	6.82	6.79	7.09	6.08	5.95	6.21	6.61	7.51	7.61		
	HDD50	3201	754	572	409	165	44	9	1	2	26	136	408	675		
	HDD65	7308	1219	992	874	585	359	176	117	118	313	562	853	1140		
	CDD50	1485	0	0	0	30	152	312	393	389	166	39	4	0		
	CDD65	117	0	0	0	0	2	29	44	40	2	0	0	0		
	CDH74	1559	0	0	0	5	80	407	529	494	44	0	0	0		
	CDH80	364	0	0	0	0	10	98	133	120	3	0	0	0		
	WSAvg	3.2	3.1	3.3	3.4	3.5	3.6	3.5	3.3	3.0	2.9	3.0	2.9	2.8		
	PrecAvg	66.3	4.4	3.9	5.3	4.3	5.8	7.6	8.5	7.2	6.1	4.3	4.4	4.5		
	PrecMax	76.6	10.2	8.0	11.9	7.3	10.0	12.8	16.3	13.0	11.7	8.2	10.4	10.4		
(15) Precipitation	PrecMin	55.4	0.6	1.5	2.2	1.5	1.6	4.6	4.3	3.5	2.9	1.6	0.9	1.9		
	PrecStd	5.6	2.3	1.7	2.6	1.4	2.1	1.9	2.9	2.0	2.2	1.7	2.0	1.8		
	DB	48.1	52.0	62.1	73.7	81.4	87.9	88.3	87.9	78.8	70.4	63.7	49.7			
	MCWB	43.2	41.8	47.9	56.7	61.4	66.5	67.0	66.7	62.7	57.1	50.8	42.8			
	2% DB	40.9	46.8	57.7	68.3	75.9	82.6	83.8	83.4	73.9	66.0	57.2	43.0			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	37.7	39.3	45.9	53.5	59.1	64.4	65.7	65.4	60.4	55.1	48.6	39.8			
	5% DB	37.2	42.9	52.9	64.3	71.7	78.9	80.0	79.5	70.3	62.2	51.9	39.7			
	MCWB	35.2	37.6	43.6	51.3	57.1	62.7	64.1	64.2	58.9	53.2	46.1	37.5			
	10% DB	35.0	39.4	48.1	60.2	67.7	74.7	76.0	75.8	66.7	58.4	47.4	36.8			
	MCWB	33.6	35.5	41.2	48.9	55.2	61.0	62.5	62.7	57.2	51.4	44.0	35.1			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	43.9	43.0	49.1	57.3	62.9	67.9	68.9	68.7	64.1	58.3	51.9	43.5			
	MCDB	48.0	49.6	59.7	72.6	76.4	84.1	83.5	82.5	74.6	67.9	60.7	48.7			
	2% WB	37.9	40.2	46.4	54.3	60.4	65.7	66.7	66.8	61.9	56.0	49.3	40.3			
	MCDB	40.3	45.8	56.1	66.9	73.6	79.5	80.2	80.5	71.5	63.7	56.5	42.7			
	5% WB	35.5	37.9	44.1	51.9	58.2	63.8	65.2	65.1	59.9	54.1	46.7	37.7			
(33) Mean Daily Temperature Range	MCDB	37.2	42.3	51.7	62.9	69.4	76.0	77.2	77.3	68.2	60.9	51.4	39.7			
	10% WB	33.8	35.8	41.7	49.5	56.2	62.0	63.6	63.4	58.0	52.3	43.9	35.3			
	MCDB	34.8	38.9	47.5	58.6	65.9	72.7	73.8	73.8	65.2	57.6	47.2	36.6			
	5% DB	12.7	15.1	17.5	20.2	19.5	19.4	19.3	20.3	18.5	18.8	13.0	11.5			
	MCDBR	12.9	21.5	27.8	30.5	29.1	29.3	28.1	28.5	26.2	26.0	20.3	14.3			
(40) Clear-Sky Solar Irradiance	MCWBR	10.3	14.5	16.3	16.0	13.2	12.0	11.4	11.9	13.1	15.5	12.8	10.9			
	5% WB	12.2	19.2	25.7	28.2	26.7	26.3	25.1	26.5	23.6	24.0	18.6	13.8			
	MCDBR	10.0	13.2	15.5	15.0	12.3	11.1	10.6	11.4	11.9	14.6	12.1	10.7			
	taub	0.277	0.307	0.350	0.389	0.401	0.406	0.409	0.401	0.370	0.339	0.310	0.278			
	taud	2.384	2.313	2.272	2.254	2.271	2.297	2.290	2.331	2.394	2.456	2.477	2.446			
(42) All-Sky Solar Radiation	Ebn at Noon	257	271	274	273	274	272	270	267	265	257	243	244			
	Edh at Noon	22	29	36	40	41	40	40	37	31	25	20	18			
	RadAvg	391	679	996	1303	1496	1644	1654	1477	1073	745	416	319			
(45)	RadStd	46	84	115	152	175	154	159	175	141	75	63	49			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (104 neighbors)		+0.90	N/A	N/A	+1.42	+0.83	+0.68	N/A	N/A	+142	+74

Nomenclature: See separate page