

BAD MITTERNDORF, Austria

WMO: 113580

Lat: 47.553N

Lon: 13.935E

Elev: 802

StdP: 92.06

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.0	-13.3	-17.4	0.9	-15.6	-15.1	1.1	-12.6	7.9	0.6	6.9	0.4	0.4	300	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	29.0	18.6	27.1	17.8	25.3	17.0	19.4	27.1	18.5	25.5	17.7	23.8	2.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.9	13.3	21.4	16.1	12.6	20.3	15.3	12.0	19.9	58.6	27.4	55.6	25.6	52.8	23.8	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.1	4.3	DB	-19.4	32.5	4.0	1.4	-22.3	33.5	-24.6	34.3	-26.9	35.1	-29.8	36.1	(4)
(5)			WB	-19.7	20.9	3.9	1.0	-22.5	21.7	-24.8	22.2	-27.0	22.8	-29.8	23.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-3.5	-1.4	2.7	7.5	11.9	15.6	17.0	16.9	12.6	8.3	2.5	-2.1	(6)
(7)		DBStd	8.22	4.36	4.34	3.76	3.79	3.77	3.94	3.38	3.30	3.45	3.67	4.17	4.23	(7)
(8)		HDD10.0	1778	419	318	227	92	24	5	1	1	14	76	227	375	(8)
(9)		HDD18.3	4060	677	551	486	325	199	98	65	66	174	312	474	633	(9)
(10)		CDD10.0	825	0	0	0	17	84	173	218	216	92	22	2	0	(10)
(11)		CDD18.3	65	0	0	0	0	1	16	24	22	1	0	0	0	(11)
(12)		CDH23.3	866	0	0	0	3	44	226	294	274	24	0	0	0	(12)
(13)		CDH26.7	202	0	0	0	0	6	54	74	67	2	0	0	0	(13)
(14)	Wind	WSAvg	1.4	1.4	1.5	1.5	1.6	1.5	1.5	1.3	1.3	1.3	1.3	1.2	(14)	
(15)	Precipitation	PrecAvg	1684	111	99	134	109	148	192	216	183	155	110	113	114	(15)
(16)		PrecMax	1945	258	202	302	186	254	326	413	329	298	208	265	264	(16)
(17)		PrecMin	1406	15	37	57	38	40	116	110	90	74	40	24	49	(17)
(18)		PrecStd	143	59	44	65	36	53	47	74	51	57	43	52	46	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	11.1	16.7	23.2	27.4	31.1	31.3	31.0	26.0	21.3	17.6	9.8	(19)
(20)			MCWB	6.2	5.5	8.8	13.7	16.3	19.2	19.4	19.3	17.1	14.0	10.5	6.0	(20)
(21)		2%	DB	4.9	8.2	14.3	20.2	24.4	28.1	28.8	28.5	23.3	18.9	14.0	6.1	(21)
(22)			MCWB	3.2	4.0	7.7	11.9	15.1	18.0	18.7	18.6	15.8	12.8	9.2	4.3	(22)
(23)		5%	DB	2.9	6.0	11.6	17.9	22.1	26.1	26.7	26.4	21.3	16.8	11.1	4.3	(23)
(24)			MCWB	1.8	3.1	6.5	10.7	13.9	17.1	17.8	17.9	14.9	11.8	7.8	3.1	(24)
(25)		10%	DB	1.7	4.1	9.0	15.7	19.8	23.7	24.5	24.3	19.3	14.7	8.5	2.7	(25)
(26)			MCWB	0.9	2.0	5.1	9.4	12.9	16.1	17.0	17.1	14.0	10.8	6.7	1.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	6.1	9.5	14.0	17.2	19.9	20.5	20.4	17.8	14.6	11.1	6.4	(27)
(28)			MCD B	8.9	9.8	15.4	22.6	24.7	29.0	28.6	28.1	23.7	20.0	16.0	9.3	(28)
(29)		2%	WB	3.3	4.6	8.0	12.4	15.8	18.7	19.3	19.3	16.6	13.3	9.6	4.6	(29)
(30)			MCD B	4.6	7.7	13.4	19.4	23.1	26.4	26.8	26.9	22.0	17.6	13.6	5.9	(30)
(31)		5%	WB	2.0	3.3	6.7	11.0	14.6	17.7	18.4	18.4	15.5	12.3	8.2	3.2	(31)
(32)			MCD B	2.9	5.7	11.0	17.2	20.8	24.4	25.1	25.2	20.1	16.1	10.8	4.3	(32)
(33)		10%	WB	1.0	2.1	5.4	9.7	13.4	16.7	17.5	17.5	14.4	11.3	6.6	1.8	(33)
(34)			MCD B	1.6	3.8	8.6	14.8	18.8	22.6	23.2	23.2	18.4	14.2	8.4	2.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.1	8.4	9.7	11.2	10.8	10.8	10.7	11.3	10.3	10.4	7.2	6.4	(35)
(36)			MCDBR	7.2	11.9	15.4	17.0	16.2	16.3	15.6	15.8	14.6	14.4	11.3	8.0	(36)
(37)			MCWBR	5.7	8.1	9.1	8.9	7.3	6.6	6.4	6.6	7.3	8.6	7.1	6.0	(37)
(38)		5% WB	MCD BR	6.8	10.7	14.3	15.7	14.8	14.6	14.0	14.7	13.1	13.4	10.3	7.7	(38)
(39)			MCWBR	5.5	7.3	8.6	8.3	6.8	6.2	5.9	6.3	6.6	8.1	6.7	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.277	0.307	0.350	0.389	0.401	0.406	0.409	0.401	0.370	0.339	0.310	0.278	(40)	
(41)		taud	2.384	2.313	2.272	2.254	2.271	2.297	2.290	2.331	2.394	2.456	2.477	2.446	(41)	
(42)		Ebn at Noon	811	853	864	862	863	858	850	841	836	810	767	769	(42)	
(43)		Edh at Noon	68	92	112	126	129	127	126	116	99	80	64	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.23	2.14	3.14	4.11	4.72	5.18	5.21	4.66	3.38	2.35	1.31	1.00	(44)	
(45)		RadStd	0.14	0.27	0.36	0.48	0.55	0.49	0.50	0.55	0.45	0.23	0.20	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (104 neighbors)	+0.50	N/A	N/A	+0.79	+0.46	+0.38	N/A	N/A	+79	+41

Nomenclature: See separate page