

REICHENAU AN DER RAX, Austria

WMO: 113800

Lat: 47.6997N

Lon: 15.8369E

Elev: 488

StdP: 95.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-9.5	-14.7	1.1	-9.6	-12.5	1.4	-7.5	10.4	0.7	9.5	1.6	1.1	280	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	29.9	20.0	28.0	19.2	26.3	18.3	21.0	27.7	20.0	26.4	19.2	24.9	2.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.6	22.9	17.9	13.6	22.1	17.0	12.9	21.6	62.7	27.5	59.5	26.5	56.5	24.9	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.5	6.4	DB	-14.9	33.2	3.0	1.8	-17.1	34.5	-18.8	35.5	-20.5	36.5	-22.7	37.8	(4)
(5)			WB	-15.1	22.9	3.0	1.1	-17.3	23.7	-19.0	24.3	-20.7	24.9	-22.8	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.1	1.6	4.8	9.4	13.5	17.1	18.9	18.5	14.1	10.0	5.5	1.1	(6)	
	DBStd	7.70	4.73	4.80	4.26	3.93	3.39	3.36	3.03	3.04	3.31	3.73	4.19	4.56	(7)	
	HDD10.0	1253	313	236	166	57	8	1	0	0	5	47	144	277	(8)	
	HDD18.3	3313	571	468	419	269	153	62	30	34	131	258	384	534	(9)	
	CDD10.0	1104	1	2	6	38	117	214	275	265	129	48	9	1	(10)	
	CDD18.3	120	0	0	0	0	3	25	47	41	4	0	0	0	(11)	
	CDH23.3	1247	0	0	0	8	65	266	447	404	54	3	0	0	(12)	
	CDH26.7	326	0	0	0	0	7	68	122	122	7	0	0	0	(13)	
(14) Wind	WSAvg	2.2	2.6	2.6	2.5	2.3	2.1	2.0	2.1	1.7	1.8	1.8	2.1	2.3	(14)	
(15) Precipitation	PrecAvg	1071	52	52	77	66	116	141	136	123	101	76	71	60	(15)	
	PrecMax	1296	114	117	193	150	203	236	272	184	236	161	141	122	(16)	
	PrecMin	773	8	8	29	5	42	62	27	36	44	12	0	9	(17)	
	PrecStd	137	32	29	40	32	43	45	63	39	43	36	30	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	16.2	19.2	24.3	27.6	31.2	32.1	33.0	27.2	23.4	18.8	14.7	(19)	
		MCWB	7.7	8.6	10.8	14.4	17.8	20.2	20.9	20.6	18.2	15.0	11.9	8.3	(20)	
	2%	DB	11.3	13.3	16.5	21.6	25.2	28.6	29.7	29.8	24.8	20.7	16.6	12.1	(21)	
		MCWB	6.7	7.4	9.6	13.0	16.5	19.7	20.1	19.9	17.4	14.1	11.2	7.5	(22)	
	5%	DB	8.9	11.1	14.1	19.3	23.1	26.4	27.8	27.6	22.8	18.6	14.5	9.7	(23)	
		MCWB	5.3	6.3	8.3	11.8	15.6	18.4	19.1	19.2	16.2	13.2	10.0	5.9	(24)	
	10%	DB	6.8	8.8	11.9	17.1	20.8	24.2	25.8	25.3	20.8	16.6	12.4	7.6	(25)	
		MCWB	3.8	5.0	7.4	10.7	14.3	17.4	18.5	18.1	15.3	12.2	8.7	4.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.1	11.4	15.1	18.9	21.7	22.1	22.0	19.1	16.2	12.9	9.2	(27)	
		MCDB	12.4	15.0	17.6	22.8	25.3	28.0	28.3	28.1	24.9	21.2	17.6	13.2	(28)	
	2%	WB	7.0	7.6	10.0	13.6	17.4	20.3	21.0	20.8	18.0	14.9	11.6	7.8	(29)	
		MCDB	10.5	12.5	15.5	20.4	23.3	26.9	27.8	27.6	23.3	19.2	15.7	11.2	(30)	
	5%	WB	5.5	6.5	8.8	12.3	16.1	19.3	20.0	19.8	17.0	13.8	10.3	6.4	(31)	
		MCDB	8.6	10.6	13.2	18.2	21.8	25.2	26.2	26.0	21.7	17.8	14.0	9.6	(32)	
	10%	WB	4.1	5.2	7.7	11.3	14.9	18.1	19.1	18.9	15.9	12.7	9.0	4.6	(33)	
		MCDB	6.5	8.7	11.5	16.2	20.0	23.0	24.6	24.4	19.9	16.1	11.9	7.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	7.9	8.8	10.4	10.4	10.4	10.6	11.1	9.6	9.8	7.4	7.0	(35)	
		MCDBR	10.0	12.3	13.7	15.3	15.1	15.0	14.7	15.3	13.7	13.4	11.1	10.4	(36)	
	5% WB	MCWBR	6.1	7.0	7.5	7.5	7.2	6.7	6.3	6.3	6.8	7.3	6.5	6.4	(37)	
		MCWBR	9.5	11.3	12.5	13.9	13.8	13.8	13.4	14.0	12.4	12.3	9.7	9.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.300	0.327	0.367	0.411	0.412	0.419	0.423	0.422	0.393	0.361	0.331	0.299	(40)	
		taud	2.401	2.345	2.281	2.207	2.252	2.270	2.260	2.277	2.329	2.394	2.431	2.440	(41)	
	Ebn at Noon		779	830	845	839	852	846	836	820	809	778	731	735	(42)	
		Edh at Noon	68	89	112	133	132	130	130	123	106	85	67	59	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.12	1.97	3.06	4.28	5.00	5.45	5.37	4.79	3.45	2.27	1.23	0.90	(44)	
	RadStd		0.12	0.25	0.36	0.45	0.55	0.42	0.48	0.51	0.43	0.23	0.15	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (96 neighbors)		+0.55	N/A	N/A	+0.85	+0.45	+0.40	-114	-151	+88	+49

Nomenclature: See separate page