

PUCHBERG, Austria

WMO: 113820

Lat: 47.790N

Lon: 15.907E

Elev: 1921

StdP: 13.70

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 6.1	(c) 11.2	(d) 2.8	(e) 6.8	(f) 8.3	(g) 7.4	(h) 8.6	(i) 13.6	(j) 18.8	(k) 39.3	(l) 16.6	(m) 38.9	(n) 1.6	(o) 280	(p) 0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.6	(c) 85.1	(d) 68.3	(e) 81.6	(f) 66.8	(g) 78.4	(h) 65.0	(i) 69.7	(j) 82.0	(k) 67.9	(l) 79.3	(m) 66.2	(n) 76.7	(o) 4.1	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	101.4	75.6	63.7	94.8	73.7	62.0	89.3	71.7	34.9	82.2	33.3	79.5	31.9	76.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a) 15.0	(b) 12.6	(c) 10.7	(d) 10.7	(e) 0.0	(f) 90.8	(g) 5.8	(h) 3.9	(i) -4.1	(j) 93.5	(k) -7.5	(l) 95.8	(m) -10.7	(n) 98.0	(o) -14.9	(p) 100.8	
(a) 15.0	(b) 12.6	(c) 10.7	(d) 10.7	(e) -0.5	(f) 72.7	(g) 5.6	(h) 1.7	(i) -4.5	(j) 74.0	(k) -7.8	(l) 75.0	(m) -11.0	(n) 76.0	(o) -15.1	(p) 77.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	30.0	33.0	38.9	47.0	54.7	61.4	64.7	63.6	55.6	48.3	40.2	32.3	(6)
	DBStd	14.04	9.18	8.94	7.83	7.06	6.23	6.08	5.23	5.26	5.89	6.78	7.78	8.76	(7)
	HDD50	2600	620	478	350	135	25	2	0	1	16	115	307	551	(8)
	HDD65	6512	1084	896	809	540	322	139	70	89	285	518	745	1015	(9)
	CDD50	1707	1	2	6	45	172	344	456	421	185	62	12	1	(10)
	CDD65	144	0	0	0	0	4	31	61	45	3	0	0	0	(11)
	CDH74	1907	0	0	0	12	82	424	729	601	56	3	0	0	(12)
	CDH80	469	0	0	0	0	7	100	189	168	5	0	0	0	(13)
	WSAvg	3.8	4.8	4.7	4.5	3.9	3.7	3.3	3.6	3.0	3.1	3.2	3.9	4.0	(14)
	PrecAvg	39.3	2.2	2.2	2.9	2.7	4.1	4.7	4.8	4.3	3.5	2.6	2.7	2.5	(15)
(16) Precipitation	PrecMax	48.5	5.5	5.1	6.5	5.9	8.9	9.3	12.3	7.9	9.8	5.9	5.7	5.3	(16)
	PrecMin	27.2	0.2	0.3	0.7	0.5	1.3	2.0	0.9	1.7	0.7	0.5	0.1	0.6	(17)
	PrecStd	5.6	1.4	1.3	1.6	1.3	1.9	1.9	2.5	1.7	2.0	1.3	1.2	1.1	(18)
	PrecStd	5.6	1.4	1.3	1.6	1.3	1.9	1.9	2.5	1.7	2.0	1.3	1.2	1.1	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.0	59.8	65.4	75.6	80.0	87.2	88.9	89.8	79.2	72.7	64.4	56.5	(19)
		MCWB	45.8	46.4	51.7	58.6	63.2	69.0	69.5	68.5	64.4	58.6	52.7	46.1	(20)
	2%	DB	51.6	54.4	60.2	70.0	76.3	82.9	84.9	84.7	74.9	67.6	60.8	52.5	(21)
		MCWB	44.1	44.5	48.9	55.8	62.0	67.8	68.6	67.7	62.9	56.8	51.5	44.6	(22)
	5%	DB	47.5	50.5	56.0	65.4	72.5	78.9	81.4	80.6	71.4	64.3	57.2	48.9	(23)
		MCWB	41.7	43.1	46.8	53.3	60.1	65.5	67.0	66.5	60.6	55.1	49.4	42.9	(24)
	10%	DB	43.2	46.6	52.3	61.5	68.8	75.2	78.0	76.7	67.9	60.5	53.0	44.7	(25)
		MCWB	38.7	40.9	45.1	51.2	57.8	63.4	65.3	64.5	59.0	53.3	47.5	40.1	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.7	47.7	52.6	59.5	66.0	71.5	72.0	71.8	66.4	60.5	54.8	47.8	(27)
		MCDB	54.0	56.8	63.5	73.3	76.6	84.3	83.8	84.3	75.5	68.8	61.9	54.0	(28)
	2%	WB	44.7	45.4	49.6	56.8	63.1	68.6	69.9	69.1	64.0	58.0	52.3	45.6	(29)
		MCDB	50.5	53.0	58.3	68.5	73.7	80.5	82.1	81.3	73.0	65.7	59.5	51.0	(30)
	5%	WB	41.9	43.3	47.6	54.1	60.9	66.6	68.0	67.2	61.8	55.9	50.0	43.1	(31)
		MCDB	47.2	50.2	54.9	63.6	70.8	77.1	79.3	78.5	69.9	62.9	56.0	48.5	(32)
	10%	WB	39.0	40.9	45.6	52.0	58.7	64.3	66.1	65.3	59.7	54.1	47.7	40.2	(33)
		MCDB	42.8	46.5	51.8	60.6	67.6	73.8	76.6	75.5	66.7	59.9	52.6	44.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	14.5	16.3	19.8	19.1	19.2	19.6	20.8	17.7	18.0	14.0	13.1	(35)
		MCDBR	18.4	21.6	25.7	29.4	28.0	28.3	28.4	29.6	25.6	25.2	21.3	20.1	(36)
		MCWBR	12.4	13.6	15.7	16.9	15.3	14.7	13.7	14.3	14.5	15.3	13.6	13.6	(37)
	5% WB	MCDBR	17.3	19.6	24.1	26.4	26.1	26.7	25.9	26.8	23.5	23.1	18.7	19.0	(38)
		MCWBR	12.1	12.9	15.2	15.6	14.8	14.4	13.2	14.0	14.0	14.6	12.4	13.4	(39)
(40) Clear-Sky Solar Irradiance	taub		0.295	0.320	0.359	0.401	0.402	0.408	0.412	0.411	0.384	0.353	0.325	0.294	(40)
	taud		2.414	2.367	2.307	2.235	2.276	2.291	2.278	2.296	2.348	2.412	2.447	2.451	(41)
	Ebn at Noon		250	266	271	269	273	272	268	263	260	250	235	235	(42)
	Edh at Noon		21	28	35	41	41	40	40	38	33	26	21	18	(43)
(44) All-Sky Solar Radiation	RadAvg		348	617	967	1368	1600	1745	1712	1527	1098	712	383	279	(44)
	RadStd		39	80	115	143	175	134	153	161	136	72	45	36	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (94 neighbors)	+0.99	N/A	N/A	N/A	+1.49	+0.79	+0.72	-211	-270	+151	+81

Nomenclature: See separate page