

PUCHBERG, Austria

WMO: 113820

Lat: 47.790N

Lon: 15.907E

Elev: 586

StdP: 94.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.4	-11.6	-16.2	1.0	-13.2	-13.7	1.2	-10.2	8.4	4.1	7.4	3.8	0.7	280	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	29.5	20.1	27.6	19.3	25.8	18.4	21.0	27.8	19.9	26.3	19.0	24.8	1.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	14.5	24.2	17.6	13.5	23.1	16.7	12.8	22.1	63.2	27.9	59.6	26.4	56.3	24.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	5.6	4.8	-17.8	32.6	3.2	2.1	-20.1	34.2	-21.9	35.4	-23.7	36.6	-26.1	38.2		
(5)			-18.0	22.6	3.1	1.0	-20.3	23.3	-22.1	23.9	-23.9	24.4	-26.2	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-1.1	0.5	3.8	8.3	12.6	16.3	18.2	17.5	13.1	9.1	4.5	0.1		
	DBStd	7.80	5.10	4.97	4.35	3.92	3.46	3.38	2.91	2.92	3.27	3.77	4.32	4.87		
	HDD10.0	1444	344	266	194	75	14	1	0	1	9	64	171	306		
	HDD18.3	3618	602	498	449	300	179	77	39	49	158	288	414	564		
	CDD10.0	948	1	1	3	25	96	191	253	234	103	34	7	1		
	CDD18.3	80	0	0	0	0	2	17	34	25	2	0	0	0		
	CDH23.3	1059	0	0	0	7	46	236	405	334	31	2	0	0		
	CDH26.7	261	0	0	0	0	4	56	105	93	3	0	0	0		
(14) Wind	WSAvg	1.7	2.1	2.1	2.0	1.7	1.6	1.5	1.6	1.3	1.4	1.4	1.8	1.8		
(15) Precipitation	PrecAvg	997	57	57	74	69	104	120	122	110	89	66	69	63		
	PrecMax	1231	140	130	166	150	225	237	313	200	250	151	144	135		
	PrecMin	691	5	8	17	13	34	51	24	42	19	12	2	15		
	PrecStd	143	35	34	41	32	48	47	64	44	50	34	31	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	15.4	18.6	24.2	26.7	30.7	31.6	32.1	26.2	22.6	18.0	13.6		
		MCWB	7.6	8.0	10.9	14.8	17.3	20.6	20.8	20.3	18.0	14.8	11.5	7.8		
	2%	DB	10.9	12.4	15.7	21.1	24.6	28.3	29.4	29.3	23.8	19.8	16.0	11.4		
		MCWB	6.7	6.9	9.4	13.2	16.7	19.9	20.4	19.8	17.2	13.8	10.8	7.0		
	5%	DB	8.6	10.3	13.4	18.6	22.5	26.1	27.5	27.0	21.9	17.9	14.0	9.4		
		MCWB	5.4	6.2	8.2	11.8	15.6	18.6	19.4	19.2	15.9	12.8	9.7	6.1		
	10%	DB	6.2	8.1	11.3	16.4	20.4	24.0	25.6	24.8	19.9	15.9	11.7	7.1		
		MCWB	3.7	4.9	7.3	10.7	14.4	17.5	18.5	18.1	15.0	11.8	8.6	4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	8.7	11.4	15.3	18.9	21.9	22.2	22.1	19.1	15.8	12.7	8.8		
		MCDB	12.2	13.8	17.5	23.0	24.8	29.1	28.8	29.0	24.1	20.5	16.6	12.2		
	2%	WB	7.0	7.4	9.8	13.8	17.3	20.3	21.0	20.6	17.8	14.5	11.3	7.6		
		MCDB	10.3	11.7	14.6	20.3	23.2	26.9	27.8	27.4	22.8	18.7	15.3	10.6		
	5%	WB	5.5	6.3	8.6	12.3	16.1	19.2	20.0	19.6	16.6	13.3	10.0	6.2		
		MCDB	8.4	10.1	12.7	17.6	21.5	25.1	26.3	25.9	21.1	17.1	13.3	9.1		
	10%	WB	3.9	4.9	7.5	11.1	14.8	18.0	18.9	18.5	15.4	12.3	8.7	4.5		
		MCDB	6.0	8.1	11.0	15.9	19.8	23.2	24.8	24.2	19.3	15.5	11.4	7.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	8.1	9.0	11.0	10.6	10.7	10.9	11.5	9.8	10.0	7.8	7.3		
		MCDBR	10.2	12.0	14.3	16.3	15.6	15.7	15.8	16.5	14.2	14.0	11.8	11.2		
		MCWBR	6.9	7.6	8.7	9.4	8.5	8.1	7.6	8.0	8.0	8.5	7.6	7.5		
		MCDBR	9.6	10.9	13.4	14.7	14.5	14.8	14.4	14.9	13.0	12.8	10.4	10.5		
	5% WB	MCWBR	6.7	7.2	8.4	8.7	8.2	8.0	7.4	7.8	7.8	8.1	6.9	7.5		
(40) Clear-Sky Solar Irradiance	taub		0.295	0.320	0.359	0.401	0.402	0.408	0.412	0.411	0.384	0.353	0.325	0.294		
	taud		2.414	2.367	2.307	2.235	2.276	2.291	2.278	2.296	2.348	2.412	2.447	2.451		
	Ebn at Noon		787	838	855	849	862	856	846	830	819	788	740	742		
	Edh at Noon		67	87	109	129	128	127	127	120	104	83	66	58		
(44) All-Sky Solar Radiation	RadAvg		1.10	1.95	3.05	4.31	5.04	5.50	5.40	4.82	3.46	2.25	1.21	0.88		
	RadStd		0.12	0.25	0.36	0.45	0.55	0.42	0.48	0.51	0.43	0.23	0.14	0.11		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (94 neighbors)	+0.55	N/A	N/A	+0.83	+0.44	+0.40	-117	-150	+84	+45

Nomenclature: See separate page