

HIRSCHENKOGEL, Austria

WMO: 113840

Lat: 47.623N

Lon: 15.833E

Elev: 1320

StdP: 86.44

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-12.0	-18.3	0.9	-9.8	-15.7	1.1	-9.8	11.7	-7.9	10.4	-8.2	3.4	240	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	23.0	16.4	21.4	15.9	19.8	15.1	17.5	21.4	16.5	20.3	15.6	19.1	2.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	13.4	19.7	15.0	12.5	18.7	14.1	11.8	17.7	54.7	21.6	51.5	20.5	48.6	19.2	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 9.2	7.5	6.1		-15.2	25.8	2.4	1.5	-16.9	26.9	-18.4	27.7	-19.7	28.6	-21.4		
(5)				-15.6	19.1	2.2	0.8	-17.2	19.6	-18.4	20.1	-19.7	20.6	-21.3	21.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-3.7	-2.9	-0.2	4.2	8.6	12.3	14.2	14.1	9.3	6.1	1.4	-2.3
	DBStd	7.65	4.54	4.91	4.64	4.35	3.99	4.02	3.59	3.48	3.80	4.34	4.54	4.51
	HDD10.0	2223	426	362	317	178	75	22	7	6	58	134	259	380
	HDD18.3	4834	684	595	576	423	302	182	135	137	271	381	509	638
	CDD10.0	445	0	0	0	4	31	92	136	133	37	12	1	0
	CDD18.3	16	0	0	0	0	0	3	6	7	0	0	0	0
	CDH23.3	32	0	0	0	0	0	6	11	15	1	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	2.6	2.9	2.8	2.8	2.6	2.7	2.5	2.4	2.2	2.4	2.4	2.5	2.7
Precipitation	PrecAvg	1071	52	52	77	66	116	141	136	123	101	76	71	60
	PrecMax	1296	114	117	193	150	203	236	272	184	236	161	141	122
	PrecMin	773	8	8	29	5	42	62	27	36	44	12	0	9
	PrecStd	137	32	29	40	32	43	45	63	39	43	36	30	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	9.2	11.4	16.5	20.4	24.1	24.7	25.1	19.7	17.2	12.7	8.1
		MCWB	3.1	3.1	5.7	10.2	14.1	17.1	17.5	16.9	14.7	11.4	7.3	2.4
	2%	DB	5.9	6.9	9.2	13.8	18.5	21.9	22.8	22.9	17.5	15.0	10.4	6.3
		MCWB	1.9	2.2	4.7	8.6	13.0	15.9	16.7	16.2	13.5	10.6	6.8	2.6
	5%	DB	4.0	5.3	7.4	11.8	16.2	19.9	21.1	21.1	16.0	13.2	8.9	4.9
		MCWB	1.4	2.0	4.0	7.6	11.7	15.1	16.0	15.7	12.8	9.6	6.1	1.8
	10%	DB	2.4	3.5	5.8	10.0	14.5	18.2	19.6	19.4	14.5	11.6	7.5	3.6
		MCWB	0.3	0.9	2.9	6.5	10.7	14.2	15.3	15.1	12.0	9.0	5.4	1.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.4	4.8	6.4	10.6	15.2	18.3	18.7	18.2	15.6	12.5	9.3	4.7
		MCDB	6.6	7.1	9.9	15.5	19.5	22.6	22.9	22.2	18.8	15.1	11.0	6.0
	2%	WB	2.9	3.3	5.3	9.1	13.3	16.7	17.6	17.1	14.2	11.3	7.8	3.6
		MCDB	4.5	5.9	8.2	12.9	17.3	20.3	21.4	21.4	16.7	13.8	9.5	5.0
	5%	WB	1.7	2.2	4.3	7.9	12.1	15.5	16.6	16.3	13.2	10.2	6.6	2.6
		MCDB	3.5	4.4	6.8	11.1	15.6	19.2	20.2	20.2	15.5	12.2	8.2	4.2
	10%	WB	0.5	1.1	3.4	6.8	11.0	14.4	15.6	15.4	12.3	9.3	5.6	1.5
		MCDB	2.2	3.3	5.5	9.5	14.1	17.9	19.0	18.7	14.2	11.1	7.1	3.2
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.5	5.0	5.7	6.2	6.2	6.3	6.0	5.1	5.0	4.0	3.9
		MCDBR	5.6	6.2	7.1	7.9	8.6	8.3	8.5	8.3	7.1	6.6	5.3	5.6
		MCWBR	3.6	3.8	4.3	4.5	4.9	4.7	4.4	4.3	4.6	3.9	3.4	3.5
	5% WB	MCDBR	5.0	5.7	6.4	7.4	8.2	7.8	7.9	7.6	6.6	6.0	4.6	4.8
		MCWBR	3.9	3.9	4.2	4.4	5.0	4.8	4.5	4.5	4.5	4.0	3.6	3.6
Clear-Sky Solar Irradiance	taub	0.261	0.283	0.315	0.350	0.352	0.358	0.361	0.360	0.337	0.313	0.290	0.262	
	taud	2.466	2.441	2.412	2.363	2.387	2.391	2.375	2.392	2.442	2.501	2.527	2.504	
	Ebn at Noon	843	893	908	903	911	904	895	882	872	843	799	801	
	Edh at Noon	63	80	97	113	115	115	115	109	94	76	60	54	
All-Sky Solar Radiation	RadAvg	1.13	1.99	3.08	4.27	4.99	5.44	5.37	4.79	3.45	2.29	1.25	0.92	
	RadStd	0.12	0.25	0.36	0.44	0.55	0.41	0.47	0.52	0.43	0.22	0.15	0.12	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (95 neighbors)		+0.56	N/A	N/A	+0.86	+0.45	+0.40	-114	-152	+89

Nomenclature: See separate page