

ST POELTEN LANDHAUS, Austria

WMO: 113890

Lat: 48.200N

Lon: 15.631E

Elev: 885

StdP: 14.23

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	17.0	7.3	8.3	13.8	12.0	10.5	18.5	25.0	39.0	22.8	39.1	4.6	180	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.7	88.4	70.3	84.8	68.5	81.7	67.1	71.4	85.3	69.7	82.4	68.1	79.6	6.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	101.1	77.8	65.2	96.2	75.7	63.8	91.6	73.9	35.7	85.4	34.2	82.5	32.9	79.7	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	18.0	15.8	7.2	93.8	7.0	3.4	2.2	96.3	-1.9	98.3	-5.8	100.2	-10.9	102.7		
(5)			6.5	74.7	6.8	1.6	1.6	75.8	-2.3	76.8	-6.2	77.7	-11.1	78.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.4	31.0	34.6	42.0	51.0	58.9	65.3	68.3	68.5	59.3	50.2	41.1	33.3		
	DBStd	14.99	7.72	8.46	7.56	7.54	6.49	6.63	5.90	6.00	6.16	6.91	7.01	7.64		
	HDD50	2253	591	433	261	78	6	1	0	0	3	85	277	518		
	HDD65	5739	1055	851	712	422	209	76	34	32	189	460	716	983		
	CDD50	2392	0	1	15	108	282	460	568	573	283	90	12	0		
	CDD65	403	0	0	0	2	19	86	138	140	18	0	0	0		
	CDH74	3461	0	0	0	41	193	773	1145	1171	134	4	0	0		
	CDH80	1059	0	0	0	4	26	238	375	396	20	0	0	0		
(14) Wind	WSAvg	6.8	7.8	7.7	7.6	6.8	6.8	6.4	7.0	5.9	6.0	6.0	6.6	7.2		
(15) Precipitation	PrecAvg	27.2	1.3	1.3	1.8	2.1	2.9	3.4	3.6	3.3	2.3	1.6	2.0	1.7		
	PrecMax	36.2	2.6	3.6	4.1	6.0	6.7	9.0	8.5	11.4	5.8	6.3	4.7	4.5		
	PrecMin	18.2	0.0	0.2	0.4	0.4	0.6	1.4	0.8	0.7	0.4	0.0	0.4	0.2		
	PrecStd	4.4	0.7	0.8	0.9	1.4	1.4	1.6	1.7	1.9	1.3	1.1	0.9	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	57.2	67.4	78.8	83.3	90.8	92.8	93.5	82.6	72.7	64.1	53.0		
		MCWB	46.5	48.0	52.7	60.0	65.9	70.9	71.1	69.7	66.7	60.5	54.3	47.5		
	2%	DB	48.2	53.2	62.1	73.4	79.2	86.5	88.0	88.1	77.9	67.0	58.4	49.2		
		MCWB	43.7	46.4	50.9	57.9	64.3	70.2	70.1	70.1	64.5	58.2	51.8	45.4		
	5%	DB	44.6	49.7	57.6	68.6	75.6	82.3	84.1	84.3	73.8	63.3	54.5	45.7		
		MCWB	41.2	44.1	48.5	55.7	62.3	67.7	68.0	68.6	62.9	56.9	50.1	42.7		
	10%	DB	41.4	46.1	53.6	64.7	72.0	78.5	80.6	80.7	70.1	59.9	50.8	42.8		
		MCWB	38.8	41.9	46.9	53.6	60.2	65.7	66.9	67.2	60.8	55.2	47.6	40.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	49.3	54.1	61.3	68.2	73.7	73.3	73.2	68.0	61.9	55.4	48.0		
		MCDB	51.8	54.8	64.3	76.5	80.5	87.3	88.3	88.2	78.7	69.6	62.2	51.7		
	2%	WB	44.2	46.8	51.5	58.7	65.3	70.9	71.2	70.9	65.5	59.5	52.7	45.7		
		MCDB	47.8	52.4	60.4	71.4	76.5	83.9	85.0	84.9	76.3	65.5	57.6	48.9		
	5%	WB	41.5	44.5	49.4	56.5	63.2	68.7	69.3	69.3	63.7	57.6	50.2	42.8		
		MCDB	44.2	49.1	56.0	67.2	73.4	80.4	81.4	82.0	72.1	62.0	54.2	45.3		
	10%	WB	38.9	42.2	47.4	54.3	61.3	66.6	67.7	67.7	61.9	55.7	47.7	40.4		
		MCDB	41.2	46.0	53.1	63.2	70.2	76.6	78.4	78.9	68.5	59.7	50.8	42.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	10.6	14.4	17.4	17.5	17.7	17.7	18.4	15.4	12.6	8.8	7.4		
		MCDBR	11.4	16.5	23.2	26.0	25.1	25.1	25.4	25.4	22.5	18.1	14.8	11.2		
	5% WB	MCWBR	8.4	10.9	13.2	12.7	11.9	10.9	9.9	10.0	10.6	10.3	9.5	8.5		
		MCWBR	10.9	15.2	20.6	24.1	23.2	23.9	22.8	23.6	20.7	16.7	13.8	11.2		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.329	0.370	0.412	0.414	0.420	0.426	0.423	0.395	0.363	0.335	0.305		
	taud		2.397	2.349	2.291	2.224	2.261	2.279	2.263	2.288	2.336	2.405	2.436	2.437		
	Ebn at Noon		243	261	266	266	270	268	264	259	255	245	228	228		
	Edh at Noon		22	28	35	41	41	41	41	38	33	27	21	18		
(44) All-Sky Solar Radiation	RadAvg		331	608	947	1359	1576	1722	1676	1496	1072	682	357	265		
	RadStd		46	79	117	156	180	145	159	155	137	75	41	31		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	+1.28	N/A	N/A	+2.20	+0.92	+0.67	-338	-464	+279	+166
Regional (98 neighbors)	+0.95	N/A	N/A	N/A	+0.76	+0.65	-216	-270	+140	+65

Nomenclature: See separate page