

MARIANSKE LAZNE, Czech Republic

WMO: 114180

Lat: 49.9906N

Lon: 12.6960E

Elev: 2283

StdP: 13.52

Time Zone: 1.00 (EUC)

Period: 90-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	10.9	1.4	6.4	8.6	5.7	8.0	11.9	18.0	35.8	16.1	31.9	1.4	60	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.1	82.4	64.9	78.8	63.4	75.4	61.6	66.3	78.5	64.7	75.6	63.2	72.9	5.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	91.1	70.7	60.7	86.2	68.5	59.3	82.0	67.2	32.2	78.8	30.9	76.1	29.7	72.9	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.5	13.4	11.7	DB	-1.0	87.9	5.3	3.1	-4.8	90.1	-8.0	91.9	-11.0	93.7	-14.8	95.9	(4)
			WB	-0.6	69.9	5.7	2.5	-4.7	71.7	-8.0	73.2	-11.2	74.6	-15.3	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.5	28.9	30.0	37.1	43.0	52.4	57.0	61.2	61.8	52.6	44.2	35.5	29.4
	DBStd	13.70	8.18	8.91	6.52	7.18	6.33	5.98	5.85	6.13	5.17	7.19	6.44	8.22
	HDD50	3214	653	561	402	231	49	7	0	2	29	206	436	638
	HDD65	7561	1118	981	865	661	392	251	149	136	374	645	886	1103
	CDD50	1209	0	0	2	21	123	216	348	367	106	26	0	0
	CDD65	80	0	0	0	0	1	10	32	36	1	0	0	0
	CDH74	1001	0	0	0	2	27	138	392	435	7	0	0	0
	CDH80	222	0	0	0	0	0	23	99	100	0	0	0	0
Wind	WSAvg	4.4	4.5	4.3	5.0	4.5	5.0	4.1	4.2	3.9	4.0	4.4	4.1	4.4
Precipitation	PrecAvg	30.5	2.4	2.0	2.1	1.9	2.7	3.1	3.5	2.9	2.6	2.2	2.6	2.5
	PrecMax	42.2	5.1	4.5	5.2	4.4	6.8	4.8	5.4	7.3	5.6	7.0	5.0	5.9
	PrecMin	21.2	0.4	0.4	0.4	0.8	0.9	1.1	1.3	1.0	0.9	0.8	0.0	1.0
	PrecStd	4.4	1.1	1.1	1.3	0.9	1.4	1.0	1.2	1.4	1.1	1.2	1.3	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	55.3	60.7	72.3	77.2	83.6	87.5	87.5	75.2	68.4	52.2	48.2
		MCWB	45.7	47.4	48.8	55.1	60.6	66.3	65.5	66.1	60.7	57.6	48.3	46.1
	2%	DB	45.8	49.3	56.0	66.6	73.4	78.3	82.6	82.5	70.3	62.8	49.5	46.0
		MCWB	43.3	44.1	46.9	53.5	58.4	63.0	64.7	64.8	60.1	55.2	47.1	44.1
	5%	DB	42.9	45.7	51.4	61.1	69.7	73.9	78.4	78.9	66.3	58.6	47.3	43.1
		MCWB	40.7	42.2	45.1	50.4	56.5	61.2	63.4	63.7	57.4	53.3	45.3	41.6
	10%	DB	40.1	42.3	47.7	56.8	66.2	70.4	74.5	75.3	62.5	55.4	44.6	39.9
		MCWB	38.3	39.5	43.3	47.8	55.0	59.3	61.3	62.2	55.1	51.4	43.0	38.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	47.8	50.6	56.4	62.5	67.5	68.3	69.5	63.1	58.9	49.4	46.8
		MCDB	48.3	53.7	58.4	69.5	73.9	78.6	81.9	82.6	71.2	65.8	51.1	47.8
	2%	WB	43.6	45.0	48.0	53.6	60.0	64.9	66.1	66.5	60.8	56.2	47.8	44.2
		MCDB	45.6	48.6	53.9	64.6	70.0	75.7	78.7	78.4	67.7	61.2	49.5	45.8
	5%	WB	41.1	42.5	45.9	51.1	57.8	62.7	64.6	64.7	58.5	53.8	45.3	41.8
		MCDB	42.5	45.5	50.2	60.0	67.5	71.6	75.1	75.9	64.4	57.4	46.9	43.1
	10%	WB	38.5	39.6	43.8	48.7	55.8	60.3	62.9	63.1	56.6	51.8	43.1	38.5
		MCDB	40.1	42.2	47.6	54.8	64.6	68.4	72.5	72.9	61.1	55.1	44.6	39.7
Mean Daily Temperature Range	5% DB	MDBR	9.0	13.5	14.1	17.9	19.3	18.2	19.0	20.1	16.6	13.9	8.2	7.9
		MCDBR	12.0	19.4	23.1	26.7	25.8	26.9	27.4	27.7	23.5	21.0	12.4	10.0
		MCWBR	10.2	13.9	14.4	15.0	13.0	13.3	12.2	11.9	13.5	13.8	10.2	9.1
	5% WB	MCDBR	11.1	18.4	20.8	24.3	23.3	23.6	23.2	24.3	20.8	18.3	11.3	9.3
		MCWBR	10.3	13.7	13.8	14.5	12.6	12.4	11.5	11.9	12.7	12.7	9.8	8.9
Clear-Sky Solar Irradiance	taub	0.281	0.302	0.340	0.375	0.378	0.379	0.390	0.384	0.356	0.332	0.307	0.279	
	taud	2.421	2.390	2.365	2.312	2.329	2.345	2.313	2.350	2.410	2.471	2.494	2.448	
	Ebn at Noon	246	267	275	275	279	279	273	270	266	253	234	230	
	Edh at Noon	19	26	32	37	38	38	39	36	30	24	18	16	
All-Sky Solar Radiation	RadAvg	267	534	848	1306	1546	1687	1608	1411	1007	603	288	206	
	RadStd	49	78	119	169	184	145	168	140	139	75	34	26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (53 neighbors)	+0.70	N/A	N/A	N/A	+0.59	+0.65	N/A	N/A	+101	+40

Nomenclature: See separate page