

MARIANSKE LAZNE, Czech Republic

WMO: 114180

Lat: 49.9906N

Lon: 12.6960E

Elev: 696

StdP: 93.24

Time Zone: 1.00 (EUC)

Period: 90-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-11.7	-17.0	0.9	-13.0	-14.6	1.1	-11.2	8.0	2.1	7.2	-0.1	0.6	60	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	28.0	18.3	26.0	17.4	24.1	16.5	19.1	25.8	18.2	24.2	17.3	22.7	2.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.8	13.0	21.5	15.9	12.3	20.3	15.2	11.7	19.5	57.0	26.0	54.0	24.5	51.2	22.7	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
6.9	6.0	5.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-18.3	31.1	3.0	1.7	-20.5	32.3	-22.2	33.3	-23.9	34.3	-26.0	35.5
			-18.1	21.0	3.1	1.4	-20.4	22.0	-22.2	22.9	-24.0	23.7	-26.3	24.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-1.7	-1.1	2.8	6.1	11.3	13.9	16.2	16.5	11.4	6.8	1.9	-1.4	(6)
(7)		DBStd	7.61	4.55	4.95	3.62	3.99	3.51	3.32	3.25	3.41	2.87	3.99	3.58	4.56	(7)
(8)		HDD10.0	1786	363	312	223	128	27	4	0	1	16	114	242	354	(8)
(9)		HDD18.3	4201	621	545	481	367	218	139	83	76	208	358	492	613	(9)
(10)		CDD10.0	672	0	0	1	12	68	120	193	204	59	14	0	0	(10)
(11)		CDD18.3	44	0	0	0	0	1	6	18	20	1	0	0	0	(11)
(12)		CDH23.3	556	0	0	0	1	15	77	218	242	4	0	0	0	(12)
(13)		CDH26.7	123	0	0	0	0	0	13	55	56	0	0	0	0	(13)
(14)	Wind	WSAvg	2.0	2.0	1.9	2.2	2.0	2.2	1.8	1.9	1.8	2.0	1.8	2.0	(14)	
(15)	Precipitation	PrecAvg	775	60	50	54	47	68	80	90	74	65	57	65	64	(15)
(16)		PrecMax	1072	129	114	131	111	173	123	138	186	142	178	128	150	(16)
(17)		PrecMin	539	10	10	11	20	24	27	32	26	22	21	1	25	(17)
(18)		PrecStd	113	29	27	33	23	35	25	30	36	28	31	33	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	12.9	15.9	22.4	25.1	28.6	30.8	30.8	24.0	20.2	11.2	9.0	(19)
(20)			MCWB	7.6	8.5	9.3	12.8	15.9	19.1	18.6	18.9	15.9	14.2	9.1	7.8	(20)
(21)		2%	DB	7.6	9.6	13.3	19.2	23.0	25.7	28.1	28.1	21.3	17.1	9.7	7.8	(21)
(22)			MCWB	6.3	6.7	8.3	12.0	14.7	17.2	18.2	18.2	15.6	12.9	8.4	6.7	(22)
(23)		5%	DB	6.1	7.6	10.8	16.2	20.9	23.3	25.8	26.1	19.0	14.8	8.5	6.2	(23)
(24)			MCWB	4.8	5.6	7.3	10.2	13.6	16.2	17.4	17.6	14.1	11.8	7.4	5.3	(24)
(25)		10%	DB	4.5	5.7	8.7	13.8	19.0	21.3	23.6	24.0	17.0	13.0	7.0	4.4	(25)
(26)			MCWB	3.5	4.2	6.3	8.8	12.8	15.2	16.3	16.8	12.9	10.8	6.1	3.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	8.8	10.4	13.5	17.0	19.7	20.1	20.8	17.3	14.9	9.7	8.2	(27)
(28)			MCDWB	9.1	12.0	14.7	20.8	23.3	25.9	27.7	28.1	21.8	18.8	10.6	8.8	(28)
(29)		2%	WB	6.5	7.2	8.9	12.0	15.5	18.3	18.9	19.2	16.0	13.5	8.8	6.8	(29)
(30)			MCDWB	7.6	9.2	12.2	18.1	21.1	24.3	25.9	25.8	19.8	16.2	9.7	7.7	(30)
(31)		5%	WB	5.0	5.9	7.7	10.6	14.3	17.1	18.1	18.2	14.7	12.1	7.4	5.4	(31)
(32)			MCDWB	5.9	7.5	10.1	15.5	19.7	22.0	23.9	24.4	18.0	14.1	8.3	6.2	(32)
(33)		10%	WB	3.6	4.2	6.6	9.3	13.2	15.7	17.2	17.3	13.7	11.0	6.1	3.6	(33)
(34)			MCDWB	4.5	5.7	8.7	12.7	18.1	20.2	22.5	22.7	16.2	12.8	7.0	4.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	7.5	7.8	9.9	10.7	10.1	10.5	11.2	9.2	7.7	4.6	4.4	(35)
(36)			MCDBR	6.6	10.8	12.8	14.8	14.4	14.9	15.2	15.4	13.1	11.7	6.9	5.6	(36)
(37)			MCWBR	5.7	7.7	8.0	8.3	7.2	7.4	6.8	6.6	7.5	7.7	5.6	5.1	(37)
(38)		5% WB	MCDWB	6.2	10.2	11.5	13.5	12.9	13.1	12.9	13.5	11.5	10.2	6.3	5.2	(38)
(39)			MCWBR	5.7	7.6	7.6	8.0	7.0	6.9	6.4	6.6	7.0	7.1	5.4	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.302	0.340	0.375	0.378	0.379	0.390	0.384	0.356	0.332	0.307	0.279	(40)	
(41)		taud	2.421	2.390	2.365	2.312	2.329	2.345	2.313	2.350	2.410	2.471	2.494	2.448	(41)	
(42)		Ebn at Noon	775	843	866	868	879	879	862	850	838	798	738	725	(42)	
(43)		Edh at Noon	61	81	100	117	120	119	122	112	95	75	58	52	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.84	1.68	2.67	4.12	4.87	5.32	5.07	4.45	3.17	1.90	0.91	0.65	(44)	
(45)		RadStd	0.16	0.25	0.37	0.53	0.58	0.46	0.53	0.44	0.44	0.24	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)		+0.39	N/A	N/A	N/A	+0.33	+0.36	N/A	N/A	+56	+22

Nomenclature: See separate page