

PRIMDA, Czech Republic

WMO: 114230

Lat: 49.6694N

Lon: 12.6781E

Elev: 2452

StdP: 13.44

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.9	13.1	4.8	7.7	11.7	9.4	9.8	15.2	30.6	33.7	27.9	33.5	11.7	80	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	82.0	64.1	78.2	62.9	74.8	61.6	66.1	77.2	64.5	74.6	63.0	72.1	5.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	91.9	69.4	60.9	87.5	67.5	59.6	83.5	66.4	32.2	77.2	30.9	74.5	29.7	72.2	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	21.2	18.9	DB	5.9	87.3	5.2	3.8	2.2	90.0	-0.8	92.2	-3.8	94.3	-7.5	97.1	(4)
(5)			WB	5.4	69.1	5.0	1.5	1.7	70.1	-1.2	71.0	-4.0	71.9	-7.7	73.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	27.2	29.6	36.2	45.5	53.1	59.1	62.4	62.0	53.8	45.0	35.8	29.2	(6)	
	DBStd	14.58	7.79	8.15	7.82	8.34	7.23	7.36	7.07	6.64	6.59	7.16	6.45	7.34	(7)	
	HDD50	3246	707	572	430	182	50	9	1	2	33	189	426	645	(8)	
	HDD65	7437	1172	992	892	585	373	204	135	138	340	621	875	1110	(9)	
	CDD50	1421	0	0	3	47	147	282	386	375	147	33	1	0	(10)	
	CDD65	138	0	0	0	0	4	28	56	46	4	0	0	0	(11)	
	CDH74	918	0	0	0	2	33	195	370	298	20	0	0	0	(12)	
	CDH80	203	0	0	0	0	3	32	88	79	1	0	0	0	(13)	
(14) Wind	WSAvg	9.4	11.8	11.5	10.6	8.9	8.4	7.5	7.7	7.3	7.8	9.2	10.4	11.7	(14)	
(15) Precipitation	PrecAvg	32.2	2.6	2.2	2.2	1.9	2.8	3.4	3.5	3.0	2.6	2.4	2.6	2.8	(15)	
	PrecMax	46.4	5.7	5.3	5.0	3.9	6.6	5.7	5.6	6.8	6.1	7.9	5.2	6.7	(16)	
	PrecMin	23.3	0.5	0.4	0.6	0.7	0.7	1.1	1.0	1.0	0.9	0.7	0.1	0.9	(17)	
	PrecStd	4.9	1.3	1.3	1.3	0.9	1.4	1.1	1.3	1.4	1.2	1.4	1.3	1.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.9	51.8	60.6	71.7	77.9	83.7	87.6	87.9	76.8	66.0	53.5	46.4	(19)	
		MCWB	43.1	42.4	47.8	55.1	61.8	65.0	65.2	63.6	62.3	57.6	50.5	44.6	(20)	
	2%	DB	42.7	46.0	55.1	66.1	72.9	79.3	82.1	81.0	71.5	60.8	49.5	43.7	(21)	
		MCWB	41.1	41.0	45.5	52.4	59.3	64.1	64.0	63.3	60.0	54.5	47.3	42.4	(22)	
	5%	DB	39.9	42.7	50.3	62.4	68.9	75.5	78.1	76.6	67.4	57.3	47.1	41.2	(23)	
		MCWB	38.5	40.0	43.1	50.6	57.3	62.0	62.7	62.4	58.2	53.3	45.7	40.2	(24)	
	10%	DB	37.1	39.8	46.6	58.4	65.1	71.8	74.1	73.0	63.8	54.3	44.6	38.4	(25)	
		MCWB	36.3	37.5	42.0	48.7	55.1	60.6	61.5	61.6	56.8	51.8	43.5	37.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.4	45.0	49.6	56.7	64.3	68.2	68.0	67.6	63.9	58.4	50.2	45.2	(27)	
		MCDB	45.1	48.8	57.5	68.5	74.8	79.4	81.1	78.6	72.1	62.4	51.9	45.7	(28)	
	2%	WB	41.3	42.5	46.8	53.8	60.7	65.6	65.8	65.5	61.2	55.9	48.0	42.7	(29)	
		MCDB	42.3	44.7	52.1	63.9	70.1	76.4	77.6	75.7	68.5	59.4	49.3	43.4	(30)	
	5%	WB	38.7	40.3	44.7	51.5	58.5	63.3	64.1	63.9	59.5	53.9	45.8	40.3	(31)	
		MCDB	39.5	42.4	48.9	59.9	66.9	72.8	74.4	73.4	65.7	56.6	46.8	41.1	(32)	
	10%	WB	36.3	37.7	42.7	49.7	56.3	61.4	62.7	62.5	57.7	52.0	43.5	37.8	(33)	
		MCDB	37.1	39.6	46.0	57.1	63.4	69.8	71.7	71.1	62.7	54.1	44.6	38.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	8.8	11.4	15.0	15.4	15.6	15.3	15.1	12.4	9.7	6.6	6.1	(35)	
		MCDBR	8.7	12.5	17.6	20.1	20.4	21.1	20.3	20.8	17.8	13.9	9.8	8.5	(36)	
	5% WB	MCWBR	7.2	8.3	10.0	9.8	10.0	9.7	8.0	8.3	8.6	8.2	7.5	7.5	(37)	
		MCWBR	8.0	11.2	14.9	18.7	19.1	19.6	18.3	17.7	16.1	12.5	9.0	8.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.281	0.301	0.337	0.371	0.375	0.376	0.386	0.380	0.353	0.330	0.305	0.278	(40)	
		taud	2.428	2.395	2.374	2.322	2.336	2.352	2.321	2.357	2.412	2.473	2.498	2.455	(41)	
	Ebn at Noon		248	269	276	277	280	280	275	271	267	255	236	233	(42)	
		Edh at Noon	20	26	31	37	38	38	38	35	30	24	18	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		273	549	870	1326	1557	1705	1627	1436	1024	615	294	210	(44)	
	RadStd		50	80	120	171	183	147	166	145	140	75	33	27	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only		N/A	N/A	N/A	N/A	+0.49	N/A	N/A	+103	N/A
(47) Regional (61 neighbors)		+0.72	N/A	N/A	N/A	+0.59	N/A	N/A	+99	+40

Nomenclature: See separate page