

PRIMDA, Czech Republic

WMO: 114230

Lat: 49.6694N

Lon: 12.6781E

Elev: 747

StdP: 92.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.8	-10.5	-15.1	1.1	-11.3	-12.5	1.4	-9.3	13.7	1.0	12.5	0.9	5.2	80	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	27.8	17.8	25.6	17.1	23.8	16.4	18.9	25.1	18.0	23.7	17.2	22.3	2.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	13.1	20.8	16.1	12.5	19.7	15.4	11.9	19.1	57.0	25.1	53.9	23.6	51.3	22.4	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.5	8.4	-14.5	30.7	2.9	2.1	-16.6	32.2	-18.2	33.4	-19.9	34.6	-22.0	36.2		
(5)			-14.8	20.6	2.8	0.8	-16.8	21.2	-18.4	21.7	-20.0	22.1	-22.0	22.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-2.7	-1.3	2.3	7.5	11.7	15.1	16.9	16.7	12.1	7.2	2.1	-1.6		
	DBStd	8.10	4.33	4.53	4.34	4.63	4.02	4.09	3.93	3.69	3.66	3.98	3.59	4.08		
	HDD10.0	1803	393	318	239	101	28	5	1	1	18	105	237	358		
	HDD18.3	4132	651	551	496	325	207	113	75	77	189	345	486	617		
	CDD10.0	789	0	0	2	26	82	157	214	208	82	18	1	0		
	CDD18.3	77	0	0	0	0	2	16	31	26	2	0	0	0		
	CDH23.3	510	0	0	0	1	18	108	206	166	11	0	0	0		
	CDH26.7	113	0	0	0	0	2	18	49	44	1	0	0	0		
(14) Wind	WSAvg	4.2	5.3	5.1	4.7	4.0	3.8	3.3	3.4	3.2	3.5	4.1	4.6	5.2		
(15) Precipitation	PrecAvg	817	67	56	57	48	72	86	89	75	67	61	67	72		
	PrecMax	1179	145	135	128	99	168	144	143	172	156	200	133	169		
	PrecMin	592	12	10	15	17	18	28	25	26	22	19	3	24		
	PrecStd	125	33	32	34	24	36	28	33	35	31	36	33	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	11.0	15.9	22.0	25.5	28.7	30.9	31.1	24.9	18.9	11.9	8.0		
		MCWB	6.1	5.8	8.8	12.9	16.6	18.3	18.5	17.5	16.8	14.2	10.3	7.0		
	2%	DB	6.0	7.8	12.8	19.0	22.7	26.3	27.8	27.2	21.9	16.0	9.7	6.5		
		MCWB	5.1	5.0	7.5	11.4	15.2	17.8	17.8	17.4	15.5	12.5	8.5	5.8		
	5%	DB	4.4	5.9	10.2	16.9	20.5	24.2	25.6	24.8	19.7	14.1	8.4	5.1		
		MCWB	3.6	4.5	6.1	10.3	14.0	16.7	17.1	16.9	14.5	11.8	7.6	4.6		
	10%	DB	2.9	4.3	8.1	14.6	18.4	22.1	23.4	22.8	17.7	12.4	7.0	3.6		
		MCWB	2.4	3.1	5.6	9.3	12.8	15.9	16.4	16.5	13.8	11.0	6.4	3.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	7.2	9.8	13.7	17.9	20.1	20.0	19.8	17.7	14.7	10.1	7.3		
		MCDB	7.3	9.3	14.2	20.3	23.8	26.3	27.3	25.9	22.3	16.9	11.1	7.6		
	2%	WB	5.2	5.8	8.2	12.1	16.0	18.7	18.8	18.6	16.2	13.3	8.9	6.0		
		MCDB	5.7	7.1	11.2	17.7	21.2	24.7	25.3	24.3	20.3	15.2	9.6	6.3		
	5%	WB	3.7	4.6	7.1	10.8	14.7	17.4	17.9	17.7	15.3	12.2	7.6	4.6		
		MCDB	4.2	5.8	9.4	15.5	19.4	22.7	23.6	23.0	18.7	13.7	8.2	5.1		
	10%	WB	2.4	3.2	5.9	9.8	13.5	16.3	17.0	16.9	14.3	11.1	6.4	3.2		
		MCDB	2.9	4.2	7.8	14.0	17.4	21.0	22.0	21.7	17.1	12.3	7.0	3.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	4.9	6.4	8.3	8.5	8.7	8.5	8.4	6.9	5.4	3.6	3.4		
		MCDBR	4.8	6.9	9.8	11.2	11.3	11.7	11.3	11.6	9.9	7.7	5.4	4.7		
		MCWBR	4.0	4.6	5.6	5.4	5.5	5.4	4.4	4.6	4.8	4.6	4.1	4.2		
	5% WB	MCDBR	4.4	6.2	8.3	10.4	10.6	10.9	10.2	9.8	8.9	7.0	5.0	4.5		
		MCWBR	4.0	4.6	5.3	5.4	5.6	5.4	4.6	4.5	4.6	4.5	4.1	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.301	0.337	0.371	0.375	0.376	0.386	0.380	0.353	0.330	0.305	0.278		
	taud		2.428	2.395	2.374	2.322	2.336	2.352	2.321	2.357	2.412	2.473	2.498	2.455		
	Ebn at Noon		781	848	871	874	883	882	867	855	843	803	745	734		
	Edh at Noon		62	81	99	116	120	119	121	111	95	75	58	53		
(44) All-Sky Solar Radiation	RadAvg		0.86	1.73	2.74	4.18	4.91	5.37	5.13	4.53	3.23	1.94	0.93	0.66		
	RadStd		0.16	0.25	0.38	0.54	0.58	0.46	0.52	0.46	0.44	0.24	0.10	0.09		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.27	N/A	N/A	+57	N/A
(47)	Regional (61 neighbors)	+0.40	N/A	N/A	N/A	+0.33	+0.36	N/A	N/A	+55	+22

Nomenclature: See separate page