

PLZEN LINE, Czech Republic

WMO: 114480

Lat: 49.675N

Lon: 13.275E

Elev: 362

StdP: 97.05

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.1	-10.1	-15.9	1.0	-12.1	-12.8	1.3	-9.7	9.1	6.3	8.0	5.6	1.0	50	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	31.1	19.5	29.0	18.9	27.1	18.3	20.8	27.9	19.8	26.3	19.0	25.5	2.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	14.2	22.6	17.9	13.4	22.0	16.9	12.6	21.3	61.6	28.0	58.5	26.3	55.5	25.9	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.1	5.3	-16.0	34.2	5.3	1.7	-19.8	35.5	-22.9	36.5	-25.9	37.4	-29.8	38.7		
(5)			-16.0	22.7	4.7	1.5	-19.4	23.8	-22.2	24.6	-24.8	25.4	-28.3	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-0.5	0.1	4.3	9.2	13.2	16.9	19.2	18.3	13.8	9.3	4.3	0.5	(6)
(7)		DBStd	8.00	4.85	4.60	3.88	4.22	3.68	3.73	3.33	3.38	3.42	3.60	3.56	4.71	(7)
(8)		HDD10.0	1392	327	277	179	64	12	1	0	0	6	57	173	296	(8)
(9)		HDD18.3	3509	585	511	435	274	166	70	31	42	142	279	422	554	(9)
(10)		CDD10.0	1062	0	0	2	40	110	209	284	259	119	36	2	0	(10)
(11)		CDD18.3	136	0	0	0	0	5	28	57	42	5	0	0	0	(11)
(12)		CDH23.3	1609	0	0	0	14	78	335	641	485	54	1	0	0	(12)
(13)		CDH26.7	519	0	0	0	1	10	94	229	174	10	0	0	0	(13)
(14)	Wind	WSAvg	1.9	2.4	2.2	2.4	2.0	1.9	1.7	1.8	1.6	1.6	1.8	2.1	(14)	
(15)	Precipitation	PrecAvg	577	30	26	35	36	58	79	80	73	45	41	38	37	(15)
(16)		PrecMax	885	58	62	82	69	148	124	164	234	98	108	84	80	(16)
(17)		PrecMin	373	10	7	7	9	11	42	31	24	18	6	2	15	(17)
(18)		PrecStd	100	16	15	21	18	28	24	29	44	19	23	18	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	14.0	18.8	25.1	28.0	32.1	34.1	34.1	28.1	22.9	14.9	11.2	(19)
(20)			MCWB	9.0	8.0	10.9	14.3	18.0	20.7	19.7	19.7	18.8	15.4	12.1	9.0	(20)
(21)		2%	DB	9.8	10.2	15.2	22.2	25.8	29.1	31.2	31.0	24.8	19.1	12.4	9.8	(21)
(22)			MCWB	7.7	6.9	9.5	13.1	16.9	19.2	19.2	19.6	17.3	14.2	10.2	8.1	(22)
(23)		5%	DB	7.8	8.1	12.9	20.1	23.1	27.1	29.2	28.1	22.2	17.0	11.0	8.0	(23)
(24)			MCWB	6.3	6.0	8.3	12.3	15.4	18.2	18.6	18.6	16.2	13.2	9.2	6.7	(24)
(25)		10%	DB	5.9	6.4	10.5	17.8	20.9	25.0	27.1	25.9	20.1	15.1	9.3	6.2	(25)
(26)			MCWB	4.7	4.4	7.3	11.4	14.2	17.2	18.4	18.0	15.3	12.4	7.9	5.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	8.9	11.9	15.8	19.3	22.0	21.6	21.7	19.4	16.5	12.4	9.7	(27)
(28)			MCD B	11.3	12.5	16.0	23.7	26.4	29.8	28.7	28.6	25.2	20.2	14.4	11.0	(28)
(29)		2%	WB	7.7	7.4	10.2	14.0	17.6	20.3	20.6	20.6	18.3	15.1	10.7	8.2	(29)
(30)			MCD B	9.3	9.7	14.2	20.5	23.9	26.6	27.6	27.6	23.7	18.2	12.2	9.5	(30)
(31)		5%	WB	6.1	6.1	8.9	12.8	16.3	19.0	19.7	19.6	17.0	13.9	9.4	6.5	(31)
(32)			MCD B	7.2	8.2	12.0	18.7	21.8	25.6	26.4	25.9	21.4	16.7	10.8	7.6	(32)
(33)		10%	WB	4.5	4.4	7.5	11.7	15.1	17.9	19.0	18.6	15.9	12.7	8.1	5.3	(33)
(34)			MCD B	5.7	6.2	10.2	16.9	19.7	23.5	25.7	24.4	19.3	15.2	9.2	6.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	6.9	8.7	11.3	11.0	11.2	11.9	11.5	9.7	8.6	5.1	4.8	(35)
(36)			MCDBR	6.7	10.6	14.5	16.4	15.4	15.6	16.3	16.1	13.5	12.1	7.7	7.2	(36)
(37)			MCWBR	5.4	7.4	8.7	8.2	7.5	6.6	5.7	6.2	6.9	7.5	5.7	5.7	(37)
(38)		5% WB	MCDBR	6.3	10.2	12.5	14.6	13.7	14.2	13.3	13.5	12.1	11.5	7.0	6.6	(38)
(39)			MCWBR	5.4	7.3	8.2	7.8	7.0	6.5	5.5	5.8	6.4	7.4	5.4	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.299	0.321	0.361	0.401	0.404	0.405	0.416	0.409	0.380	0.353	0.324	0.295	(40)	
(41)		taud	2.390	2.353	2.308	2.243	2.268	2.292	2.265	2.303	2.356	2.420	2.453	2.424	(41)	
(42)		Ebn at Noon	750	819	841	843	855	855	838	825	812	772	715	703	(42)	
(43)		Edh at Noon	64	85	106	126	128	126	128	118	101	80	62	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.86	1.73	2.74	4.18	4.91	5.37	5.13	4.52	3.23	1.94	0.93	0.66	(44)	
(45)		RadStd	0.16	0.25	0.38	0.54	0.58	0.46	0.52	0.46	0.44	0.24	0.10	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (61 neighbors)	+0.42	N/A	N/A	N/A	+0.33	+0.32	N/A	N/A	+55	+23

Nomenclature: See separate page