

PLZEN-MIKULKA, Czech Republic

WMO: 114500

Lat: 49.7647N

Lon: 13.3789E

Elev: 372

StdP: 96.94

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-9.1	-15.1	1.1	-10.3	-12.3	1.4	-7.5	10.8	6.2	9.6	6.2	2.1	10	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	31.7	19.2	29.6	18.6	27.7	17.9	20.4	28.6	19.5	27.3	18.7	25.5	3.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.5	21.8	17.2	12.8	21.3	16.4	12.2	20.8	60.2	28.5	57.2	27.5	54.6	25.4	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.4	6.4	-13.9	35.4	3.8	1.8	-16.6	36.7	-18.9	37.7	-21.1	38.7	-23.8	40.0		
(5)			-14.2	22.0	3.8	1.0	-17.0	22.7	-19.2	23.3	-21.4	23.9	-24.2	24.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-0.2	0.6	4.7	10.1	13.8	17.7	19.7	18.9	14.7	9.6	4.6	1.2	(6)
(7)		DBStd	8.04	4.63	4.41	4.20	3.99	3.86	3.68	3.44	3.35	3.54	3.60	3.62	4.03	(7)
(8)		HDD10.0	1302	316	264	168	48	11	1	0	0	3	53	164	274	(8)
(9)		HDD18.3	3338	574	497	422	248	148	55	26	33	119	272	411	533	(9)
(10)		CDD10.0	1179	0	0	4	50	128	232	301	277	144	39	3	0	(10)
(11)		CDD18.3	174	0	0	0	1	8	37	69	51	9	0	0	0	(11)
(12)		CDH23.3	1923	0	0	0	18	113	412	728	547	104	2	0	0	(12)
(13)		CDH26.7	641	0	0	0	2	24	126	276	192	21	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.5	3.2	3.4	3.0	3.0	2.8	2.9	2.7	2.6	2.7	3.1	3.3	(14)
(15)	Precipitation	PrecAvg	524	28	23	30	32	55	72	74	63	43	38	35	31	(15)
(16)		PrecMax	766	52	54	82	66	124	114	145	186	89	109	86	63	(16)
(17)		PrecMin	330	8	3	4	8	14	24	17	20	13	5	2	5	(17)
(18)		PrecStd	87	13	14	18	16	27	24	29	35	18	21	20	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	13.9	19.5	25.6	29.5	32.8	35.0	34.5	29.2	22.9	15.3	11.1	(19)
(20)			MCWB	8.5	7.8	10.7	14.4	17.8	19.3	19.8	19.3	18.7	15.0	11.7	8.7	(20)
(21)		2%	DB	9.6	10.5	16.4	22.9	26.6	30.0	32.2	30.9	26.1	19.6	13.4	9.4	(21)
(22)			MCWB	7.4	6.9	9.2	13.0	16.9	18.9	19.2	19.3	17.1	13.9	10.5	7.6	(22)
(23)		5%	DB	7.6	8.4	13.9	20.8	23.9	27.8	29.8	28.6	23.9	17.5	11.6	7.7	(23)
(24)			MCWB	5.8	5.5	8.0	12.1	15.4	17.8	18.5	18.5	16.1	13.0	9.4	6.1	(24)
(25)		10%	DB	5.9	6.6	11.3	18.3	21.5	25.6	27.5	26.4	21.4	15.3	10.0	6.4	(25)
(26)			MCWB	4.4	4.4	7.3	11.1	14.0	17.1	17.9	17.7	15.2	12.2	8.4	5.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	8.9	11.6	15.2	19.3	21.5	21.1	21.4	19.3	16.0	12.5	9.2	(27)
(28)			MCDWB	11.0	12.0	17.8	23.7	27.0	29.3	30.4	29.0	27.0	20.1	15.0	10.5	(28)
(29)		2%	WB	7.5	7.1	10.1	13.6	17.5	19.9	20.1	20.4	17.9	14.6	10.9	7.7	(29)
(30)			MCDWB	9.3	9.9	14.9	21.0	24.4	28.1	29.1	28.0	24.3	18.1	12.8	9.1	(30)
(31)		5%	WB	5.9	5.7	8.8	12.5	16.1	18.7	19.4	19.3	16.9	13.6	9.7	6.2	(31)
(32)			MCDWB	7.4	8.2	12.7	19.4	22.6	25.7	27.3	26.1	22.3	16.7	11.3	7.6	(32)
(33)		10%	WB	4.5	4.4	7.5	11.5	14.9	17.6	18.7	18.4	15.9	12.5	8.3	5.1	(33)
(34)			MCDWB	5.8	6.6	11.0	17.4	20.2	24.0	25.5	24.5	20.2	15.2	9.8	6.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	6.9	9.2	11.6	11.1	11.4	11.9	11.7	10.6	8.6	5.2	4.6	(35)
(36)			MCDBR	6.4	10.1	14.8	16.3	15.4	15.9	16.4	16.0	14.8	12.4	7.6	6.4	(36)
(37)			MCWBR	4.9	6.5	8.2	7.6	6.7	6.3	5.3	5.7	6.4	6.9	5.1	4.8	(37)
(38)		5% WB	MCDBR	6.2	9.4	12.8	14.6	14.2	13.9	13.7	13.6	13.2	11.1	6.7	6.0	(38)
(39)			MCWBR	5.0	6.4	7.6	7.2	6.5	5.9	4.9	5.4	6.0	6.6	4.7	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.298	0.320	0.360	0.399	0.402	0.404	0.415	0.408	0.378	0.351	0.323	0.294	(40)	
(41)		taud	2.395	2.362	2.313	2.245	2.271	2.294	2.266	2.305	2.360	2.422	2.456	2.429	(41)	
(42)		Ebn at Noon	750	820	842	843	856	856	839	826	814	773	715	703	(42)	
(43)		Edh at Noon	64	84	105	126	128	126	128	117	100	79	61	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.86	1.72	2.72	4.16	4.90	5.36	5.11	4.50	3.21	1.93	0.92	0.66	(44)	
(45)		RadStd	0.16	0.25	0.38	0.54	0.58	0.46	0.53	0.45	0.44	0.24	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (63 neighbors)		+0.41	N/A	N/A	N/A	+0.33	+0.33	N/A	N/A	+50	+19

Nomenclature: See separate page