

CHURANOV, Czech Republic

WMO: 114570

Lat: 49.0682N

Lon: 13.6152E

Elev: 1122

StdP: 88.55

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-12.1	-18.4	0.8	-9.5	-15.5	1.1	-8.2	11.9	0.0	10.8	-0.8	2.6	80	0.630

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	25.3	16.2	23.4	15.7	21.6	15.1	17.4	22.8	16.6	21.7	15.7	20.5	2.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	12.6	19.3	14.7	12.0	18.3	13.9	11.3	17.4	53.5	22.8	50.7	21.7	48.2	20.7	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.2	7.2	-17.0	28.4	2.7	1.7	-18.9	29.7	-20.5	30.7	-22.0	31.7	-24.0	33.0		
(5)			-17.3	19.3	2.6	1.1	-19.2	20.1	-20.7	20.7	-22.2	21.3	-24.2	22.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-3.1	-2.5	0.3	4.9	9.3	12.7	14.5	14.4	10.0	6.3	1.8	-1.8	(6)
(7)		DBStd	7.70	4.61	5.06	4.57	4.80	4.14	4.11	3.72	3.71	3.83	4.60	4.83	4.62	(7)
(8)		HDD10.0	2108	406	351	301	162	64	19	5	6	47	133	248	366	(8)
(9)		HDD18.3	4668	664	584	559	402	280	175	128	132	250	374	496	624	(9)
(10)		CDD10.0	506	0	0	1	11	42	99	145	141	48	17	2	0	(10)
(11)		CDD18.3	24	0	0	0	0	1	4	9	9	1	0	0	0	(11)
(12)		CDH23.3	169	0	0	0	0	3	36	67	61	4	0	0	0	(12)
(13)		CDH26.7	19	0	0	0	0	0	2	9	9	0	0	0	0	(13)
(14)	Wind	WSAvg	3.4	4.2	3.9	3.7	3.0	3.0	2.8	3.0	2.8	2.9	3.3	3.6	4.2	(14)
(15)	Precipitation	PrecAvg	894	67	59	70	49	79	101	107	96	69	64	64	70	(15)
(16)		PrecMax	1291	151	136	177	106	134	182	169	294	150	175	130	195	(16)
(17)		PrecMin	655	4	8	15	5	16	33	27	23	20	18	3	24	(17)
(18)		PrecStd	137	39	36	42	21	32	35	39	52	33	37	32	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	10.9	14.4	20.2	23.2	26.6	27.8	28.0	23.2	19.8	15.3	10.1	(19)
(20)			MCWB	3.2	3.2	6.7	10.7	14.3	16.5	16.9	16.3	15.0	11.9	8.8	4.8	(20)
(21)		2%	DB	6.4	7.8	11.2	16.7	20.5	24.4	25.1	24.9	20.0	16.7	12.6	7.2	(21)
(22)			MCWB	2.8	3.0	5.5	9.8	13.7	16.2	16.4	16.2	14.2	11.0	7.1	3.3	(22)
(23)		5%	DB	4.6	5.6	8.7	14.5	18.5	22.0	23.1	22.6	18.0	14.6	10.1	5.4	(23)
(24)			MCWB	2.5	2.3	4.4	8.7	12.6	15.3	15.8	15.6	13.4	10.2	6.5	3.0	(24)
(25)		10%	DB	3.0	3.8	6.5	12.2	16.4	19.9	21.1	20.8	16.0	12.4	8.2	3.8	(25)
(26)			MCWB	1.4	1.6	3.7	7.4	11.4	14.2	15.1	15.1	12.4	9.4	5.7	2.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	5.5	7.5	11.9	16.1	18.7	18.4	18.1	16.4	13.4	9.8	5.9	(27)
(28)			MCDWB	6.2	8.5	12.0	17.8	20.7	23.6	23.9	23.7	20.5	17.0	13.0	7.8	(28)
(29)		2%	WB	4.0	4.1	6.3	10.3	14.5	17.0	17.3	17.1	14.9	12.0	8.2	4.7	(29)
(30)			MCDWB	5.2	5.9	9.6	15.7	19.3	22.0	22.9	22.6	18.8	15.1	11.1	6.2	(30)
(31)		5%	WB	2.7	3.0	5.2	9.1	13.1	15.9	16.5	16.2	13.8	10.9	7.1	3.7	(31)
(32)			MCDWB	4.1	4.9	7.8	13.5	17.3	20.8	21.6	21.5	17.1	13.4	9.4	5.0	(32)
(33)		10%	WB	1.4	1.9	4.1	8.0	11.9	14.7	15.6	15.4	12.8	9.8	5.9	2.5	(33)
(34)			MCDWB	2.7	3.7	6.0	11.8	15.6	19.2	20.1	20.1	15.5	12.1	8.0	3.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	5.8	6.5	7.9	8.2	8.5	8.4	7.1	6.7	5.6	5.0	(35)	
(36)			MCDBR	7.4	8.5	10.1	10.7	11.1	11.5	11.2	11.2	10.0	9.5	9.0	7.4	(36)
(37)			MCWBR	4.9	5.4	5.9	5.8	6.1	6.0	5.2	5.3	5.5	5.7	5.3	5.0	(37)
(38)		5% WB	MCDWB	6.0	7.1	8.6	9.9	10.1	10.4	9.9	10.2	8.8	8.6	8.1	6.3	(38)
(39)			MCWBR	4.5	5.0	5.5	5.8	6.0	5.9	5.1	5.2	5.2	5.5	5.2	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.265	0.285	0.319	0.350	0.355	0.357	0.365	0.359	0.336	0.313	0.289	0.264	(40)	
(41)		taud	2.421	2.407	2.394	2.364	2.375	2.388	2.360	2.394	2.439	2.499	2.517	2.475	(41)	
(42)		Ebn at Noon	814	876	895	898	904	902	888	878	866	832	779	769	(42)	
(43)		Edh at Noon	62	81	97	112	115	115	116	107	93	74	58	52	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.93	1.83	2.88	4.26	4.98	5.47	5.25	4.63	3.30	2.02	0.99	0.71	(44)	
(45)		RadStd	0.16	0.26	0.38	0.55	0.58	0.47	0.51	0.47	0.44	0.24	0.11	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e) +1.14	(f) N/A	(g) N/A	(h) N/A	(i) +0.34	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (82 neighbors)	+0.46	N/A	N/A	N/A	+0.37	+0.35	N/A	N/A	+60	+26

Nomenclature: See separate page