

MILESOVKA, Czech Republic

WMO: 114640

Lat: 50.5550N

Lon: 13.9308E

Elev: 843

StdP: 91.60

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.0	-10.8	-16.7	1.0	-10.9	-13.4	1.3	-9.4	22.4	2.6	20.1	0.8	7.6	120	0.878

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	28.3	18.9	26.2	18.0	24.1	17.1	19.9	26.6	18.8	24.8	17.7	23.1	4.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	13.9	23.4	16.5	13.0	21.7	15.6	12.3	20.3	60.9	26.7	56.9	25.1	53.3	23.3	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	16.3	14.7	DB	-15.1	32.6	3.0	2.0	-17.3	34.1	-19.1	35.3	-20.8	36.4	-23.0	37.8	(4)
(5)			WB	-15.4	22.4	3.0	1.0	-17.6	23.1	-19.4	23.7	-21.0	24.3	-23.2	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-3.1	-1.9	1.9	7.8	12.0	15.1	17.1	16.9	12.2	6.8	1.8	-1.8	(6)	
	DBStd	8.40	4.29	4.50	4.65	4.93	4.35	4.33	4.09	3.83	3.97	4.07	3.80	4.00	(7)	
	HDD10.0	1878	404	334	254	99	29	7	1	2	20	114	247	366	(8)	
	HDD18.3	4184	663	568	511	317	200	114	74	74	187	356	497	624	(9)	
	CDD10.0	826	0	0	2	33	92	161	220	215	87	17	1	0	(10)	
	CDD18.3	90	0	0	0	1	4	18	35	29	4	0	0	0	(11)	
	CDH23.3	604	0	0	0	4	35	137	233	178	17	0	0	0	(12)	
	CDH26.7	148	0	0	0	0	4	34	63	46	1	0	0	0	(13)	
(14) Wind	WSAvg	7.7	9.1	8.7	8.1	7.1	7.1	6.6	6.6	6.5	7.0	8.0	8.4	9.1	(14)	
(15) Precipitation	PrecAvg	694	46	40	47	39	67	78	88	84	57	49	51	50	(15)	
	PrecMax	996	90	73	157	79	133	162	159	228	128	100	107	106	(16)	
	PrecMin	412	6	9	15	2	13	35	24	10	21	9	0	16	(17)	
	PrecStd	114	23	18	28	18	32	31	34	47	28	23	25	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	10.2	16.1	23.4	26.6	30.3	31.5	31.1	25.8	18.9	11.9	7.6	(19)	
		MCWB	5.9	5.5	8.9	13.7	17.7	20.7	20.4	19.4	17.3	13.7	10.0	5.9	(20)	
	2%	DB	6.0	7.2	12.6	19.9	23.9	27.1	28.3	27.6	22.5	15.8	9.7	6.1	(21)	
		MCWB	5.1	4.6	7.3	12.0	16.1	19.0	18.8	18.6	16.2	12.4	8.2	4.6	(22)	
	5%	DB	4.2	5.4	10.0	17.3	21.2	24.4	25.9	25.1	19.9	13.6	8.3	4.7	(23)	
		MCWB	3.5	3.5	6.0	10.7	14.6	17.4	18.1	17.8	14.8	11.3	7.4	3.8	(24)	
	10%	DB	2.6	3.7	7.7	14.8	18.6	21.9	23.5	22.7	17.6	12.0	6.7	3.3	(25)	
		MCWB	2.0	2.4	5.1	9.6	13.0	16.2	17.1	16.6	13.8	10.5	5.9	2.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	6.7	9.7	14.4	19.1	21.6	21.2	20.7	18.3	14.6	10.2	6.8	(27)	
		MCDB	7.2	8.3	14.8	22.2	25.6	28.1	29.1	27.3	23.4	17.3	11.4	7.2	(28)	
	2%	WB	5.1	5.2	7.9	12.6	16.9	19.5	19.7	19.4	16.6	12.8	8.7	5.3	(29)	
		MCDB	5.7	6.6	11.1	18.8	22.3	25.6	26.7	25.9	21.4	15.1	9.4	5.8	(30)	
	5%	WB	3.5	3.8	6.6	11.3	15.1	18.0	18.6	18.3	15.3	11.7	7.5	3.9	(31)	
		MCDB	4.1	5.1	9.2	16.5	20.4	23.6	24.8	24.0	19.2	13.3	8.2	4.4	(32)	
	10%	WB	2.1	2.5	5.4	9.9	13.6	16.6	17.5	17.2	14.2	10.6	6.1	2.8	(33)	
		MCDB	2.6	3.6	7.6	14.1	17.8	21.2	22.7	21.9	17.2	11.9	6.7	3.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.0	5.0	6.7	9.3	9.8	9.7	9.3	9.4	7.5	5.5	3.8	3.8	(35)	
		MCDBR	5.0	6.6	9.9	12.6	13.2	13.2	12.6	12.5	11.0	7.9	5.3	4.7	(36)	
	5% WB	MCWBR	4.3	4.7	6.1	6.6	7.4	7.3	6.4	6.1	6.0	5.2	4.1	4.0	(37)	
		MCWBR	4.7	6.0	8.9	12.0	12.6	12.6	11.6	11.4	10.4	7.3	5.0	4.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.283	0.303	0.341	0.378	0.380	0.378	0.391	0.385	0.353	0.332	0.308	0.278	(40)	
		taud	2.419	2.407	2.348	2.282	2.301	2.324	2.288	2.326	2.398	2.449	2.473	2.440	(41)	
	Ebn at Noon		763	838	860	862	876	879	859	845	837	790	725	714	(42)	
		Edh at Noon	60	79	100	120	123	122	124	114	95	75	58	51	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.80	1.58	2.55	4.05	4.88	5.25	4.98	4.36	3.12	1.82	0.86	0.61	(44)	
	RadStd		0.14	0.24	0.38	0.53	0.58	0.45	0.56	0.42	0.43	0.25	0.11	0.07	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (53 neighbors)		+0.41	N/A	N/A	N/A	+0.34	+0.35	N/A	N/A	+50	+16	

Nomenclature: See separate page