

USTI NAD LABEM, Czech Republic

WMO: 115020

Lat: 50.6833N

Lon: 14.0411E

Elev: 379

StdP: 96.86

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.6	-9.1	-15.4	1.0	-10.3	-12.7	1.3	-7.5	13.9	6.0	12.0	3.4	2.8	40	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	29.5	19.3	27.6	18.5	25.7	17.7	20.4	27.2	19.4	25.7	18.5	24.3	3.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.5	23.1	17.1	12.7	22.0	16.3	12.1	21.2	60.1	27.1	56.7	25.7	53.8	24.4	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.4	7.2	DB	-13.6	32.8	2.8	2.3	-15.6	34.4	-17.2	35.8	-18.8	37.1	-20.9	38.7	(4)
(5)			WB	-14.1	22.2	2.7	1.4	-16.0	23.2	-17.6	24.0	-19.2	24.7	-21.1	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-1.1	0.5	4.2	9.6	13.7	16.9	19.0	18.8	14.2	9.0	4.0	0.1		
	DBStd	8.18	4.59	4.48	4.18	4.64	3.92	3.75	3.66	3.42	3.51	3.78	3.65	4.29		
	HDD10.0	1427	344	266	184	63	11	1	0	0	4	64	182	308		
	HDD18.3	3513	602	499	439	262	151	72	37	36	131	289	431	566		
	CDD10.0	1106	0	1	4	52	127	207	278	272	130	34	2	0		
	CDD18.3	151	0	0	0	1	8	28	57	49	8	0	0	0		
	CDH23.3	1041	0	0	0	6	51	201	420	328	37	0	0	0		
	CDH26.7	263	0	0	0	0	4	46	124	86	3	0	0	0		
(14) Wind	WSAvg	3.2	3.5	3.4	3.7	3.4	3.3	3.2	3.1	2.8	2.9	2.8	3.0	3.3		
(15) Precipitation	PrecAvg	599	35	30	36	32	60	72	84	77	49	42	42	40		
	PrecMax	910	71	55	121	68	111	152	147	238	117	86	88	83		
	PrecMin	333	6	5	9	2	11	28	23	9	18	6	0	13		
	PrecStd	106	17	14	23	16	28	32	34	42	26	21	20	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	12.3	17.0	24.0	27.2	30.9	32.6	32.2	26.9	20.5	14.3	10.8		
		MCWB	8.3	8.5	10.0	14.1	17.7	20.9	20.0	20.1	17.5	14.6	11.3	8.6		
	2%	DB	8.6	10.0	14.5	21.3	24.8	27.9	29.8	28.9	24.1	17.6	12.1	8.4		
		MCWB	6.6	6.9	8.6	12.8	16.5	18.7	19.3	19.3	16.5	13.2	9.6	6.6		
	5%	DB	6.6	8.2	12.1	18.9	22.4	25.7	27.8	26.7	21.9	15.7	10.5	6.8		
		MCWB	4.9	5.7	7.7	11.9	15.2	17.9	18.5	18.4	15.6	12.4	8.6	5.5		
	10%	DB	4.9	6.4	10.0	16.8	20.4	23.6	25.5	24.8	19.8	14.1	9.0	5.4		
		MCWB	3.5	4.3	6.7	10.8	13.9	16.9	17.7	17.5	14.8	11.8	7.6	4.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.2	10.9	15.0	19.1	22.0	21.5	21.3	19.2	15.6	11.7	8.7		
		MCDB	10.3	11.8	15.5	22.3	25.7	28.6	29.3	29.3	24.5	18.7	13.9	10.4		
	2%	WB	6.8	7.5	9.3	13.4	17.4	20.1	20.0	20.1	17.4	14.0	10.2	6.9		
		MCDB	8.3	9.6	13.1	20.0	23.3	25.7	27.5	26.9	21.9	16.2	11.7	8.0		
	5%	WB	5.0	6.0	8.3	12.2	15.9	18.6	19.2	19.1	16.2	12.9	8.9	5.6		
		MCDB	6.5	7.8	11.3	17.9	21.2	24.1	25.9	25.2	20.6	15.2	10.2	6.7		
	10%	WB	3.6	4.4	7.0	11.1	14.7	17.4	18.4	18.2	15.2	11.9	7.6	4.3		
		MCDB	4.8	6.1	9.7	16.2	19.2	22.5	24.3	23.5	19.2	13.8	8.8	5.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	5.0	6.5	8.3	8.7	8.7	8.8	8.9	7.6	5.8	3.9	3.6		
		MCDBR	5.4	6.6	10.0	11.2	11.4	12.1	11.9	11.7	10.7	8.1	5.6	5.0		
	5% WB	MCWBR	4.3	4.5	5.6	5.6	5.7	5.7	4.9	5.0	5.0	4.5	4.0	4.0		
		MCWBR	5.3	6.0	8.7	10.5	10.4	11.1	10.6	10.4	9.6	7.3	5.1	4.7		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.328	0.371	0.414	0.415	0.412	0.428	0.422	0.384	0.359	0.332	0.300		
		taud	2.370	2.347	2.265	2.190	2.222	2.259	2.221	2.259	2.337	2.386	2.411	2.395		
	Ebn at Noon		722	800	822	824	841	846	824	809	801	752	682	672		
		Edh at Noon	64	84	109	132	133	130	133	122	101	81	62	54		
(44) All-Sky Solar Radiation	RadAvg		0.80	1.55	2.54	4.05	4.89	5.26	4.98	4.37	3.12	1.81	0.86	0.60		
	RadStd		0.14	0.24	0.37	0.53	0.57	0.44	0.57	0.42	0.43	0.25	0.11	0.06		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)		+0.40	N/A	N/A	N/A	+0.33	+0.34	N/A	N/A	+50	+16

Nomenclature: See separate page