

**DOKSANY, Czech Republic**WMO: **115090**Lat: **50.4589N**Lon: **14.1700E**Elev: **526**StdP: **14.42**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

| Coldest Month | Heating DB |      | Humidification DP/MCDB and HR |     |      |     |     |      | Coldest Month WS/MCDB |      |      |      | MCWS/PCWD to 99.6% DB |      | WSF   |
|---------------|------------|------|-------------------------------|-----|------|-----|-----|------|-----------------------|------|------|------|-----------------------|------|-------|
|               |            |      | 99.6%                         |     |      | 99% |     |      | 0.4%                  |      | 1%   |      |                       |      |       |
|               | 99.6%      | 99%  | DP                            | HR  | MCDB | DP  | HR  | MCDB | WS                    | MCDB | WS   | MCDB | MCWS                  | PCWD |       |
| (a)           | (b)        | (c)  | (d)                           | (e) | (f)  | (g) | (h) | (i)  | (j)                   | (k)  | (l)  | (m)  | (n)                   | (o)  | (p)   |
| 1             | 8.8        | 14.6 | 3.8                           | 6.8 | 11.1 | 9.6 | 9.1 | 16.6 | 25.0                  | 44.8 | 22.2 | 43.3 | 3.4                   | 0    | 0.525 |

**Annual Cooling, Dehumidification, and Enthalpy Design Conditions**

| Hottest Month | Hottest Month DB Range | Cooling DB/MCWB |      |      |      |      |      | Evaporation WB/MCDB |      |      |      |      |      | MCWS/PCWD to 0.4% DB |      |
|---------------|------------------------|-----------------|------|------|------|------|------|---------------------|------|------|------|------|------|----------------------|------|
|               |                        | 0.4%            |      | 1%   |      | 2%   |      | 0.4%                |      | 1%   |      | 2%   |      |                      |      |
|               |                        | DB              | MCWB | DB   | MCWB | DB   | MCWB | WB                  | MCDB | WB   | MCDB | WB   | MCDB | MCWS                 | PCWD |
| (a)           | (b)                    | (c)             | (d)  | (e)  | (f)  | (g)  | (h)  | (i)                 | (j)  | (k)  | (l)  | (m)  | (n)  | (o)                  | (p)  |
| 7             | 22.9                   | 89.4            | 67.9 | 85.7 | 66.5 | 82.4 | 65.5 | 70.1                | 83.8 | 68.4 | 81.0 | 66.9 | 78.5 | 6.8                  | 120  |

| Dehumidification DP/MCDB and HR |      |      |      |      |      |      |      |      | Enthalpy/MCDB |      |      |      |      |      | Extreme<br>Max WB |
|---------------------------------|------|------|------|------|------|------|------|------|---------------|------|------|------|------|------|-------------------|
| 0.4%                            |      |      | 1%   |      |      | 2%   |      |      | 0.4%          |      | 1%   |      | 2%   |      |                   |
| DP                              | HR   | MCDB | DP   | HR   | MCDB | DP   | HR   | MCDB | Enth          | MCDB | Enth | MCDB | Enth | MCDB |                   |
| (a)                             | (b)  | (c)  | (d)  | (e)  | (f)  | (g)  | (h)  | (i)  | (j)           | (k)  | (l)  | (m)  | (n)  | (o)  |                   |
| 65.9                            | 97.4 | 73.4 | 64.4 | 92.3 | 71.8 | 62.9 | 87.5 | 70.9 | 34.3          | 84.0 | 32.9 | 81.1 | 31.7 | 78.6 | 77.5              |

**Extreme Annual Design Conditions**

| Extreme Annual WS |             |             | Extreme Annual Temperature |            |                    |            | n-Year Return Period Values of Extreme Temperature |             |             |             |              |              |              |              |              |    |
|-------------------|-------------|-------------|----------------------------|------------|--------------------|------------|----------------------------------------------------|-------------|-------------|-------------|--------------|--------------|--------------|--------------|--------------|----|
|                   |             |             | Mean                       |            | Standard Deviation |            | n=5 years                                          |             | n=10 years  |             | n=20 years   |              | n=50 years   |              |              |    |
| 1%                | 2.5%        | 5%          | Min                        | Max        | Min                | Max        | Min                                                | Max         | Min         | Max         | Min          | Max          | Min          | Max          | DB           | WB |
| (a)               | (b)         | (c)         | (e)                        | (f)        | (g)                | (h)        | (i)                                                | (j)         | (k)         | (l)         | (m)          | (n)          | (o)          | (p)          |              |    |
| (4)               | <b>20.1</b> | <b>17.1</b> | <b>14.8</b>                | <b>1.4</b> | <b>95.7</b>        | <b>7.1</b> | <b>4.1</b>                                         | <b>-3.7</b> | <b>98.7</b> | <b>-7.8</b> | <b>101.1</b> | <b>-11.8</b> | <b>103.4</b> | <b>-17.0</b> | <b>106.4</b> |    |
| (5)               |             |             |                            | <b>1.0</b> | <b>73.8</b>        | <b>7.1</b> | <b>2.0</b>                                         | <b>-4.1</b> | <b>75.2</b> | <b>-8.3</b> | <b>76.4</b>  | <b>-12.3</b> | <b>77.5</b>  | <b>-17.4</b> | <b>78.9</b>  |    |

**Monthly Climatic Design Conditions**

|                                                                               |             | Annual | Jan   | Feb   | Mar   | Apr   | May   | Jun   | Jul   | Aug   | Sep   | Oct   | Nov   | Dec  |
|-------------------------------------------------------------------------------|-------------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|------|
|                                                                               |             | (d)    | (e)   | (f)   | (g)   | (h)   | (i)   | (j)   | (k)   | (l)   | (m)   | (n)   | (o)   | (p)  |
| Temperatures,<br>Degree-Days<br>and<br>Degree-Hours                           | DBAvg       | 49.5   | 31.2  | 34.1  | 40.7  | 49.8  | 57.7  | 63.8  | 67.4  | 66.9  | 58.7  | 49.5  | 40.4  | 33.4 |
|                                                                               | DBStd       | 14.53  | 8.76  | 8.10  | 6.90  | 7.00  | 6.26  | 5.99  | 5.62  | 5.46  | 5.89  | 6.62  | 6.42  | 8.28 |
|                                                                               | HDD50       | 2325   | 584   | 447   | 294   | 88    | 10    | 0     | 0     | 0     | 3     | 90    | 294   | 515  |
|                                                                               | HDD65       | 5941   | 1048  | 865   | 753   | 457   | 239   | 94    | 40    | 43    | 203   | 481   | 738   | 980  |
|                                                                               | CDD50       | 2158   | 1     | 2     | 6     | 81    | 249   | 413   | 539   | 522   | 264   | 75    | 6     | 0    |
|                                                                               | CDD65       | 297    | 0     | 0     | 0     | 0     | 13    | 57    | 113   | 100   | 14    | 0     | 0     | 0    |
|                                                                               | CDH74       | 3840   | 0     | 0     | 0     | 43    | 242   | 763   | 1360  | 1211  | 214   | 7     | 0     | 0    |
|                                                                               | CDH80       | 1271   | 0     | 0     | 0     | 3     | 51    | 232   | 516   | 425   | 44    | 0     | 0     | 0    |
| Wind                                                                          | WSAvg       | 6.0    | 6.6   | 6.5   | 7.1   | 6.5   | 6.2   | 5.6   | 5.7   | 5.3   | 5.4   | 5.5   | 5.7   | 6.3  |
| Precipitation                                                                 | PrecAvg     | 20.4   | 1.0   | 0.9   | 1.1   | 1.1   | 2.2   | 2.7   | 3.0   | 2.8   | 1.7   | 1.4   | 1.3   | 1.2  |
|                                                                               | PrecMax     | 30.4   | 2.2   | 1.7   | 3.7   | 2.3   | 4.2   | 5.4   | 5.4   | 7.2   | 3.7   | 2.8   | 3.3   | 2.5  |
|                                                                               | PrecMin     | 12.2   | 0.2   | 0.2   | 0.2   | 0.2   | 0.4   | 0.9   | 0.6   | 0.7   | 0.5   | 0.3   | 0.0   | 0.3  |
|                                                                               | PrecStd     | 3.7    | 0.5   | 0.5   | 0.7   | 0.6   | 1.0   | 1.0   | 1.2   | 1.4   | 0.9   | 0.7   | 0.7   | 0.6  |
| Monthly Design<br>Dry Bulb and<br>Mean Coincident<br>Wet Bulb<br>Temperatures | 0.4%        | DB     | 54.8  | 56.8  | 67.2  | 79.1  | 85.3  | 91.3  | 95.1  | 94.8  | 85.0  | 73.2  | 60.9  | 52.9 |
|                                                                               |             | MCWB   | 49.0  | 49.0  | 52.0  | 59.4  | 65.8  | 69.7  | 69.3  | 68.0  | 65.5  | 60.8  | 54.2  | 48.0 |
|                                                                               | 2%          | DB     | 50.1  | 53.2  | 61.9  | 73.7  | 80.4  | 86.0  | 89.9  | 88.3  | 79.7  | 67.3  | 56.6  | 48.9 |
|                                                                               |             | MCWB   | 45.5  | 46.9  | 50.0  | 56.7  | 63.2  | 67.2  | 67.6  | 67.3  | 63.7  | 58.3  | 51.6  | 45.1 |
|                                                                               | 5%          | DB     | 46.5  | 49.5  | 57.4  | 69.6  | 76.1  | 82.1  | 85.8  | 84.5  | 75.6  | 63.4  | 53.3  | 46.2 |
|                                                                               |             | MCWB   | 42.8  | 44.2  | 48.2  | 55.0  | 61.2  | 66.0  | 66.7  | 66.1  | 62.1  | 56.4  | 49.5  | 43.0 |
|                                                                               | 10%         | DB     | 42.9  | 45.7  | 52.9  | 65.2  | 72.2  | 78.3  | 81.7  | 80.9  | 71.3  | 59.9  | 50.0  | 43.7 |
|                                                                               |             | MCWB   | 39.8  | 41.4  | 45.9  | 52.9  | 58.9  | 64.1  | 65.5  | 64.8  | 60.2  | 54.5  | 47.1  | 41.0 |
| Monthly Design<br>Wet Bulb and<br>Mean Coincident<br>Dry Bulb<br>Temperatures | 0.4%        | WB     | 49.6  | 50.2  | 54.2  | 60.9  | 68.2  | 73.1  | 72.0  | 71.5  | 67.5  | 62.1  | 55.3  | 48.5 |
|                                                                               |             | MCDB   | 54.0  | 55.7  | 63.8  | 75.4  | 81.7  | 86.0  | 87.9  | 84.8  | 78.6  | 69.5  | 59.1  | 51.8 |
|                                                                               | 2%          | WB     | 45.9  | 47.6  | 51.4  | 57.9  | 64.9  | 69.6  | 69.7  | 69.5  | 65.1  | 59.5  | 52.2  | 45.5 |
|                                                                               |             | MCDB   | 49.6  | 52.5  | 59.7  | 71.1  | 77.0  | 81.5  | 84.3  | 83.1  | 75.8  | 65.2  | 55.8  | 48.5 |
|                                                                               | 5%          | WB     | 42.9  | 44.7  | 48.7  | 55.9  | 62.6  | 67.2  | 68.2  | 67.8  | 63.3  | 57.3  | 49.7  | 43.4 |
|                                                                               |             | MCDB   | 46.2  | 49.0  | 55.6  | 67.6  | 73.3  | 78.5  | 81.1  | 80.2  | 73.2  | 62.4  | 52.8  | 45.9 |
|                                                                               | 10%         | WB     | 40.0  | 41.4  | 46.3  | 53.7  | 60.5  | 65.2  | 66.7  | 66.3  | 61.4  | 55.1  | 47.2  | 41.3 |
|                                                                               |             | MCDB   | 42.7  | 45.4  | 52.4  | 63.6  | 69.7  | 75.5  | 78.2  | 77.3  | 69.8  | 59.2  | 49.6  | 43.5 |
| Mean Daily<br>Temperature<br>Range                                            | 5% DB       | MDBR   | 9.8   | 13.7  | 17.7  | 22.8  | 22.6  | 22.5  | 22.9  | 23.8  | 20.6  | 16.1  | 10.8  | 9.1  |
|                                                                               |             | MCDBR  | 12.7  | 18.0  | 28.0  | 31.8  | 30.4  | 30.7  | 31.5  | 31.1  | 28.8  | 22.4  | 16.2  | 12.3 |
|                                                                               |             | MCWBR  | 9.7   | 12.4  | 17.1  | 16.5  | 14.7  | 13.7  | 11.8  | 11.9  | 13.6  | 13.6  | 11.4  | 9.5  |
|                                                                               | 5% WB       | MCDBR  | 12.3  | 16.5  | 24.7  | 29.1  | 27.3  | 27.8  | 27.3  | 26.6  | 26.1  | 20.4  | 14.8  | 11.5 |
|                                                                               |             | MCWBR  | 9.8   | 11.9  | 15.9  | 15.6  | 13.8  | 13.1  | 11.1  | 11.2  | 12.8  | 12.8  | 10.9  | 9.2  |
| Clear-Sky<br>Solar<br>Irradiance                                              | taub        | 0.312  | 0.334 | 0.378 | 0.422 | 0.423 | 0.421 | 0.437 | 0.431 | 0.393 | 0.368 | 0.340 | 0.307 |      |
|                                                                               | taud        | 2.373  | 2.351 | 2.262 | 2.182 | 2.215 | 2.250 | 2.213 | 2.252 | 2.328 | 2.378 | 2.409 | 2.400 |      |
|                                                                               | Ebn at Noon | 227    | 252   | 259   | 259   | 265   | 266   | 259   | 254   | 252   | 236   | 214   | 212   |      |
|                                                                               | Edh at Noon | 20     | 27    | 35    | 42    | 43    | 42    | 43    | 39    | 33    | 26    | 20    | 17    |      |
| All-Sky Solar<br>Radiation                                                    | RadAvg      | 258    | 504   | 815   | 1294  | 1558  | 1676  | 1584  | 1395  | 995   | 576   | 272   | 192   |      |
|                                                                               | RadStd      | 45     | 75    | 124   | 168   | 181   | 141   | 180   | 137   | 136   | 82    | 33    | 19    |      |

**Historical Trends**

|                         |  | DBAvg | Heating |        | Cooling |       |       | Degree-Days |       |       |       |
|-------------------------|--|-------|---------|--------|---------|-------|-------|-------------|-------|-------|-------|
|                         |  |       | 99% DB  | 99% DP | 1% DB   | 1% WB | 1% DP | HDD50       | HDD65 | CDD50 | CDD65 |
|                         |  | (d)   | (e)     | (f)    | (g)     | (h)   | (i)   | (j)         | (k)   | (l)   | (m)   |
| Station Only            |  | +0.86 | N/A     | N/A    | +1.71   | N/A   | +0.72 | N/A         | N/A   | N/A   | N/A   |
| Regional (51 neighbors) |  | +0.74 | N/A     | N/A    | N/A     | +0.61 | +0.63 | N/A         | N/A   | +90   | +29   |