

DOKSANY, Czech Republic

WMO: 115090

Lat: 50.4589N

Lon: 14.1700E

Elev: 160

StdP: 99.42

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-9.7	-15.7	1.0	-11.6	-12.5	1.3	-8.6	11.2	7.1	9.9	6.3	1.5	0	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	31.9	19.9	29.8	19.2	28.0	18.6	21.1	28.8	20.2	27.2	19.4	25.8	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.9	23.0	18.0	13.2	22.1	17.2	12.5	21.6	61.8	28.9	58.6	27.3	55.9	25.9	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	7.6	6.6	DB	-17.0	35.4	4.0	2.3	-19.8	37.0	-22.1	38.4	-24.3	39.7	-27.2	41.3	(4)
(5)			WB	-17.2	23.2	3.9	1.1	-20.1	24.0	-22.4	24.7	-24.6	25.3	-27.5	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-0.5	1.2	4.8	9.9	14.3	17.6	19.7	19.4	14.8	9.7	4.7	0.8	(6)
(7)		DBStd	8.07	4.87	4.50	3.83	3.89	3.48	3.33	3.12	3.03	3.27	3.68	3.57	4.60	(7)
(8)		HDD10.0	1292	324	248	163	49	6	0	0	0	2	50	163	286	(8)
(9)		HDD18.3	3301	582	481	418	254	133	52	22	24	113	267	410	544	(9)
(10)		CDD10.0	1199	1	1	3	45	138	229	299	290	147	42	3	0	(10)
(11)		CDD18.3	165	0	0	0	0	7	32	63	56	8	0	0	0	(11)
(12)		CDH23.3	2133	0	0	0	24	134	424	756	673	119	4	0	0	(12)
(13)		CDH26.7	706	0	0	0	2	28	129	287	236	24	0	0	0	(13)
(14)	Wind	WSAvg	2.7	2.9	2.9	3.2	2.9	2.8	2.5	2.5	2.4	2.4	2.5	2.6	2.8	(14)
(15)	Precipitation	PrecAvg	519	25	22	29	28	57	69	76	43	35	34	31		(15)
(16)		PrecMax	773	57	44	94	58	107	136	137	182	93	72	84	63	(16)
(17)		PrecMin	310	6	4	5	4	10	24	14	17	12	8	1	7	(17)
(18)		PrecStd	94	12	12	18	14	25	26	30	35	22	17	18	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	13.8	19.6	26.2	29.6	33.0	35.0	34.9	29.4	22.9	16.0	11.6	(19)
(20)			MCWB	9.5	9.5	11.1	15.2	18.8	21.0	20.7	20.0	18.6	16.0	12.3	8.9	(20)
(21)		2%	DB	10.1	11.8	16.6	23.2	26.9	30.0	32.2	31.3	26.5	19.6	13.7	9.4	(21)
(22)			MCWB	7.5	8.3	10.0	13.7	17.3	19.6	19.8	19.6	17.6	14.6	10.9	7.3	(22)
(23)		5%	DB	8.1	9.7	14.1	20.9	24.5	27.9	29.9	29.2	24.2	17.4	11.8	7.9	(23)
(24)			MCWB	6.0	6.8	9.0	12.8	16.2	18.9	19.3	19.0	16.7	13.6	9.7	6.1	(24)
(25)		10%	DB	6.1	7.6	11.6	18.4	22.4	25.7	27.6	27.2	21.8	15.5	10.0	6.5	(25)
(26)			MCWB	4.3	5.2	7.7	11.6	14.9	17.8	18.6	18.2	15.7	12.5	8.4	5.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.1	12.3	16.1	20.1	22.8	22.2	21.9	19.7	16.7	13.0	9.2	(27)
(28)			MCDWB	12.2	13.2	17.7	24.1	27.6	30.0	31.1	29.3	25.9	20.8	15.0	11.0	(28)
(29)		2%	WB	7.7	8.7	10.8	14.4	18.3	20.9	21.0	20.8	18.4	15.3	11.2	7.5	(29)
(30)			MCDWB	9.8	11.4	15.4	21.7	25.0	27.5	29.1	28.4	24.3	18.5	13.2	9.2	(30)
(31)		5%	WB	6.1	7.1	9.3	13.3	17.0	19.6	20.1	19.9	17.4	14.1	9.8	6.3	(31)
(32)			MCDWB	7.9	9.4	13.1	19.8	23.0	25.8	27.3	26.8	22.9	16.9	11.5	7.7	(32)
(33)		10%	WB	4.4	5.2	7.9	12.1	15.8	18.5	19.3	19.0	16.3	12.8	8.4	5.2	(33)
(34)			MCDWB	6.0	7.5	11.3	17.6	21.0	24.2	25.6	25.2	21.0	15.1	9.8	6.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	7.6	9.8	12.7	12.6	12.7	13.2	11.5	8.9	6.0	5.1	(35)	
(36)			MCDBR	7.0	10.0	15.6	17.7	16.9	17.0	17.5	17.3	16.0	12.4	9.0	6.8	(36)
(37)			MCWBR	5.4	6.9	9.5	9.2	8.1	7.6	6.5	6.6	7.5	7.6	6.3	5.3	(37)
(38)		5% WB	MCDBR	6.8	9.2	13.7	16.2	15.2	15.4	15.2	14.8	14.5	11.3	8.2	6.4	(38)
(39)			MCWBR	5.4	6.6	8.8	8.6	7.7	7.3	6.1	6.2	7.1	7.1	6.0	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.334	0.378	0.422	0.423	0.421	0.437	0.431	0.393	0.368	0.340	0.307	(40)	
(41)		taud	2.373	2.351	2.262	2.182	2.215	2.250	2.213	2.252	2.328	2.378	2.409	2.400	(41)	
(42)		Ebn at Noon	716	795	816	817	835	838	816	801	793	743	676	667	(42)	
(43)		Edh at Noon	64	84	110	133	135	131	134	123	103	82	63	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.81	1.59	2.57	4.08	4.91	5.28	4.99	4.40	3.14	1.82	0.86	0.60	(44)	
(45)		RadStd	0.14	0.24	0.39	0.53	0.57	0.44	0.57	0.43	0.43	0.26	0.10	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.48	N/A	N/A	+0.95	N/A	+0.40	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)		+0.41	N/A	N/A	N/A	+0.34	+0.35	N/A	N/A	+50	+16

Nomenclature: See separate page