

PRAHA-RUZYNE, Czech Republic

WMO: 115180

Lat: 50.1003N

Lon: 14.2556E

Elev: 365

StdP: 97.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-10.0	-15.6	1.0	-11.4	-12.7	1.3	-9.0	15.1	5.4	13.3	4.1	2.4	340	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	30.1	19.3	28.1	18.6	26.2	17.9	20.4	27.4	19.5	26.1	18.7	24.8	3.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.5	23.1	17.2	12.8	21.8	16.4	12.2	21.1	60.0	27.7	57.1	26.3	54.3	25.0	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.6	8.4	-15.5	33.4	3.6	2.1	-18.1	34.9	-20.1	36.1	-22.1	37.3	-24.7	38.8		
(5)			-15.9	22.3	3.5	1.1	-18.4	23.1	-20.4	23.7	-22.4	24.3	-25.0	25.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-1.1	0.4	4.1	9.0	13.3	16.6	18.7	18.4	14.0	9.0	3.9	0.2	(6)
(7)		DBStd	8.06	4.93	4.84	4.19	4.23	3.66	3.66	3.37	3.23	3.41	3.78	3.76	4.58	(7)
(8)		HDD10.0	1434	344	268	187	67	11	1	0	0	5	65	184	303	(8)
(9)		HDD18.3	3554	602	501	442	279	160	76	37	38	137	290	432	561	(9)
(10)		CDD10.0	1047	0	1	3	38	114	199	271	262	124	33	2	0	(10)
(11)		CDD18.3	125	0	0	0	0	4	24	49	42	6	0	0	0	(11)
(12)		CDH23.3	1242	0	0	0	7	59	246	474	402	53	1	0	0	(12)
(13)		CDH26.7	343	0	0	0	1	7	63	148	116	8	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.5	4.4	4.5	3.9	3.6	3.4	3.5	3.3	3.6	3.6	3.8	4.3	(14)
(15)	Precipitation	PrecAvg	488	21	18	27	31	68	69	71	67	39	32	29	25	(15)
(16)		PrecMax	706	58	46	89	82	166	141	227	173	95	109	81	50	(16)
(17)		PrecMin	306	4	1	6	3	18	15	4	16	4	6	7	2	(17)
(18)		PrecStd	89	11	10	14	17	36	32	43	35	22	23	14	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	12.7	18.2	24.2	27.7	31.5	33.1	33.0	27.9	21.8	14.8	10.8	(19)
(20)			MCWB	8.5	8.1	11.0	14.5	18.0	20.2	19.4	19.9	18.2	15.3	11.6	8.6	(20)
(21)		2%	DB	9.1	10.5	15.0	21.3	25.0	28.4	30.2	29.6	24.7	18.5	12.6	9.3	(21)
(22)			MCWB	7.1	7.4	9.1	13.1	16.7	19.2	19.2	19.1	16.9	13.9	10.1	7.5	(22)
(23)		5%	DB	7.3	8.8	12.6	19.0	22.6	26.1	28.1	27.4	22.4	16.5	10.9	7.7	(23)
(24)			MCWB	5.5	6.3	8.1	12.0	15.5	18.0	18.6	18.4	15.9	12.9	8.9	6.0	(24)
(25)		10%	DB	5.3	6.9	10.3	16.8	20.6	24.0	25.9	25.4	20.2	14.6	9.2	6.0	(25)
(26)			MCWB	3.9	4.8	7.0	10.8	14.4	17.2	18.0	17.7	15.0	12.1	7.6	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.1	11.3	15.4	19.2	22.0	21.3	21.2	18.8	16.0	12.0	9.1	(27)
(28)			MCDWB	11.1	11.9	16.6	23.1	25.9	29.0	29.5	28.7	25.4	20.1	14.6	10.4	(28)
(29)		2%	WB	7.2	7.7	9.9	13.6	17.5	20.1	20.2	20.1	17.5	14.5	10.4	7.7	(29)
(30)			MCDWB	8.9	10.0	13.9	20.0	23.3	26.5	27.2	27.2	23.0	17.6	12.3	9.2	(30)
(31)		5%	WB	5.6	6.3	8.7	12.5	16.1	18.8	19.4	19.2	16.6	13.4	9.1	6.1	(31)
(32)			MCDWB	7.2	8.5	11.9	18.1	21.6	24.8	26.1	25.8	21.3	15.9	10.8	7.5	(32)
(33)		10%	WB	4.0	4.9	7.3	11.2	15.0	17.6	18.6	18.3	15.6	12.2	7.7	4.7	(33)
(34)			MCDWB	5.3	6.9	10.1	16.0	19.8	22.9	24.7	24.0	19.6	14.4	9.0	5.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	6.2	7.9	10.1	10.3	10.4	10.6	10.8	9.3	7.6	5.2	4.5	(35)
(36)			MCDBR	6.2	8.2	12.1	13.9	13.9	14.2	14.5	14.2	13.0	10.4	7.4	6.1	(36)
(37)			MCWBR	5.0	5.7	7.3	7.2	7.2	6.6	5.6	5.8	6.4	6.4	5.4	4.9	(37)
(38)		5% WB	MCDWB	6.0	7.6	10.7	12.9	12.7	12.9	12.5	12.4	11.7	9.8	7.0	6.0	(38)
(39)			MCWBR	5.0	5.6	6.9	7.1	7.0	6.4	5.4	5.6	6.1	6.3	5.4	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.322	0.363	0.404	0.405	0.405	0.419	0.413	0.379	0.355	0.328	0.297	(40)	
(41)		taud	2.400	2.382	2.308	2.231	2.258	2.284	2.250	2.288	2.356	2.408	2.440	2.431	(41)	
(42)		Ebn at Noon	741	815	836	837	853	854	834	820	811	764	701	693	(42)	
(43)		Edh at Noon	63	82	106	127	129	127	129	119	100	80	61	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.85	1.66	2.65	4.13	4.95	5.34	5.07	4.48	3.19	1.86	0.89	0.64	(44)	
(45)		RadStd	0.15	0.24	0.40	0.54	0.57	0.44	0.56	0.44	0.43	0.26	0.11	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.48	N/A	N/A	N/A	+0.40	N/A	N/A	-164	+90	+36
(47)	Regional (61 neighbors)	+0.43	N/A	N/A	N/A	+0.33	+0.32	N/A	N/A	+54	+19

Nomenclature: See separate page