

PRAHA-KARLOV, Czech Republic

WMO: 115190

Lat: 50.0692N

Lon: 14.4278E

Elev: 833

StdP: 14.26

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.1	(c) 18.4	(d) 5.4	(e) 7.5	(f) 16.9	(g) 11.0	(h) 9.9	(i) 21.6	(j) 25.0	(k) 43.3	(l) 22.7	(m) 43.3	(n) 4.8	(o) 220	(p) 0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	90.5	68.2	86.5	66.4	83.1	65.3	69.9	84.5	68.3	82.3	66.8	80.0	6.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	96.1	75.4	63.6	90.7	73.2	62.1	86.1	71.9	34.3	84.7	33.0	82.1	31.8	80.0	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.6	(b) 17.9	(c) 15.5	(e) 9.8	(f) 96.4	(g) 6.2	(h) 3.3	(i) 5.3	(j) 98.8	(k) 1.7	(l) 100.7	(m) -1.7	(n) 102.5	(o) -6.2	(p) 104.9		
(a) 20.6	(b) 17.9	(c) 15.5	(e) 8.9	(f) 73.9	(g) 6.2	(h) 2.3	(i) 4.4	(j) 75.6	(k) 0.8	(l) 77.0	(m) -2.6	(n) 78.3	(o) -7.1	(p) 80.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	33.2	35.3	42.8	52.6	59.0	66.1	69.6	68.8	59.8	50.5	42.6	36.2
	DBStd	14.55	7.89	8.21	7.18	7.43	7.05	6.61	6.21	6.28	6.38	6.62	6.71	7.45
	HDD50	1978	520	413	238	58	10	0	0	0	2	76	234	427
	HDD65	5406	984	832	688	376	211	64	26	30	182	451	671	891
	CDD50	2514	0	1	15	135	289	484	606	583	296	91	14	0
	CDD65	471	0	0	0	3	26	98	167	149	27	1	0	0
	CDH74	4392	0	0	0	55	243	891	1570	1393	233	7	0	0
	CDH80	1495	0	0	0	9	46	284	586	517	53	0	0	0
Wind	WSAvg	6.9	7.7	7.1	7.9	6.7	6.5	6.7	6.8	5.9	6.2	6.2	6.9	7.6
Precipitation	PrecAvg	20.5	1.0	0.8	1.1	1.2	2.5	3.2	3.0	2.8	1.8	1.3	1.3	1.1
	PrecMax	30.4	2.2	2.0	3.6	2.8	6.0	7.7	6.8	7.3	4.3	3.3	3.0	2.1
	PrecMin	11.7	0.3	0.1	0.2	0.0	0.6	0.7	0.2	0.3	0.2	0.3	0.2	0.0
	PrecStd	3.9	0.5	0.5	0.6	0.7	1.2	1.5	1.6	1.6	1.0	0.8	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	57.8	68.7	80.2	84.5	93.3	94.9	95.5	85.5	74.6	62.8	53.5
		MCWB	48.2	45.6	52.0	60.0	65.1	70.6	68.8	67.6	65.9	59.7	55.2	48.0
	2%	DB	50.1	53.0	63.4	74.6	80.4	87.2	90.3	90.1	80.4	68.3	58.6	50.9
		MCWB	45.5	45.7	50.1	56.5	62.8	68.2	68.0	67.8	63.6	57.7	52.3	46.5
	5%	DB	46.7	49.7	59.0	70.8	76.2	82.6	86.6	85.5	75.9	64.3	55.1	48.1
		MCWB	42.2	43.4	47.8	55.0	61.1	65.0	66.0	66.3	62.0	56.0	49.4	43.7
	10%	DB	43.7	46.1	54.2	66.9	72.5	79.0	82.5	81.8	71.5	60.5	52.2	45.7
		MCWB	40.1	40.7	45.8	53.1	58.8	63.4	64.9	65.4	59.8	54.0	47.4	42.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	48.7	53.5	61.1	66.9	73.5	71.8	72.0	67.1	61.5	55.7	48.9
		MCDB	52.5	53.8	65.2	78.2	80.7	89.1	87.1	87.9	80.6	71.2	61.0	52.7
	2%	WB	45.6	45.8	51.3	57.8	64.4	69.5	69.4	69.4	64.6	58.8	52.9	46.6
		MCDB	49.8	52.0	61.5	71.5	77.6	83.7	83.8	84.0	77.5	66.7	58.3	50.6
	5%	WB	42.8	43.4	48.9	55.9	62.0	66.9	68.0	68.0	62.9	56.7	50.1	44.0
		MCDB	46.0	49.3	58.1	68.4	74.1	79.9	82.3	82.3	73.5	63.0	54.1	47.5
	10%	WB	40.4	40.7	46.2	54.0	60.1	64.6	66.6	66.4	61.0	54.8	47.9	42.2
		MCDB	43.5	45.9	53.4	65.5	70.5	75.5	79.3	79.3	69.5	60.1	51.5	45.4
Mean Daily Temperature Range	5% DB	MDBR	7.5	10.4	13.9	17.9	17.2	17.6	18.5	19.1	16.2	13.0	8.7	7.5
		MCDBR	10.6	15.8	24.8	25.2	23.8	24.7	25.4	25.5	23.7	19.6	13.0	9.9
		MCWBR	7.7	10.1	13.7	11.4	10.1	9.7	8.1	8.5	9.9	10.5	8.4	7.2
	5% WB	MCDBR	10.3	15.0	22.0	23.3	21.9	22.8	22.2	22.6	21.1	18.0	12.0	9.8
		MCWBR	7.9	10.3	12.6	11.1	9.8	9.6	8.1	8.3	9.5	10.0	8.5	7.5
Clear-Sky Solar Irradiance	taub	0.308	0.329	0.371	0.413	0.414	0.414	0.429	0.423	0.388	0.362	0.334	0.303	
	taud	2.387	2.366	2.287	2.206	2.237	2.267	2.233	2.270	2.339	2.390	2.423	2.419	
	Ebn at Noon	232	256	262	263	268	268	262	257	254	239	219	217	
	Edh at Noon	20	27	34	41	42	41	42	38	32	26	20	17	
All-Sky Solar Radiation	RadAvg	270	528	845	1315	1577	1701	1610	1426	1016	589	281	202	
	RadStd	47	75	130	172	180	139	178	141	137	84	35	22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (63 neighbors)	+0.79	N/A	N/A	N/A	N/A	+0.59	+0.58	N/A	N/A	+101

Nomenclature: See separate page