

PRAHA-KARLOV, Czech Republic

WMO: 115190

Lat: 50.0692N

Lon: 14.4278E

Elev: 254

StdP: 98.31

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-7.6	-14.8	1.1	-8.4	-11.7	1.4	-5.8	11.2	6.3	10.2	6.3	2.1	220	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	32.5	20.1	30.3	19.1	28.4	18.5	21.1	29.2	20.2	28.0	19.3	26.6	2.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.7	24.1	17.6	13.0	22.9	16.7	12.3	22.2	61.9	29.3	58.9	27.9	56.0	26.7	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.0	6.9	-12.3	35.8	3.4	1.8	-14.8	37.1	-16.8	38.2	-18.7	39.2	-21.2	40.5		
(5)			-12.9	23.3	3.4	1.3	-15.3	24.2	-17.3	25.0	-19.2	25.7	-21.7	26.7		

Monthly Climatic Design Conditions

		Annual													
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	0.7	1.8	6.0	11.4	15.0	19.0	20.9	20.5	15.5	10.3	5.9	2.4
(7)		DBStd	8.09	4.38	4.56	3.99	4.13	3.92	3.67	3.45	3.49	3.54	3.68	3.73	4.14
(8)		HDD10.0	1099	289	229	132	32	6	0	0	0	1	42	130	237
(9)		HDD18.3	3003	547	462	382	209	117	36	14	17	101	251	373	495
(10)		CDD10.0	1397	0	1	8	75	161	269	337	324	164	51	8	0
(11)		CDD18.3	262	0	0	0	2	14	54	93	83	15	1	0	0
(12)		CDH23.3	2440	0	0	0	31	135	495	872	774	129	4	0	0
(13)		CDH26.7	831	0	0	0	5	26	158	326	287	29	0	0	0
(14)	Wind	WSAvg	3.1	3.4	3.2	3.5	3.0	2.9	3.0	3.0	2.6	2.8	2.8	3.1	3.4
(15)	Precipitation	PrecAvg	521	25	21	29	30	63	81	76	72	46	33	32	27
(16)		PrecMax	773	56	50	92	71	152	195	172	186	108	84	75	53
(17)		PrecMin	296	7	3	6	1	14	18	5	7	4	7	6	1
(18)		PrecStd	100	12	12	16	17	31	38	40	41	26	20	15	14
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	12.1	14.3	20.4	26.8	29.2	34.0	35.0	35.3	29.7	23.7	17.1	11.9	
(20)		0.4% MCWB	9.0	7.5	11.1	15.6	18.4	21.4	20.5	19.8	18.8	15.4	12.9	8.9	
(21)		2% DB	10.0	11.6	17.5	23.6	26.9	30.7	32.4	32.3	26.9	20.2	14.8	10.5	
(22)		2% MCWB	7.5	7.6	10.0	13.6	17.1	20.1	20.0	19.9	17.6	14.3	11.3	8.1	
(23)		5% DB	8.1	9.8	15.0	21.6	24.6	28.1	30.3	29.7	24.4	17.9	12.8	8.9	
(24)		5% MCWB	5.7	6.3	8.8	12.8	16.2	18.3	18.9	19.0	16.7	13.3	9.7	6.5	
(25)		10% DB	6.5	7.8	12.3	19.4	22.5	26.1	28.0	27.7	21.9	15.8	11.2	7.6	
(26)		10% MCWB	4.5	4.8	7.6	11.7	14.9	17.4	18.3	18.6	15.4	12.2	8.6	5.5	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	9.3	9.3	11.9	16.2	19.4	23.1	22.1	22.2	19.5	16.4	13.1	9.4	
(28)		0.4% MCDB	11.4	12.1	18.4	25.7	27.1	31.7	30.6	31.1	27.0	21.8	16.1	11.5	
(29)		2% WB	7.6	7.7	10.7	14.3	18.0	20.8	20.8	20.8	18.1	14.9	11.6	8.1	
(30)		2% MCDB	9.9	11.1	16.4	21.9	25.3	28.7	28.8	28.9	25.3	19.3	14.6	10.3	
(31)		5% WB	6.0	6.4	9.4	13.3	16.7	19.4	20.0	20.0	17.2	13.7	10.1	6.7	
(32)		5% MCDB	7.8	9.6	14.5	20.2	23.4	26.6	27.9	27.9	23.1	17.2	12.3	8.6	
(33)		10% WB	4.7	4.8	7.9	12.2	15.6	18.1	19.2	19.1	16.1	12.7	8.8	5.7	
(34)		10% MCDB	6.4	7.7	11.9	18.6	21.4	24.2	26.3	26.3	20.8	15.6	10.8	7.4	
(35)	Mean Daily Temperature Range	MDBR	4.2	5.8	7.7	9.9	9.6	9.8	10.3	10.6	9.0	7.2	4.8	4.2	
(36)		5% DB MCDBR	5.9	8.8	13.8	14.0	13.2	13.7	14.1	14.2	13.2	10.9	7.2	5.5	
(37)		5% WB MCWBR	4.3	5.6	7.6	6.3	5.6	5.4	4.5	4.7	5.5	5.9	4.7	4.0	
(38)		5% WB MCDBR	5.7	8.3	12.2	12.9	12.2	12.7	12.3	12.5	11.7	10.0	6.7	5.4	
(39)	Clear-Sky Solar Irradiance	taub	0.308	0.329	0.371	0.413	0.414	0.414	0.429	0.423	0.388	0.362	0.334	0.303	
(40)		taud	2.387	2.366	2.287	2.206	2.237	2.267	2.233	2.270	2.339	2.390	2.423	2.419	
(41)		Ebn at Noon	731	806	827	828	844	845	825	811	801	754	691	683	
(42)		Edh at Noon	64	84	108	130	132	129	132	121	102	82	63	55	
(43)	All-Sky Solar Radiation	RadAvg	0.85	1.67	2.66	4.15	4.97	5.36	5.08	4.50	3.20	1.86	0.89	0.64	
(44)		RadStd	0.15	0.24	0.41	0.54	0.57	0.44	0.56	0.45	0.43	0.27	0.11	0.07	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A		N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	+0.44	N/A	N/A	N/A	+0.33	+0.32	N/A	N/A	+56	+20

Nomenclature: See separate page