

CESKE BUDEJOVICE-ROZNOV, Czech Republic

WMO: 115460

Lat: 48.9519N

Lon: 14.4697E

Elev: 1323

StdP: 14.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.0	(c) 14.9	(d) 4.0	(e) 7.1	(f) 10.9	(g) 9.3	(h) 9.3	(i) 17.6	(j) 21.0	(k) 42.5	(l) 17.8	(m) 41.7	(n) 2.4	(o) 160	(p) 0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 21.5	(c) 88.8	(d) 67.2	(e) 85.0	(f) 66.2	(g) 81.8	(h) 65.1	(i) 69.3	(j) 83.1	(k) 67.8	(l) 81.1	(m) 66.4	(n) 78.4	(o) 5.8	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	97.5	73.0	63.6	92.5	71.6	62.2	88.0	70.6	34.2	83.4	32.9	81.3	31.7	78.4	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	13.1	11.3	3.3	94.4	7.0	2.7	-1.7	96.3	-5.8	97.9	-9.7	99.4	-14.8	101.3
			2.9	72.6	6.7	1.6	-1.9	73.8	-5.9	74.7	-9.7	75.6	-14.6	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	31.7	33.1	40.5	49.3	56.8	64.0	67.3	66.3	57.9	49.0	40.6	33.8
	DBStd	14.51	9.16	8.69	7.66	7.19	6.59	6.62	5.63	5.95	5.97	6.92	6.76	7.46
	HDD50	2362	567	474	302	98	16	0	0	0	8	106	289	502
	HDD65	6035	1032	893	759	472	264	97	42	57	223	498	731	967
	CDD50	2099	0	1	8	76	227	420	537	504	245	74	7	0
	CDD65	300	0	0	0	1	11	67	114	96	10	1	0	0
	CDH74	3359	0	0	0	33	171	742	1233	1036	139	5	0	0
	CDH80	1084	0	0	0	4	31	225	432	367	25	0	0	0
(14) Wind	WSAvg	4.9	5.4	5.2	5.6	5.3	5.1	4.7	4.7	4.2	4.2	4.3	4.7	5.1
(15) Precipitation	PrecAvg	26.9	1.4	1.2	1.8	1.6	2.9	3.7	3.8	3.5	2.3	1.9	1.6	1.4
	PrecMax	42.3	3.0	2.8	4.1	3.1	5.6	7.3	6.9	14.8	6.0	3.9	2.5	2.8
	PrecMin	20.6	0.3	0.2	0.3	0.2	0.4	1.2	1.1	0.9	0.3	0.4	0.1	0.3
	PrecStd	4.3	0.7	0.7	0.9	0.8	1.1	1.5	1.5	2.6	1.1	1.0	0.6	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	58.7	68.1	78.5	83.9	90.6	93.5	93.6	83.9	73.6	61.8	53.9
		MCWB	47.2	46.4	51.4	59.4	64.1	68.3	67.4	67.7	65.4	59.1	53.6	47.1
	2%	DB	50.8	53.0	62.3	72.4	78.7	86.3	88.8	88.3	78.2	68.0	57.4	50.4
		MCWB	45.0	44.8	49.3	55.6	62.3	67.6	66.9	67.0	63.3	57.8	50.7	45.5
	5%	DB	47.0	49.3	57.6	68.4	74.4	82.1	84.8	83.9	73.8	63.7	53.7	46.7
		MCWB	42.1	43.0	47.2	54.0	60.2	64.9	66.0	66.1	61.5	55.8	49.4	42.3
	10%	DB	43.5	45.1	53.2	64.4	70.5	78.2	81.3	79.8	69.8	60.0	50.2	43.7
		MCWB	39.7	39.9	45.3	52.0	58.0	63.5	65.4	64.6	59.6	54.2	46.6	40.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	48.2	52.8	59.6	66.6	72.1	71.0	70.8	66.4	61.7	54.8	48.3
		MCDB	53.7	56.0	63.7	75.4	79.4	84.5	85.4	86.8	79.3	70.4	60.0	52.9
	2%	WB	45.3	45.4	50.2	56.6	63.7	69.1	69.1	68.8	64.5	58.9	51.9	45.8
		MCDB	50.3	51.8	59.7	69.8	75.7	81.7	82.5	83.7	76.2	65.1	56.1	50.1
	5%	WB	42.5	43.0	48.2	54.8	61.5	66.8	67.7	67.3	62.6	56.7	49.4	42.8
		MCDB	46.5	49.3	56.5	66.2	72.0	78.5	80.5	80.6	71.3	62.6	53.4	46.2
	10%	WB	40.0	40.3	45.8	52.7	59.4	64.9	66.3	65.7	60.9	54.8	46.9	40.6
		MCDB	43.2	45.1	52.4	62.9	68.6	75.3	78.3	77.1	68.4	59.6	49.8	43.4
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	13.1	16.9	21.0	20.1	20.4	21.5	21.2	19.0	16.0	10.8	10.3
		MCDBR	14.6	19.7	27.1	29.5	27.6	28.1	29.1	28.9	26.1	22.4	17.0	14.7
	5% WB	MCWBR	10.4	12.3	15.4	14.7	12.9	11.1	10.6	11.2	12.5	13.0	11.2	10.5
		MCDWR	13.6	19.1	23.8	27.4	25.2	24.9	24.3	26.0	22.5	20.7	15.9	14.0
(40) Clear-Sky Solar Irradiance	taub		0.298	0.322	0.364	0.403	0.407	0.408	0.419	0.413	0.384	0.354	0.326	0.297
		taud	2.385	2.352	2.294	2.231	2.260	2.289	2.261	2.294	2.343	2.404	2.435	2.434
	Ebn at Noon		241	262	267	267	271	271	266	261	258	246	229	227
		Edh at Noon	21	28	35	41	41	40	41	38	33	26	20	18
(44) All-Sky Solar Radiation	RadAvg		304	584	914	1354	1585	1729	1659	1477	1051	639	318	236
	RadStd		51	78	128	172	183	147	165	148	138	80	36	27

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (91 neighbors)		+0.90	N/A	N/A	N/A	+0.65	+0.59	N/A	N/A	+50

Nomenclature: See separate page