

CESKE BUDEJOVICE-ROZNOV, Czech Republic

WMO: 115460

Lat: 48.9519N

Lon: 14.4697E

Elev: 403

StdP: 96.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.8	-9.5	-15.5	1.0	-11.7	-12.6	1.3	-8.0	9.4	5.8	8.0	5.4	1.1	160	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	31.6	19.6	29.5	19.0	27.6	18.4	20.7	28.4	19.9	27.3	19.1	25.8	2.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.9	22.8	17.6	13.2	22.0	16.8	12.6	21.4	61.6	28.5	58.6	27.4	55.9	25.8	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	5.9	5.1	-15.9	34.7	3.9	1.5	-18.7	35.7	-21.0	36.6	-23.2	37.4	-26.0	38.5		
			-16.2	22.6	3.7	0.9	-18.9	23.2	-21.1	23.7	-23.2	24.2	-25.9	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.2	0.6	4.7	9.6	13.8	17.8	19.6	19.0	14.4	9.4	4.8	1.0
	DBStd	8.06	5.09	4.83	4.25	4.00	3.66	3.68	3.13	3.31	3.32	3.85	3.76	4.14
	HDD10.0	1312	315	263	168	54	9	0	0	4	59	161	279	
	HDD18.3	3353	573	496	422	262	147	54	23	124	277	406	537	
	CDD10.0	1166	0	1	4	42	126	233	298	280	136	41	4	0
	CDD18.3	167	0	0	0	1	6	37	63	53	6	1	0	0
	CDH23.3	1866	0	0	0	18	95	412	685	576	77	3	0	0
	CDH26.7	602	0	0	0	2	17	125	240	204	14	0	0	0
Wind	WSAvg	2.2	2.4	2.3	2.5	2.3	2.3	2.1	2.1	1.9	1.9	1.9	2.1	2.3
Precipitation	PrecAvg	684	36	30	46	41	74	93	96	88	58	47	40	36
	PrecMax	1075	75	70	103	78	142	186	176	377	153	99	64	70
	PrecMin	523	8	6	8	5	9	30	28	24	7	9	2	7
	PrecStd	110	19	19	22	20	29	37	38	65	28	25	16	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.8	20.1	25.9	28.9	32.5	34.2	34.2	28.8	23.1	16.6	12.2
		MCWB	8.4	8.0	10.8	15.2	17.9	20.2	19.7	19.8	18.6	15.1	12.0	8.4
	2%	DB	10.5	11.6	16.8	22.5	25.9	30.2	31.5	31.3	25.6	20.0	14.1	10.2
		MCWB	7.2	7.1	9.6	13.1	16.8	19.8	19.4	19.4	17.4	14.3	10.4	7.5
	5%	DB	8.3	9.6	14.2	20.2	23.6	27.8	29.4	28.8	23.2	17.6	12.0	8.2
		MCWB	5.6	6.1	8.5	12.2	15.7	18.3	18.9	19.0	16.4	13.2	9.7	5.7
	10%	DB	6.4	7.3	11.8	18.0	21.4	25.6	27.4	26.5	21.0	15.6	10.1	6.5
		MCWB	4.3	4.4	7.4	11.1	14.4	17.5	18.6	18.1	15.3	12.3	8.1	4.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.0	11.6	15.3	19.2	22.3	21.7	21.5	19.1	16.5	12.7	9.1
		MCDB	12.1	13.3	17.6	24.1	26.3	29.2	29.7	30.4	26.3	21.4	15.6	11.6
	2%	WB	7.4	7.4	10.1	13.7	17.6	20.6	20.6	20.5	18.0	14.9	11.1	7.6
		MCDB	10.2	11.0	15.4	21.0	24.3	27.6	28.0	28.7	24.5	18.4	13.4	10.1
	5%	WB	5.8	6.1	9.0	12.6	16.4	19.4	19.8	19.6	17.0	13.7	9.7	6.0
		MCDB	8.1	9.6	13.6	19.0	22.2	25.8	27.0	27.0	21.8	17.0	11.9	7.9
	10%	WB	4.5	4.6	7.7	11.5	15.2	18.3	19.0	18.7	16.1	12.6	8.3	4.8
		MCDB	6.2	7.3	11.3	17.2	20.4	24.1	25.7	25.1	20.2	15.3	9.9	6.4
Mean Daily Temperature Range	5% DB	MDBR	5.8	7.3	9.4	11.6	11.2	11.3	11.9	11.8	10.6	8.9	6.0	5.7
		MCDBR	8.1	10.9	15.1	16.4	15.4	15.6	16.2	16.1	14.5	12.5	9.4	8.2
		MCWBR	5.8	6.8	8.6	8.2	7.2	6.2	5.9	6.2	6.9	7.2	6.2	5.9
	5% WB	MCDBR	7.6	10.6	13.2	15.2	14.0	13.9	13.5	14.4	12.5	11.5	8.8	7.8
		MCWBR	5.5	6.8	7.9	7.8	6.9	5.9	5.4	5.9	6.4	7.0	6.1	5.7
Clear-Sky Solar Irradiance	taub	0.298	0.322	0.364	0.403	0.407	0.408	0.419	0.413	0.384	0.354	0.326	0.297	
	taud	2.385	2.352	2.294	2.231	2.260	2.289	2.261	2.294	2.343	2.404	2.435	2.434	
	Ebn at Noon	761	825	842	843	854	854	837	824	812	776	721	715	
	Edh at Noon	66	87	109	128	130	127	129	119	103	82	64	56	
All-Sky Solar Radiation	RadAvg	0.96	1.84	2.88	4.27	5.00	5.45	5.23	4.66	3.31	2.01	1.00	0.74	
	RadStd	0.16	0.24	0.40	0.54	0.58	0.46	0.52	0.47	0.43	0.25	0.12	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (91 neighbors)	+0.50	N/A	N/A	N/A	+0.36	+0.33	N/A	N/A	+66	+28

Nomenclature: See separate page