

PRAHA-KBELY, Czech Republic

WMO: 115670

Lat: 50.1233N

Lon: 14.5381E

Elev: 286

StdP: 97.94

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.1	-9.5	-15.1	1.0	-10.9	-12.2	1.4	-8.2	11.4	6.2	10.4	5.3	1.6	70	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	30.3	19.7	28.4	18.9	26.7	18.3	20.9	27.4	20.0	26.1	19.2	24.8	3.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	14.2	22.8	18.0	13.4	22.0	17.2	12.7	21.4	61.4	27.5	58.3	26.1	55.6	24.8	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	7.0	-15.1	34.0	3.4	2.1	-17.5	35.5	-19.5	36.7	-21.4	37.9	-23.9	39.4		
(5)			-15.4	22.9	3.4	1.3	-17.8	23.9	-19.8	24.7	-21.6	25.4	-24.1	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.6	1.1	4.6	9.8	14.2	17.6	19.5	19.3	14.6	9.5	4.5	0.7		
	DBStd	8.15	5.12	4.70	4.13	4.11	3.60	3.52	3.25	3.20	3.39	3.76	3.74	4.62		
	HDD10.0	1322	329	251	170	53	6	0	0	0	3	54	168	287		
	HDD18.3	3347	588	483	424	258	134	56	26	27	120	273	415	545		
	CDD10.0	1182	0	1	4	46	138	228	293	287	141	41	3	0		
	CDD18.3	164	0	0	0	1	7	33	61	55	8	1	0	0		
	CDH23.3	1415	0	0	0	9	79	276	508	474	68	1	0	0		
	CDH26.7	397	0	0	0	1	11	70	158	146	12	0	0	0		
(14) Wind	WSAvg	3.0	3.5	3.4	3.4	3.0	2.8	2.7	2.8	2.5	2.6	2.8	3.0	3.4		
(15) Precipitation	PrecAvg	555	29	25	34	29	62	76	78	70	47	36	36	33		
	PrecMax	827	58	50	102	64	135	175	133	177	96	80	77	58		
	PrecMin	361	7	3	7	3	15	21	6	27	13	6	1	8		
	PrecStd	102	14	13	20	15	29	29	31	37	26	19	18	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.3	18.7	24.8	28.1	31.5	33.2	33.7	28.3	22.3	15.5	11.2		
		MCWB	9.1	8.6	11.1	15.6	18.7	21.0	20.3	19.8	18.3	15.3	12.3	8.8		
	2%	DB	10.1	11.3	15.7	21.8	25.7	28.7	30.3	30.1	25.2	19.0	13.1	9.7		
		MCWB	7.8	8.0	9.8	13.6	17.2	19.7	19.5	19.4	17.3	14.3	10.8	7.6		
	5%	DB	8.1	9.7	13.3	19.5	23.3	26.5	28.2	27.9	23.0	17.0	11.5	8.0		
		MCWB	6.2	7.0	8.7	12.5	16.0	18.4	18.9	18.8	16.3	13.5	9.4	6.4		
	10%	DB	6.1	7.7	11.1	17.1	21.3	24.4	26.1	25.9	20.9	15.1	9.9	6.6		
		MCWB	4.6	5.4	7.6	11.2	14.8	17.6	18.3	18.1	15.5	12.7	8.4	5.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	9.6	12.0	15.9	19.7	22.5	21.9	21.7	19.6	16.6	12.9	9.4		
		MCDB	11.9	12.1	16.8	23.7	26.3	28.7	29.5	28.0	25.4	19.8	15.0	10.7		
	2%	WB	8.0	8.4	10.5	14.3	18.0	20.7	20.6	20.6	18.1	15.2	11.1	7.8		
		MCDB	9.8	10.9	14.4	20.4	23.5	26.6	27.4	26.9	23.3	17.9	12.8	9.5		
	5%	WB	6.3	7.0	9.2	13.1	16.7	19.4	19.8	19.7	17.1	14.0	9.7	6.4		
		MCDB	8.0	9.4	12.4	18.6	22.0	24.8	26.0	25.6	21.7	16.5	11.1	7.7		
	10%	WB	4.7	5.5	7.9	11.9	15.6	18.2	19.0	18.9	16.1	12.9	8.4	5.2		
		MCDB	6.0	7.5	10.8	16.6	20.3	23.0	24.5	24.3	20.1	15.1	9.6	6.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	6.1	8.0	9.9	9.9	9.6	9.6	10.2	9.0	7.4	5.2	4.6		
		MCDBR	6.5	8.1	12.4	13.8	13.5	13.4	13.5	13.7	12.8	10.3	7.2	6.4		
	5% WB	MCWBR	5.1	5.4	7.3	7.1	6.6	5.9	5.0	5.1	6.0	6.2	5.2	5.0		
		MCWBR	6.3	7.6	10.8	12.7	12.3	12.2	11.8	11.7	11.1	9.7	6.8	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.326	0.367	0.409	0.410	0.410	0.425	0.419	0.384	0.359	0.332	0.301		
		taud	2.390	2.370	2.296	2.218	2.247	2.275	2.241	2.278	2.347	2.397	2.429	2.422		
	Ebn at Noon		734	810	831	832	848	849	828	814	805	758	694	686		
		Edh at Noon	64	83	107	129	131	128	131	120	101	81	62	54		
(44) All-Sky Solar Radiation	RadAvg		0.85	1.65	2.65	4.14	4.97	5.36	5.07	4.49	3.20	1.85	0.88	0.63		
	RadStd		0.15	0.23	0.41	0.54	0.57	0.44	0.57	0.44	0.43	0.27	0.11	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.87	+0.62	N/A	N/A	N/A	N/A	+39
(47) Regional (60 neighbors)		+0.45	N/A	N/A	N/A	+0.34	+0.33	N/A	N/A	+58	+20

Nomenclature: See separate page