

CASLAV, Czech Republic

WMO: 116240

Lat: 49.9408N

Lon: 15.3864E

Elev: 786

StdP: 14.28

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	14.8	4.2	7.0	12.3	9.3	9.1	16.7	27.8	44.5	24.8	41.8	2.5	310	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	87.8	68.4	84.4	67.3	81.1	65.9	70.5	83.2	68.9	81.0	67.4	78.3	7.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	100.2	74.9	64.9	94.7	73.1	63.5	90.3	71.8	34.8	83.0	33.5	81.5	32.3	78.6	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	18.9	16.5	DB	3.7	93.3	6.9	3.2	-1.3	95.6	-5.3	97.5	-9.1	99.3	-14.1	101.6	(4)
(5)			WB	3.1	73.6	6.9	1.4	-1.8	74.6	-5.8	75.4	-9.7	76.2	-14.7	77.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.7	31.2	34.2	40.7	49.8	57.9	63.9	67.2	67.0	58.9	49.8	41.2	34.2	(6)
(7)		DBStd	14.59	9.30	8.62	7.46	7.48	6.62	6.30	5.76	5.83	6.11	7.02	6.99	7.86	(7)
(8)		HDD50	2286	585	443	296	94	10	0	0	4	91	274	489		(8)
(9)		HDD65	5880	1049	862	752	457	236	95	43	45	200	472	715	954	(9)
(10)		CDD50	2194	1	1	9	88	255	416	533	526	271	85	9	0	(10)
(11)		CDD65	312	0	0	0	1	16	61	111	106	16	1	0	0	(11)
(12)		CDH74	3125	0	0	0	25	191	608	1095	1045	159	2	0	0	(12)
(13)		CDH80	941	0	0	0	1	32	162	373	344	29	0	0	0	(13)
(14)	Wind	WSAvg	6.7	7.7	7.5	7.8	6.9	6.4	5.8	6.0	5.4	5.7	6.3	7.0	7.7	(14)
(15)	Precipitation	PrecAvg	24.0	1.4	1.1	1.7	1.3	2.7	2.9	3.5	2.9	2.0	1.5	1.5	1.5	(15)
(16)		PrecMax	31.2	2.5	2.3	4.6	2.9	4.9	6.1	8.9	6.5	4.3	3.4	3.3	2.8	(16)
(17)		PrecMin	18.0	0.4	0.2	0.4	0.1	0.4	0.8	0.5	1.2	0.4	0.2	0.0	0.4	(17)
(18)		PrecStd	3.5	0.6	0.7	0.9	0.6	1.1	1.1	1.7	1.4	1.2	0.7	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	56.6	65.9	77.4	83.9	89.7	92.8	93.0	83.8	72.4	61.3	53.0	(19)
(20)			MCWB	49.0	48.5	52.6	59.8	64.9	70.3	69.6	68.5	66.1	60.3	55.2	49.0	(20)
(21)		2%	DB	50.1	52.7	60.6	72.2	79.2	85.0	88.0	87.3	78.5	67.4	57.4	49.7	(21)
(22)			MCWB	45.6	46.8	49.7	56.9	63.3	68.8	68.5	67.7	64.3	58.5	52.8	46.2	(22)
(23)		5%	DB	46.3	49.4	56.5	68.1	75.1	80.7	84.1	83.7	74.3	63.9	54.1	46.9	(23)
(24)			MCWB	42.9	44.5	47.9	55.2	61.2	66.0	67.4	66.9	62.4	57.2	50.4	43.8	(24)
(25)		10%	DB	43.0	45.7	52.5	64.1	71.3	77.1	80.3	79.9	70.5	60.6	51.2	44.4	(25)
(26)			MCWB	40.2	41.8	46.1	52.9	59.5	64.6	65.9	65.6	60.5	55.5	48.2	41.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	49.6	53.9	61.0	68.0	73.0	72.3	71.8	67.7	62.1	56.3	49.4	(27)
(28)			MCDWB	53.9	54.8	62.7	74.4	79.9	86.2	85.6	84.2	79.9	68.5	59.8	52.3	(28)
(29)		2%	WB	46.1	47.4	51.1	58.5	64.8	70.1	70.2	69.9	65.5	59.9	53.3	46.5	(29)
(30)			MCDWB	49.5	52.0	58.5	70.0	75.4	82.4	82.9	83.2	75.5	65.3	56.5	49.3	(30)
(31)		5%	WB	43.2	44.9	49.0	56.1	62.7	67.6	68.8	68.2	63.7	58.0	50.9	44.0	(31)
(32)			MCDWB	46.2	49.1	55.4	65.8	72.4	77.5	80.7	80.3	72.0	62.9	53.8	46.5	(32)
(33)		10%	WB	40.3	42.0	46.5	53.8	60.8	65.6	67.3	66.7	61.8	56.0	48.4	42.1	(33)
(34)			MCDWB	42.8	45.6	51.8	63.0	69.9	74.9	78.0	77.4	69.2	60.3	50.7	44.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	11.6	14.9	19.1	19.2	18.8	19.2	20.0	17.4	14.1	9.7	8.5	(35)
(36)			MCDBR	12.0	15.7	23.1	26.3	25.5	25.4	26.4	26.2	23.9	19.1	13.9	10.8	(36)
(37)			MCWBR	9.2	11.0	13.9	13.9	12.6	11.8	10.2	10.6	11.7	11.5	10.1	8.5	(37)
(38)		5% WB	MCDWB	11.7	14.7	20.3	24.2	22.9	23.4	23.2	22.9	21.2	17.5	12.2	10.4	(38)
(39)			MCWBR	9.4	10.8	13.1	13.4	12.2	11.5	9.9	10.1	11.1	11.2	9.5	8.4	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.310	0.333	0.376	0.420	0.421	0.422	0.437	0.430	0.395	0.368	0.340	0.307	(40)
(41)	taud		2.352	2.321	2.252	2.174	2.212	2.245	2.209	2.245	2.310	2.359	2.386	2.388	(41)	
(42)	Ebn at Noon		230	253	260	260	266	266	259	255	252	237	216	214	(42)	
(43)	Edh at Noon		21	28	36	43	43	42	43	39	33	27	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	275	537	855	1321	1581	1708	1619	1436	1022	594	285	206	(44)	
(45)		RadStd	48	75	133	173	180	139	177	142	137	85	36	23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.03	N/A	N/A	+1.46	N/A	N/A	N/A	N/A	N/A	+72
(47)	Regional (60 neighbors)	+0.86	N/A	N/A	N/A	+0.63	+0.59	N/A	N/A	+110	+40

Nomenclature: See separate page