

KOSETICE, Czech Republic

WMO: 116280

Lat: 49.5736N

Lon: 15.0806E

Elev: 1746

StdP: 13.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.3	13.0	3.1	6.9	9.6	8.3	9.0	14.9	28.9	38.8	25.7	38.1	4.7	280	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	84.5	66.0	81.0	65.0	77.7	63.7	68.1	79.8	66.4	77.8	64.9	75.2	7.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	95.5	72.1	62.5	90.4	70.7	61.1	85.7	69.0	33.4	79.6	32.0	77.9	30.8	75.6	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.0	18.8	16.4	1.4	89.7	6.5	3.4	-3.3	92.1	-7.1	94.2	-10.7	96.1	-15.5	98.6		
			1.1	71.3	6.4	2.6	-3.5	73.2	-7.3	74.7	-10.8	76.1	-15.5	78.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	28.8	31.2	37.6	46.8	54.6	60.6	64.0	63.9	55.6	47.2	38.7	31.2
	DBStd	14.51	8.71	8.96	7.76	7.85	6.77	6.62	6.00	6.05	6.33	7.20	7.04	8.07
	HDD50	2840	658	526	387	149	32	3	0	0	19	140	344	582
	HDD65	6816	1123	946	848	546	326	164	93	94	288	551	790	1047
	CDD50	1663	0	0	4	53	176	320	435	431	186	54	4	0
	CDD65	165	0	0	0	0	5	31	63	60	6	0	0	0
	CDH74	1646	0	0	0	5	57	319	624	584	57	0	0	0
	CDH80	399	0	0	0	0	5	68	164	154	8	0	0	0
Wind	WSAvg	7.6	9.0	8.4	8.5	7.5	7.1	6.7	6.6	6.2	6.8	7.2	8.0	8.7
Precipitation	PrecAvg	26.5	1.7	1.4	1.9	1.5	2.7	3.1	3.5	3.2	2.2	1.7	1.8	1.7
	PrecMax	34.1	3.4	2.8	5.0	3.0	5.2	7.5	7.3	7.8	4.8	3.9	3.7	3.0
	PrecMin	19.6	0.4	0.2	0.4	0.1	0.3	1.1	0.9	1.3	0.4	0.2	0.0	0.6
	PrecStd	3.7	0.9	0.8	0.9	0.7	1.1	1.2	1.4	1.7	1.2	0.9	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.5	53.9	62.7	73.7	79.4	86.2	89.2	89.5	79.9	69.6	58.4	50.2
		MCWB	46.0	45.7	50.1	56.8	62.7	66.1	67.9	65.5	63.5	58.6	52.6	46.4
	2%	DB	46.6	49.5	57.4	68.3	75.0	81.8	84.5	84.1	74.5	64.8	54.0	46.8
		MCWB	43.3	43.7	47.9	54.6	61.2	66.2	66.2	65.6	61.9	56.6	50.0	43.9
	5%	DB	43.3	46.1	53.1	64.5	71.4	77.5	80.8	80.2	70.4	61.1	51.3	44.2
		MCWB	40.6	41.8	45.8	52.8	59.1	63.8	65.1	64.5	60.1	55.1	48.2	41.7
	10%	DB	40.3	42.8	49.1	60.5	67.5	74.0	77.2	76.5	66.8	57.7	48.5	41.5
		MCWB	38.2	39.6	43.7	50.4	57.0	62.3	63.9	63.0	58.4	53.3	46.0	39.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.9	47.4	51.5	58.1	65.6	70.1	70.4	69.4	65.7	60.3	53.4	46.8
		MCDB	49.5	52.2	60.6	71.3	76.4	81.4	83.0	81.8	74.3	66.6	56.7	49.0
	2%	WB	43.6	44.6	48.8	55.6	62.5	67.4	68.2	67.2	63.2	57.7	50.8	44.5
		MCDB	45.9	48.4	55.2	66.5	71.7	78.4	79.8	79.6	72.2	62.9	53.6	46.8
	5%	WB	40.8	42.2	46.6	53.5	60.2	65.1	66.6	65.6	61.1	55.8	48.4	41.9
		MCDB	43.1	45.6	52.2	62.9	69.1	75.0	78.0	77.3	68.7	60.1	50.9	43.9
	10%	WB	38.3	39.6	44.2	51.4	58.1	63.1	64.9	64.1	59.3	53.9	46.2	39.7
		MCDB	40.2	42.8	48.3	59.4	66.2	72.1	74.9	74.4	65.8	57.5	48.3	41.4
Mean Daily Temperature Range	5% DB	MDBR	8.4	10.4	12.8	16.6	17.1	17.9	18.5	18.6	15.5	12.7	8.7	8.0
		MCDBR	10.7	14.4	20.6	22.9	22.9	24.1	25.0	24.6	21.3	17.8	12.8	10.8
		MCWBR	8.5	9.9	12.6	12.2	11.8	11.1	10.6	10.2	10.6	10.8	9.2	8.6
	5% WB	MCDBR	10.2	12.7	18.1	21.3	21.0	21.6	22.3	21.8	19.3	16.4	11.7	10.3
		MCWBR	8.4	9.5	12.0	11.9	11.5	10.9	10.2	10.0	10.5	10.5	8.9	8.7
Clear-Sky Solar Irradiance	taub	0.295	0.317	0.358	0.399	0.401	0.402	0.415	0.409	0.378	0.351	0.324	0.294	
	taud	2.367	2.346	2.291	2.227	2.258	2.284	2.252	2.287	2.344	2.398	2.422	2.413	
	Ebn at Noon	239	261	268	268	272	272	266	262	259	245	226	224	
	Edh at Noon	21	27	34	41	41	40	41	38	32	26	20	18	
All-Sky Solar Radiation	RadAvg	287	563	884	1335	1588	1725	1642	1459	1036	609	296	219	
	RadStd	50	76	137	176	182	138	171	145	138	85	38	26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (72 neighbors)	+0.85	N/A	N/A	N/A	+0.61	+0.56	N/A	N/A	+104	+38

Nomenclature: See separate page