

KOSETICE, Czech Republic

WMO: 116280

Lat: 49.5736N

Lon: 15.0806E

Elev: 532

StdP: 95.09

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.2	-10.5	-16.1	1.0	-12.4	-13.2	1.3	-9.5	12.9	3.8	11.5	3.4	2.1	280	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	29.2	18.9	27.2	18.3	25.4	17.6	20.1	26.6	19.1	25.5	18.3	24.0	3.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.8	13.6	22.3	17.0	12.9	21.5	16.1	12.2	20.6	59.8	26.5	56.6	25.5	53.8	24.2	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.3	-17.0	32.0	3.6	1.9	-19.6	33.4	-21.7	34.5	-23.7	35.6	-26.4	37.0		
(5)			-17.2	21.9	3.5	1.4	-19.7	22.9	-21.8	23.7	-23.8	24.5	-26.4	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-1.8	-0.4	3.1	8.2	12.6	15.9	17.8	17.7	13.1	8.5	3.7	-0.4		
	DBStd	8.06	4.84	4.98	4.31	4.36	3.76	3.68	3.33	3.36	3.52	4.00	3.91	4.48		
	HDD10.0	1578	366	292	215	83	18	2	0	0	11	78	191	323		
	HDD18.3	3787	624	526	471	303	181	91	52	52	160	306	439	582		
	CDD10.0	924	0	0	2	29	98	178	242	239	103	30	2	0		
	CDD18.3	92	0	0	0	0	3	17	35	33	3	0	0	0		
	CDH23.3	914	0	0	0	3	32	177	347	324	32	0	0	0		
	CDH26.7	222	0	0	0	0	3	38	91	86	4	0	0	0		
(14) Wind	WSAvg	3.4	4.0	3.8	3.8	3.4	3.2	3.0	3.0	2.8	3.0	3.2	3.6	3.9		
(15) Precipitation	PrecAvg	673	44	35	48	38	69	80	90	81	56	44	45	42		
	PrecMax	867	87	71	126	76	131	190	186	198	121	98	95	76		
	PrecMin	497	9	6	11	3	7	27	22	32	9	6	1	14		
	PrecStd	95	22	20	24	19	29	31	36	42	30	23	23	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	12.2	17.1	23.2	26.3	30.1	31.8	32.0	26.6	20.9	14.6	10.1		
		MCWB	7.8	7.6	10.1	13.8	17.0	18.9	19.9	18.6	17.5	14.8	11.5	8.0		
	2%	DB	8.1	9.7	14.1	20.2	23.9	27.7	29.1	28.9	23.6	18.2	12.2	8.2		
		MCWB	6.3	6.5	8.8	12.6	16.2	19.0	19.0	18.7	16.6	13.7	10.0	6.6		
	5%	DB	6.3	7.8	11.7	18.1	21.9	25.3	27.1	26.8	21.3	16.2	10.7	6.8		
		MCWB	4.8	5.5	7.6	11.5	15.1	17.7	18.4	18.1	15.6	12.9	9.0	5.4		
	10%	DB	4.6	6.0	9.5	15.8	19.7	23.3	25.1	24.7	19.3	14.3	9.2	5.3		
		MCWB	3.4	4.2	6.5	10.2	13.9	16.8	17.7	17.2	14.7	11.9	7.8	4.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	8.6	10.9	14.5	18.7	21.2	21.4	20.8	18.7	15.7	11.9	8.2		
		MCDB	9.7	11.2	15.9	21.8	24.7	27.5	28.3	27.7	23.5	19.2	13.7	9.4		
	2%	WB	6.4	7.0	9.4	13.1	16.9	19.7	20.1	19.6	17.3	14.3	10.5	6.9		
		MCDB	7.7	9.1	12.9	19.2	22.0	25.8	26.6	26.4	22.3	17.2	12.0	8.2		
	5%	WB	4.9	5.7	8.1	11.9	15.7	18.4	19.2	18.7	16.2	13.2	9.1	5.5		
		MCDB	6.2	7.5	11.2	17.2	20.6	23.9	25.5	25.2	20.4	15.6	10.5	6.6		
	10%	WB	3.5	4.2	6.8	10.8	14.5	17.3	18.3	17.8	15.2	12.2	7.9	4.3		
		MCDB	4.6	6.0	9.1	15.2	19.0	22.3	23.8	23.5	18.8	14.2	9.0	5.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.8	7.1	9.2	9.5	9.9	10.3	10.4	8.6	7.1	4.8	4.5		
		MCDBR	6.0	8.0	11.4	12.7	12.7	13.4	13.9	13.7	11.8	9.9	7.1	6.0		
		MCWBR	4.7	5.5	7.0	6.8	6.6	6.1	5.9	5.7	5.9	6.0	5.1	4.8		
		MCWBR	5.7	7.1	10.1	11.9	11.7	12.0	12.4	12.1	10.7	9.1	6.5	5.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.295	0.317	0.358	0.399	0.401	0.402	0.415	0.409	0.378	0.351	0.324	0.294		
		taud	2.367	2.346	2.291	2.227	2.258	2.284	2.252	2.287	2.344	2.398	2.422	2.413		
		Ebn at Noon	754	824	844	844	858	858	839	826	815	773	712	706		
		Edh at Noon	66	86	108	128	129	127	130	120	102	81	63	56		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.90	1.78	2.79	4.21	5.01	5.44	5.17	4.60	3.27	1.92	0.93	0.69		
		RadStd	0.16	0.24	0.43	0.56	0.57	0.43	0.54	0.46	0.44	0.27	0.12	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (72 neighbors)	+0.47	N/A	N/A	N/A	+0.34	+0.31	N/A	N/A	+58	+21

Nomenclature: See separate page