

KOSTELNI MYSLOVA, Czech RepublicWMO: **116360**Lat: **49.1592N**Lon: **15.4392E**Elev: **572**StdP: **94.63**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-10.3	-15.9	1.0	-12.0	-13.0	1.3	-8.8	11.4	-0.3	10.1	0.9	2.0	340	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	29.4	18.6	27.3	18.1	25.5	17.4	19.8	26.5	18.9	25.4	18.1	24.1	3.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	13.5	22.2	16.7	12.7	21.1	15.9	12.1	20.4	59.1	26.7	56.2	25.5	53.4	24.1	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.5	6.5	-15.9	32.3	2.8	2.2	-17.9	33.9	-19.5	35.2	-21.1	36.4	-23.1	38.0		
(5)			-16.2	21.4	2.7	1.0	-18.2	22.1	-19.8	22.7	-21.3	23.2	-23.3	23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-2.2	-0.7	3.2	8.4	12.8	16.3	18.3	18.1	13.3	8.3	3.1	-1.2
	DBStd	8.30	4.51	4.68	4.21	4.29	3.72	3.69	3.45	3.48	3.55	3.86	3.95	4.15
	HDD10.0	1631	379	299	212	78	16	1	0	1	9	80	208	346
	HDD18.3	3816	638	532	469	298	175	83	46	47	156	311	457	604
	CDD10.0	967	0	0	2	31	102	189	256	251	107	27	2	0
	CDD18.3	110	0	0	0	0	3	21	43	39	4	0	0	0
	CDH23.3	960	0	0	0	2	23	174	384	346	30	0	0	0
	CDH26.7	240	0	0	0	0	2	34	106	94	4	0	0	0
(14) Wind	WSAvg	2.9	3.4	3.2	3.3	3.1	2.8	2.4	2.4	2.4	2.6	2.8	3.3	3.2
(15) Precipitation	PrecAvg	688	47	38	50	40	69	83	86	80	58	45	47	44
	PrecMax	973	104	88	128	81	143	171	185	243	141	100	101	85
	PrecMin	541	8	7	12	3	15	31	29	24	7	5	1	13
	PrecStd	103	27	23	26	20	28	35	34	45	31	25	24	19
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	12.2	17.1	22.7	25.8	30.1	32.0	32.2	26.6	20.7	14.2	9.6
		MCWB	7.3	7.2	9.5	13.8	16.6	19.1	18.9	18.6	17.1	14.3	10.7	7.3
	2%	DB	7.5	9.3	14.3	19.9	23.4	27.3	29.5	29.4	23.5	17.5	11.8	7.5
		MCWB	5.5	6.1	8.4	12.3	15.9	18.9	18.5	18.4	16.2	13.4	9.7	6.1
	5%	DB	5.6	7.4	11.6	17.8	21.6	25.3	27.3	27.0	21.4	15.5	10.1	5.7
		MCWB	4.1	4.9	7.2	11.2	14.8	17.6	18.0	17.8	15.3	12.3	8.7	4.6
	10%	DB	3.7	5.5	9.3	15.7	19.7	23.5	25.4	25.0	19.4	13.7	8.5	4.2
		MCWB	2.6	3.6	6.1	10.1	13.8	16.7	17.4	17.0	14.4	11.6	7.4	3.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	8.2	10.5	14.4	18.2	21.1	20.8	20.8	18.0	15.3	11.6	7.6
		MCDB	9.9	11.1	15.5	21.3	24.2	27.4	28.2	28.0	24.2	18.4	13.3	8.9
	2%	WB	5.8	6.6	9.0	13.0	16.7	19.6	19.7	19.4	16.8	13.9	10.2	6.2
		MCDB	7.1	8.8	13.1	18.9	21.9	25.7	26.3	26.5	22.0	16.5	11.4	7.4
	5%	WB	4.2	5.2	7.8	11.7	15.5	18.5	18.8	18.5	15.9	12.9	8.8	4.8
		MCDB	5.4	7.2	11.1	16.7	20.3	23.9	25.4	25.1	20.3	14.9	9.9	5.6
	10%	WB	2.7	3.7	6.5	10.5	14.4	17.3	18.0	17.7	15.0	11.9	7.5	3.4
		MCDB	3.7	5.3	8.9	15.2	18.7	22.2	24.0	23.5	18.6	13.5	8.4	4.1
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	6.2	7.7	9.5	9.4	10.0	10.3	10.4	8.5	6.8	4.6	4.4
		MCDBR	6.7	8.7	11.8	12.3	12.0	12.7	13.6	13.5	11.8	9.6	7.1	6.4
		MCWBR	5.1	5.9	6.8	6.3	5.9	5.7	5.2	5.1	5.4	5.8	5.0	5.2
		MCDBR	6.4	8.1	10.5	11.4	11.2	11.8	12.1	12.1	10.5	8.4	6.0	6.2
	5% WB	MCWBR	5.1	5.8	6.5	6.1	5.9	5.7	5.1	5.1	5.2	5.4	4.7	5.1
(40) Clear-Sky Solar Irradiance	taub	0.294	0.316	0.356	0.397	0.399	0.401	0.411	0.407	0.377	0.350	0.324	0.293	
	taud	2.372	2.349	2.299	2.234	2.266	2.290	2.263	2.292	2.344	2.398	2.421	2.421	
	Ebn at Noon	763	830	850	848	861	860	844	829	817	778	719	716	
	Edh at Noon	66	86	108	128	129	127	128	119	102	82	64	56	
(44) All-Sky Solar Radiation	RadAvg	0.94	1.82	2.85	4.25	5.00	5.45	5.21	4.64	3.30	1.98	0.98	0.73	
	RadStd	0.16	0.24	0.41	0.55	0.58	0.45	0.53	0.46	0.44	0.26	0.12	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.46	N/A	N/A	+0.78	+0.44	+0.46	-102	-156	+84	N/A