

PEC POD SNEZKOU, Czech Republic

WMO: 116430

Lat: 50.6919N

Lon: 15.7289E

Elev: 821

StdP: 91.85

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.5	-13.2	-18.5	0.8	-13.5	-16.2	1.0	-12.0	7.8	-3.4	6.6	-2.0	0.9	220	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	25.6	17.0	23.7	16.1	22.0	15.4	17.9	23.3	17.0	22.1	16.2	20.7	3.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	12.6	19.6	15.2	11.9	18.7	14.4	11.3	18.0	53.9	23.1	51.0	22.0	48.3	20.8	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.5	4.9	-18.3	28.5	2.4	1.7	-20.0	29.7	-21.4	30.7	-22.8	31.7	-24.5	32.9		
(5)			-18.5	19.8	2.4	0.9	-20.2	20.4	-21.6	21.0	-22.9	21.5	-24.7	22.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-3.7	-2.7	0.2	4.9	9.6	12.8	14.8	14.4	10.3	6.0	1.6	-2.5	(6)
(7)		DBStd	7.58	4.16	4.58	3.95	4.03	3.63	3.50	3.17	3.17	3.37	3.86	3.76	4.15	(7)
(8)		HDD10.0	2120	424	356	305	157	53	12	1	3	38	132	252	387	(8)
(9)		HDD18.3	4694	682	589	563	402	272	169	117	128	242	381	502	646	(9)
(10)		CDD10.0	482	0	0	0	5	39	96	149	139	46	8	0	0	(10)
(11)		CDD18.3	15	0	0	0	0	0	3	7	5	0	0	0	0	(11)
(12)		CDH23.3	193	0	0	0	0	5	38	91	57	3	0	0	0	(12)
(13)		CDH26.7	25	0	0	0	0	1	3	14	8	0	0	0	0	(13)
(14)	Wind	WSAvg	2.0	2.1	2.1	2.1	1.9	2.1	2.1	2.0	1.9	1.9	2.0	2.1	(14)	
(15)	Precipitation	PrecAvg	985	86	70	76	47	75	96	116	99	81	68	80	90	(15)
(16)		PrecMax	1221	197	166	192	95	137	195	306	280	175	198	174	189	(16)
(17)		PrecMin	699	9	14	25	4	36	40	32	39	24	15	2	41	(17)
(18)		PrecStd	135	45	35	40	21	31	36	55	59	40	39	37	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	8.7	13.2	20.1	23.7	26.8	28.5	27.6	22.9	18.2	11.9	7.1	(19)
(20)			MCWB	4.9	4.4	6.4	12.2	15.1	17.9	17.5	17.4	15.6	13.1	9.0	5.6	(20)
(21)		2%	DB	4.6	6.2	10.1	17.0	21.1	24.4	25.9	24.8	20.6	15.3	9.8	5.3	(21)
(22)			MCWB	3.6	3.8	5.0	10.1	14.0	16.7	17.0	16.8	14.4	11.5	8.2	4.5	(22)
(23)		5%	DB	3.0	4.4	7.4	14.5	18.9	22.2	23.6	22.9	18.4	13.3	8.2	3.9	(23)
(24)			MCWB	2.2	2.9	4.0	8.6	12.7	15.4	16.1	16.0	13.4	10.7	7.1	3.3	(24)
(25)		10%	DB	1.7	2.9	5.4	12.3	16.8	20.1	21.6	21.0	16.2	11.7	6.8	2.6	(25)
(26)			MCWB	0.9	1.6	3.3	7.5	11.4	14.4	15.6	15.2	12.6	9.9	5.9	2.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	6.3	7.6	12.7	16.3	19.1	19.2	18.7	16.7	13.7	9.8	6.1	(27)
(28)			MCD B	5.8	7.5	11.5	18.9	22.0	25.3	24.6	23.8	21.2	16.3	11.0	6.6	(28)
(29)		2%	WB	3.8	4.4	5.9	10.8	14.6	17.5	17.8	17.6	15.2	12.2	8.5	4.6	(29)
(30)			MCD B	4.3	5.5	8.6	15.7	19.4	22.6	23.4	22.8	18.8	14.4	9.6	5.1	(30)
(31)		5%	WB	2.2	3.1	4.7	9.2	13.4	16.2	17.0	16.7	14.1	11.1	7.2	3.3	(31)
(32)			MCD B	2.8	4.1	6.9	13.4	17.8	20.8	22.2	21.5	17.3	12.9	8.1	3.8	(32)
(33)		10%	WB	1.1	1.8	3.5	7.8	12.2	15.0	16.1	15.9	13.0	10.0	6.0	2.1	(33)
(34)			MCD B	1.6	2.8	5.2	11.3	16.0	19.3	20.7	19.9	15.8	11.6	6.7	2.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.9	6.5	7.2	9.5	9.8	9.6	10.0	8.4	7.0	5.4	5.5	(35)	
(36)			MCD BR	6.3	7.8	11.0	14.1	13.4	13.6	13.6	13.0	12.1	10.3	7.3	6.1	(36)
(37)			MCWBR	5.2	5.6	6.6	7.6	7.0	6.9	6.1	6.0	6.5	6.5	5.5	5.1	(37)
(38)		5% WB	MCD BR	5.3	6.3	9.3	13.0	12.2	12.2	11.9	11.5	10.6	9.0	6.6	5.1	(38)
(39)			MCWBR	4.7	5.2	6.2	7.5	6.8	6.6	5.9	5.9	6.2	6.1	5.3	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.320	0.364	0.411	0.409	0.405	0.423	0.416	0.377	0.352	0.324	0.290	(40)	
(41)		taud	2.301	2.274	2.213	2.153	2.201	2.245	2.198	2.234	2.314	2.351	2.359	2.346	(41)	
(42)		Ebn at Noon	728	803	827	826	846	852	828	813	807	757	685	678	(42)	
(43)		Edh at Noon	67	89	115	137	136	132	136	125	103	83	64	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.80	1.54	2.55	4.09	4.96	5.28	4.99	4.43	3.16	1.81	0.86	0.58	(44)	
(45)		RadStd	0.14	0.24	0.39	0.54	0.57	0.45	0.59	0.43	0.43	0.26	0.11	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	+0.45	N/A	N/A	N/A	+0.33	+0.32	N/A	N/A	+58	+21

Nomenclature: See separate page