

PRIBYSLAV, Czech Republic

WMO: 116590

Lat: 49.5828N

Lon: 15.7625E

Elev: 1760

StdP: 13.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.2	12.0	1.2	6.2	7.5	6.9	8.4	13.4	31.7	35.2	28.4	32.9	5.0	120	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	84.1	66.5	80.6	65.4	77.4	64.0	68.4	80.2	66.7	77.9	65.1	75.2	8.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	96.5	74.2	62.7	91.0	71.4	61.2	86.1	69.7	33.7	80.2	32.3	78.1	31.0	75.4	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
25.7	22.5	19.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-0.3	88.6	6.9	3.5	-5.3	91.2	-9.3	93.2	-13.2	95.2	-18.2	97.8
			-0.9	71.7	6.8	1.9	-5.8	73.1	-9.8	74.2	-13.6	75.3	-18.5	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	27.8	30.4	37.1	46.3	54.1	59.9	63.6	63.4	55.1	46.6	37.9	30.0
	DBStd	14.61	8.42	8.71	7.35	7.66	6.71	6.61	5.95	6.17	6.24	6.98	7.30	7.94
	HDD50	2996	688	550	402	157	35	5	0	1	21	151	365	621
	HDD65	7041	1153	970	865	561	340	178	99	105	301	570	813	1086
	CDD50	1575	0	0	2	46	163	303	423	415	175	45	3	0
	CDD65	145	0	0	0	0	3	26	57	54	5	0	0	0
	CDH74	1519	0	0	0	2	44	269	603	553	48	0	0	0
	CDH80	345	0	0	0	0	3	49	147	142	4	0	0	0
Wind	WSAvg	9.3	10.4	10.0	10.2	9.6	9.1	8.0	7.8	7.6	8.5	9.5	10.4	10.3
Precipitation	PrecAvg	27.6	1.8	1.5	2.0	1.5	3.0	3.1	3.9	3.3	2.5	1.7	1.8	1.7
	PrecMax	33.2	3.6	3.1	6.0	3.0	4.9	6.1	9.8	8.3	6.1	3.9	3.9	2.9
	PrecMin	20.8	0.5	0.4	0.6	0.2	0.4	0.9	1.3	1.1	0.6	0.2	0.0	0.6
	PrecStd	3.6	0.8	0.8	1.1	0.7	1.1	1.3	1.8	1.9	1.5	0.9	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	52.1	61.6	72.6	78.6	85.3	88.2	88.8	79.2	68.1	56.7	48.7
		MCWB	44.4	44.7	49.9	57.6	64.7	68.2	66.5	67.9	62.7	58.0	51.5	45.1
	2%	DB	44.8	47.7	56.5	68.0	74.2	80.6	84.1	84.1	74.3	63.5	53.5	45.1
		MCWB	41.8	43.0	47.5	54.7	61.9	66.5	66.2	66.4	61.4	56.4	49.8	42.7
	5%	DB	41.6	44.6	52.0	63.9	70.8	76.9	80.6	80.1	70.2	59.9	50.6	42.3
		MCWB	39.2	40.9	45.1	52.7	59.7	64.6	65.3	65.1	59.8	54.4	47.8	40.2
	10%	DB	38.6	41.1	48.1	60.0	67.2	73.4	77.1	76.4	66.4	56.8	48.0	39.8
		MCWB	36.6	38.1	43.1	50.7	57.5	62.5	63.9	63.5	58.0	52.9	45.8	38.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.2	46.2	51.2	58.8	66.4	70.5	70.7	70.3	65.2	59.8	52.8	45.6
		MCDB	48.0	50.4	59.9	70.2	76.2	81.7	82.1	83.1	75.2	65.9	55.3	47.9
	2%	WB	42.1	43.7	48.4	56.0	62.9	67.9	68.2	67.9	62.7	57.2	50.5	42.9
		MCDB	44.4	46.9	54.8	66.3	72.3	78.5	79.9	81.0	70.8	61.8	53.1	45.1
	5%	WB	39.4	41.2	46.2	53.6	60.6	65.7	66.4	66.2	60.8	55.3	48.0	40.5
		MCDB	41.4	44.3	51.3	61.9	69.3	74.9	77.5	78.0	68.7	59.2	50.2	42.0
	10%	WB	36.8	38.4	43.6	51.3	58.3	63.6	64.7	64.5	58.9	53.3	45.8	38.4
		MCDB	38.5	40.9	47.3	58.7	65.6	71.6	74.7	74.4	65.3	56.6	47.8	39.8
Mean Daily Temperature Range	5% DB	MDBR	8.6	10.8	13.5	17.4	17.9	18.6	19.4	19.6	16.0	12.5	8.3	7.6
		MCDBR	11.0	14.7	21.2	24.0	23.5	24.0	26.1	25.3	22.6	17.1	11.8	9.8
		MCWBR	8.7	10.4	13.3	13.2	13.3	12.3	11.4	11.3	11.7	10.8	8.7	8.0
	5% WB	MCDBR	10.5	13.3	19.5	21.3	21.7	21.9	22.9	22.9	20.3	15.9	10.6	9.3
		MCWBR	8.7	10.2	12.9	12.6	13.0	12.3	11.4	11.1	11.4	10.5	8.3	7.9
Clear-Sky Solar Irradiance	taub	0.295	0.318	0.359	0.402	0.403	0.404	0.416	0.411	0.380	0.353	0.327	0.294	
	taud	2.346	2.325	2.278	2.218	2.253	2.280	2.248	2.279	2.336	2.385	2.402	2.395	
	Ebn at Noon	238	260	267	267	272	272	266	261	258	244	224	223	
	Edh at Noon	21	28	35	41	41	41	41	38	33	26	20	18	
All-Sky Solar Radiation	RadAvg	283	552	880	1336	1591	1724	1641	1462	1037	607	295	215	
	RadStd	49	74	140	171	185	142	172	143	141	87	37	24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+0.90	N/A	N/A	N/A	N/A	N/A	N/A	-283	+86	N/A	
Regional (73 neighbors)	+0.88	N/A	N/A	N/A	+0.65	+0.59	N/A	-266	+115	+43	

Nomenclature: See separate page